

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 18-May-2026

Sub - Report 15

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
PANIPAT TPS	6	210.00	5/18/26, 10:35 AM	2026-05-21	TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE
KALISINDH TPS	1	600.00	5/18/26, 10:49 PM		TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE
SHREE CEMENT LTD TPS	3	19.00	5/18/26, 5:09 AM	2026-05-18 16:04:00	RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	4	19.00	5/18/26, 5:09 AM	2026-05-18 15:55:00	RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	5	6.00	5/18/26, 5:06 AM	2026-05-18 16:03:00	RSD/LOW SCHEDULE
ANPARA TPS	7	500.00	5/18/26, 10:30 AM		ECONOMISER TUBE LEAKAGE
PATHADI TPP	1	300.00	5/18/26, 6:47 AM		AIR PREHEATERS PROBLEM
NORTH CHENNAI TPS STAGE 3	6	800.00	5/18/26, 11:30 PM	2026-05-20	TRIPPING OF TRANSMISSION LINE
NEYVELI TPS-II	5	210.00	5/18/26, 7:31 AM	2026-05-18 13:15:00	FURNACE DRAFT ABNORMAL
BARH STPS	2	660.00	5/18/26, 5:14 PM		AIR SUPPLY FAILURE
MEJIA TPS	6	250.00	5/18/26, 8:54 AM	2026-05-18 16:28:11	GENERATOR MISCLLANEOUS MAINTENANCE
NORTH KARANPURA TPP	2	660.00	5/18/26, 12:50 PM		CONDENSATE PUMP problem
TALCHER STPS	6	500.00	5/18/26, 3:23 PM	2026-05-18 19:12:00	ELECTRICAL MISCELLANEOUS PROBLEMS
AGARTALA GT	2	21.00	5/18/26, 12:00 AM	2026-05-18 23:59:59	Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	5	9.96	5/18/26, 2:30 AM	2026-05-18 19:28:00	GRID DISTURBENCE
KATHALGURI CCPP	5	33.50	5/18/26, 12:00 AM	2026-05-18 23:59:59	Low system demand/ costly fuel
Total		4798.47			

Note: 1.Actual generation is gross generation from stations above 25 MW. It excludes generation from RES.
2.Data published in this report is for operational purpose only and not for commercial purpose.
3.Generation data/Outage data are compiled based on data submitted directly by the utilities."

Remarks:-

Report Version :-