

**CENTRAL ELECTRICITY AUTHORITY  
G O & D WING  
OPERATION PERFORMANCE MONITORING DIVISION**

**THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 18-11-2020**

Sub-Report - 15

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
JALIPA KAPURDI TPP	4	135.00	18/11/2020 22:04		BOILER MISC. PROBLEM
JALIPA KAPURDI TPP	7	135.00	18/11/2020 12:02		BOILER MISC. PROBLEM
RIHAND STPS	2	500.00	18/11/2020 05:53		C&I PROBLEM
LARA TPP	2	800.00	18/11/2020 01:30		WATER WALL TUBE LEAKAGE
BANDAKHAR TPP	1	300.00	18/11/2020 07:29	18/11/2020	I.D. FANS PROBLEM
KUTCH LIG. TPS	4	75.00	18/11/2020 23:45		ELECTRICAL MISCELLANEOUS PROBLEMS
SHREE SINGAJI TPP	2	600.00	18/11/2020 09:18		WATER WALL TUBE LEAKAGE
KORADI TPS	8	660.00	18/11/2020 19:47		GEN. TRANSORMER PROTECTION RELAY OPERATION PROBLEM
KONDAPALLI CCPP	1	118.65	18/11/2020 00:00		Fuel Shortage
TALCHER STPS	2	500.00	18/11/2020 10:49		WATER WALL TUBE LEAKAGE
SAGARDIGHI TPS	4	500.00	18/11/2020 23:59		BOILER INSPECTION/ RE-CERTIFICATION
SOUTHERN REPL. TPS	1	67.50	18/11/2020 19:39	19/11/2020	RESERVE SHUT DOWN / STANDBY UNIT
SOUTHERN REPL. TPS	2	67.50	18/11/2020 21:40	19/11/2020	RESERVE SHUT DOWN / STANDBY UNIT
BONGAIGAON TPP	1	250.00	18/11/2020 18:42		DRUM LEVEL LOW
KATHALGURI CCPP	1	33.50	18/11/2020 13:30		Fuel Shortage
KATHALGURI CCPP	4	33.50	18/11/2020 16:08		Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	1	9.96	18/11/2020 10:37		Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	2	9.96	18/11/2020 14:11		Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	3	9.96	18/11/2020 12:05		Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	5	9.96	18/11/2020 21:52		Fuel Shortage
NAMRUP CCPP	2	21.00	18/11/2020 10:55		Fuel Shortage
NAMRUP CCPP	3	21.00	18/11/2020 14:23		Fuel Shortage
AGARTALA GT	4	21.00	18/11/2020 00:05		GT-MISCELLANEOUS PROBLEMS
MONARCHAK CCPP	2	35.60	18/11/2020 06:05		GT-MISCELLANEOUS PROBLEMS
Total		4914.11			