

CENTRAL ELECTRICITY AUTHORITY  
G O & D WING  
OPERATION PERFORMANCE MONITORING DIVISION

**DAILY MAINTENANCE REPORT (COAL, LIGNITE AND NUCLEAR) 19-04-2021**

Sub-Report-10

| State/System    | Power Station      | Unit No. | Planned Maintenance (MW) | Forced Maintenance (Major) (MW) | Forced Maintenance (Minor) (MW) | Others Maintenance (MW) | Date& Time of Maintenance<br>DD/MM/YYYY<br>HH24:MM | Expected/sync Date of Return<br>DD/MM/YYYY<br>HH24:MM | Reasons/Present Status        |
|-----------------|--------------------|----------|--------------------------|---------------------------------|---------------------------------|-------------------------|----------------------------------------------------|-------------------------------------------------------|-------------------------------|
| 1               | 2                  | 3        | 4                        | 5                               | 6                               | 7                       | 8                                                  | 9                                                     | 10                            |
| <b>Northern</b> |                    |          |                          |                                 |                                 |                         |                                                    |                                                       |                               |
| Haryana         | PANIPAT TPS        | 6        | 0.00                     | 210.00                          | 0.00                            | 0.00                    | 23/07/2020 12:15                                   |                                                       | RSD/LOW SCHEDULE              |
| Haryana         | PANIPAT TPS        | 7        | 0.00                     | 0.00                            | 250.00                          | 0.00                    | 16/04/2021 19:24                                   |                                                       | RSD/LOW SCHEDULE              |
| Haryana         | PANIPAT TPS        | 8        | 0.00                     | 250.00                          | 0.00                            | 0.00                    | 01/04/2021 11:23                                   |                                                       | RSD/LOW SCHEDULE              |
| Haryana         | RAJIV GANDHI TPS   | 1        | 0.00                     | 600.00                          | 0.00                            | 0.00                    | 29/03/2021 09:40                                   |                                                       | RSD/LOW SCHEDULE              |
| Haryana         | RAJIV GANDHI TPS   | 2        | 0.00                     | 600.00                          | 0.00                            | 0.00                    | 18/09/2020 15:01                                   |                                                       | RSD/LOW SCHEDULE              |
| Punjab          | GH TPS (LEH.MOH.)  | 1        | 0.00                     | 210.00                          | 0.00                            | 0.00                    | 23/10/2020 19:00                                   |                                                       | RSD/LOW SCHEDULE              |
| Punjab          | GH TPS (LEH.MOH.)  | 2        | 0.00                     | 210.00                          | 0.00                            | 0.00                    | 22/09/2020 12:17                                   |                                                       | RSD/LOW SCHEDULE              |
| Punjab          | GH TPS (LEH.MOH.)  | 3        | 0.00                     | 250.00                          | 0.00                            | 0.00                    | 23/03/2021 13:50                                   |                                                       | RSD/LOW SCHEDULE              |
| Punjab          | GH TPS (LEH.MOH.)  | 4        | 0.00                     | 250.00                          | 0.00                            | 0.00                    | 23/03/2021 06:22                                   |                                                       | RSD/LOW SCHEDULE              |
| Punjab          | ROPAR TPS          | 3        | 0.00                     | 210.00                          | 0.00                            | 0.00                    | 21/03/2021 20:25                                   |                                                       | RSD/LOW SCHEDULE              |
| Punjab          | ROPAR TPS          | 4        | 0.00                     | 210.00                          | 0.00                            | 0.00                    | 21/03/2021 22:10                                   |                                                       | RSD/LOW SCHEDULE              |
| Punjab          | ROPAR TPS          | 5        | 210.00                   | 0.00                            | 0.00                            | 0.00                    | 01/04/2021 00:00                                   |                                                       | CAPITAL MAINTENANCE           |
| Punjab          | ROPAR TPS          | 6        | 0.00                     | 210.00                          | 0.00                            | 0.00                    | 06/11/2020 01:13                                   |                                                       | RSD/LOW SCHEDULE              |
| Punjab          | GOINDWAL SAHIB TPP | 1        | 0.00                     | 0.00                            | 270.00                          | 0.00                    | 18/04/2021 11:12                                   |                                                       | RSD/LOW SCHEDULE              |
| Punjab          | TALWANDI SABO TPP  | 3        | 660.00                   | 0.00                            | 0.00                            | 0.00                    | 08/03/2021 00:00                                   |                                                       | SCHEDULED ANNUAL MAINTENANCE  |
| Rajasthan       | BARSINGSAR LIGNITE | 2        | 0.00                     | 125.00                          | 0.00                            | 0.00                    | 18/03/2021 23:01                                   |                                                       | BOILER MISC. PROBLEM          |
| Rajasthan       | DAE (RAJASTHAN)    | 1        | 0.00                     | 100.00                          | 0.00                            | 0.00                    | 09/10/2004 22:58                                   |                                                       | GENERATOR EARTH FAULT         |
| Rajasthan       | CHHABRA TPP        | 1        | 0.00                     | 0.00                            | 250.00                          | 0.00                    | 16/04/2021 00:00                                   |                                                       | WATER SHORTAGE DUE TO DROUGHT |
| Rajasthan       | CHHABRA TPP        | 2        | 0.00                     | 250.00                          | 0.00                            | 0.00                    | 24/03/2021 11:30                                   |                                                       | TURBINE CONTROL VALVE PROBLEM |
| Rajasthan       | CHHABRA TPP        | 5        | 660.00                   | 0.00                            | 0.00                            | 0.00                    | 01/04/2021 00:00                                   |                                                       | SCHEDULED ANNUAL MAINTENANCE  |

## DAILY MAINTENANCE REPORT (COAL, LIGNITE AND NUCLEAR) 19-04-2021

Sub-Report-10

| State/System  | Power Station      | Unit No. | Planned Maintenance (MW) | Forced Maintenance (Major) (MW) | Forced Maintenance (Minor) (MW) | Others Maintenance (MW) | Date& Time of Maintenance<br>DD/MM/YYYY<br>HH24:MM | Expected/sync Date of Return<br>DD/MM/YYYY<br>HH24:MM | Reasons/Present Status              |
|---------------|--------------------|----------|--------------------------|---------------------------------|---------------------------------|-------------------------|----------------------------------------------------|-------------------------------------------------------|-------------------------------------|
| 1             | 2                  | 3        | 4                        | 5                               | 6                               | 7                       | 8                                                  | 9                                                     | 10                                  |
| Rajasthan     | GIRAL TPS          | 1        | 125.00                   | 0.00                            | 0.00                            | 0.00                    | 11/07/2014 08:20                                   |                                                       | UNIT LIKELY TO BE SCRAPPED.         |
| Rajasthan     | GIRAL TPS          | 2        | 125.00                   | 0.00                            | 0.00                            | 0.00                    | 27/01/2016 15:27                                   |                                                       | UNIT LIKELY TO BE SCRAPPED.         |
| Rajasthan     | KOTA TPS           | 3        | 0.00                     | 0.00                            | 0.00                            | 210.00                  | 11/12/2020 15:49                                   |                                                       | Low system demand/ costly fuel      |
| Rajasthan     | SURATGARH TPS      | 1        | 0.00                     | 0.00                            | 250.00                          | 0.00                    | 16/04/2021 03:17                                   |                                                       | DRUM LEVEL HIGH/ low                |
| Rajasthan     | SURATGARH TPS      | 2        | 0.00                     | 0.00                            | 250.00                          | 0.00                    | 10/04/2021 21:46                                   |                                                       | BOILER MISC. PROBLEM                |
| Rajasthan     | SURATGARH TPS      | 3        | 0.00                     | 0.00                            | 0.00                            | 250.00                  | 27/03/2021 20:14                                   |                                                       | Low system demand/ costly fuel      |
| Rajasthan     | SURATGARH TPS      | 4        | 0.00                     | 0.00                            | 250.00                          | 0.00                    | 10/04/2021 13:26                                   |                                                       | BOILER MISC. PROBLEM                |
| Rajasthan     | SURATGARH TPS      | 5        | 0.00                     | 0.00                            | 0.00                            | 250.00                  | 12/03/2021 20:12                                   |                                                       | Low system demand/ costly fuel      |
| Rajasthan     | SURATGARH TPS      | 6        | 0.00                     | 0.00                            | 0.00                            | 250.00                  | 21/03/2021 19:58                                   |                                                       | Low system demand/ costly fuel      |
| Rajasthan     | SURATGARH TPS      | 7        | 0.00                     | 0.00                            | 660.00                          | 0.00                    | 18/04/2021 08:12                                   |                                                       | ELECTRICAL MISCELLANEOUS PROBLEMS   |
| Rajasthan     | JALIPA KAPURDI TPP | 3        | 0.00                     | 0.00                            | 135.00                          | 0.00                    | 15/04/2021 20:03                                   | 19/04/2021 13:30                                      | BOILER MISC. PROBLEM                |
| Rajasthan     | JALIPA KAPURDI TPP | 6        | 0.00                     | 135.00                          | 0.00                            | 0.00                    | 18/03/2021 02:35                                   |                                                       | BOILER MISC. PROBLEM                |
| Rajasthan     | KAWAI TPS          | 2        | 0.00                     | 0.00                            | 660.00                          | 0.00                    | 19/04/2021 18:11                                   |                                                       | BOILER AUX. MISC. PROMLEMS          |
| Uttar Pradesh | RIHAND STPS        | 4        | 500.00                   | 0.00                            | 0.00                            | 0.00                    | 30/03/2021 23:10                                   |                                                       | OVERHAULING WORKS                   |
| Uttar Pradesh | SINGRAULI STPS     | 3        | 0.00                     | 200.00                          | 0.00                            | 0.00                    | 16/03/2021 11:43                                   |                                                       | TURBINE VIBRATIONS HIGH             |
| Uttar Pradesh | SINGRAULI STPS     | 7        | 0.00                     | 0.00                            | 500.00                          | 0.00                    | 18/04/2021 08:30                                   |                                                       | WATER WALL TUBE LEAKAGE             |
| Uttar Pradesh | UNCHAHAR TPS       | 2        | 0.00                     | 0.00                            | 0.00                            | 0.00                    | 19/04/2021 23:08                                   |                                                       | VARIOUS STEAM LEAKAGES              |
| Uttar Pradesh | ANPARA TPS         | 7        | 0.00                     | 500.00                          | 0.00                            | 0.00                    | 13/11/2019 14:13                                   |                                                       | HYDROGEN PRESSURE PROBLEM           |
| Uttar Pradesh | HARDUAGANJ TPS     | 7        | 0.00                     | 0.00                            | 105.00                          | 0.00                    | 15/04/2021 00:41                                   |                                                       | FURNACE FIRE OUT /FLAME FAILURE     |
| Uttar Pradesh | HARDUAGANJ TPS     | 8        | 250.00                   | 0.00                            | 0.00                            | 0.00                    | 13/03/2021 00:00                                   |                                                       | BOILER OVERHAUL/ ANNUAL MAINTENANCE |
| Uttar Pradesh | HARDUAGANJ TPS     | 9        | 0.00                     | 0.00                            | 250.00                          | 0.00                    | 16/04/2021 20:28                                   |                                                       | ELECTRICAL FAULT                    |

**DAILY MAINTENANCE REPORT (COAL, LIGNITE AND NUCLEAR) 19-04-2021**

Sub-Report-10

| State/System          | Power Station     | Unit No. | Planned Maintenance (MW) | Forced Maintenance (Major) (MW) | Forced Maintenance (Minor) (MW) | Others Maintenance (MW) | Date& Time of Maintenance<br>DD/MM/YYYY<br>HH24:MM | Expected/sync Date of Return<br>DD/MM/YYYY<br>HH24:MM | Reasons/Present Status           |
|-----------------------|-------------------|----------|--------------------------|---------------------------------|---------------------------------|-------------------------|----------------------------------------------------|-------------------------------------------------------|----------------------------------|
| 1                     | 2                 | 3        | 4                        | 5                               | 6                               | 7                       | 8                                                  | 9                                                     | 10                               |
| Uttar Pradesh         | OBRA TPS          | 7        | 94.00                    | 0.00                            | 0.00                            | 0.00                    | 26/06/2010 13:25                                   |                                                       | R AND M / REFURBISHMENT WORKS    |
| Uttar Pradesh         | OBRA TPS          | 13       | 200.00                   | 0.00                            | 0.00                            | 0.00                    | 04/03/2018 08:50                                   |                                                       | R AND M / REFURBISHMENT WORKS    |
| Uttar Pradesh         | PARICHA TPS       | 1        | 110.00                   | 0.00                            | 0.00                            | 0.00                    | 07/07/2016 17:59                                   |                                                       | R AND M / REFURBISHMENT WORKS    |
| Uttar Pradesh         | PARICHA TPS       | 2        | 110.00                   | 0.00                            | 0.00                            | 0.00                    | 30/12/2019 21:32                                   |                                                       | R AND M / REFURBISHMENT works    |
| Uttar Pradesh         | ANPARA C TPS      | 2        | 600.00                   | 0.00                            | 0.00                            | 0.00                    | 22/03/2021 22:24                                   |                                                       | CAPITAL MAINTENANCE              |
| <b>Total Northern</b> |                   |          | <b>3,644.00</b>          | <b>4,520.00</b>                 | <b>3,830.00</b>                 | <b>960.00</b>           |                                                    |                                                       |                                  |
| <b>Western</b>        |                   |          |                          |                                 |                                 |                         |                                                    |                                                       |                                  |
| Chhatisgarh           | KORBA-WEST TPS    | 1        | 0.00                     | 0.00                            | 210.00                          | 0.00                    | 18/04/2021 13:32                                   |                                                       | WATER WALL TUBE LEAKAGE          |
| Chhatisgarh           | KORBA-WEST TPS    | 3        | 0.00                     | 0.00                            | 210.00                          | 0.00                    | 18/04/2021 16:19                                   |                                                       | WATER WALL TUBE LEAKAGE          |
| Chhatisgarh           | KORBA-WEST TPS    | 5        | 0.00                     | 0.00                            | 0.00                            | 0.00                    | 19/04/2021 22:30                                   |                                                       | WATER WALL TUBE LEAKAGE          |
| Chhatisgarh           | BINJNOTE TPP      | 1        | 0.00                     | 300.00                          | 0.00                            | 0.00                    | 18/02/2021 00:00                                   |                                                       | RESERVE SHUT DOWN / STANDBY UNIT |
| Chhatisgarh           | KASAIPALLI TPP    | 1        | 0.00                     | 135.00                          | 0.00                            | 0.00                    | 09/03/2021 00:59                                   |                                                       | COAL SHORTAGE                    |
| Chhatisgarh           | KASAIPALLI TPP    | 2        | 0.00                     | 0.00                            | 135.00                          | 0.00                    | 08/04/2021 16:25                                   |                                                       | COAL SHORTAGE                    |
| Chhatisgarh           | KATGHORA TPP      | 1        | 0.00                     | 35.00                           | 0.00                            | 0.00                    | 15/10/2012 00:28                                   |                                                       | NO Power purchase agreement      |
| Chhatisgarh           | NAWAPARA TPP      | 1        | 0.00                     | 0.00                            | 300.00                          | 0.00                    | 19/04/2021 00:00                                   |                                                       | TURBINE VIBRATIONS HIGH          |
| Chhatisgarh           | NAWAPARA TPP      | 2        | 0.00                     | 300.00                          | 0.00                            | 0.00                    | 10/03/2021 12:54                                   |                                                       | TURBINE VIBRATIONS HIGH          |
| Chhatisgarh           | OP JINDAL TPS     | 4        | 0.00                     | 0.00                            | 250.00                          | 0.00                    | 05/04/2021 01:55                                   |                                                       | COAL SHORTAGE                    |
| Chhatisgarh           | SALORA TPP        | 1        | 0.00                     | 135.00                          | 0.00                            | 0.00                    | 19/10/2014 04:30                                   |                                                       | NO Power purchase agreement      |
| Chhatisgarh           | SVPL TPP          | 1        | 0.00                     | 63.00                           | 0.00                            | 0.00                    | 29/03/2020 00:00                                   |                                                       | NON AVAILABILITY OF MAN POWER    |
| Chhatisgarh           | SWASTIK KORBA TPP | 1        | 0.00                     | 25.00                           | 0.00                            | 0.00                    | 01/04/2015 00:20                                   |                                                       | NO Power purchase agreement      |
| Chhatisgarh           | TAMNAR TPP        | 1        | 0.00                     | 0.00                            | 600.00                          | 0.00                    | 18/04/2021 00:00                                   |                                                       | AIR PREHEATERS PROBLEM           |
| Chhatisgarh           | TAMNAR TPP        | 4        | 0.00                     | 600.00                          | 0.00                            | 0.00                    | 30/12/2020 12:16                                   |                                                       | ASH HANDLING SYSTEM              |

**DAILY MAINTENANCE REPORT (COAL, LIGNITE AND NUCLEAR) 19-04-2021**

Sub-Report-10

| State/System   | Power Station      | Unit No. | Planned Maintenance (MW) | Forced Maintenance (Major) (MW) | Forced Maintenance (Minor) (MW) | Others Maintenance (MW) | Date& Time of Maintenance<br>DD/MM/YYYY<br>HH24:MM | Expected/sync Date of Return<br>DD/MM/YYYY<br>HH24:MM | Reasons/Present Status            |
|----------------|--------------------|----------|--------------------------|---------------------------------|---------------------------------|-------------------------|----------------------------------------------------|-------------------------------------------------------|-----------------------------------|
| 1              | 2                  | 3        | 4                        | 5                               | 6                               | 7                       | 8                                                  | 9                                                     | 10                                |
| Chhatisgarh    | TAMNAR TPP         | 4        | 0.00                     | 600.00                          | 0.00                            | 0.00                    | 30/12/2020 12:16                                   |                                                       | PROBLEM                           |
| Chhatisgarh    | UCHPINDA TPP       | 3        | 0.00                     | 360.00                          | 0.00                            | 0.00                    | 03/01/2021 05:36                                   |                                                       | ELECTRICAL MISCELLANEOUS PROBLEMS |
| Gujarat        | KAKRAPARA          | 2        | 220.00                   | 0.00                            | 0.00                            | 0.00                    | 02/04/2021 00:00                                   |                                                       | ANNUAL MAINTENANCE                |
| Gujarat        | AKRIMOTA LIG TPS   | 1        | 0.00                     | 0.00                            | 125.00                          | 0.00                    | 18/04/2021 23:00                                   |                                                       | BOILER FEED PUMP/MOTOR PROBLEM    |
| Gujarat        | AKRIMOTA LIG TPS   | 2        | 0.00                     | 125.00                          | 0.00                            | 0.00                    | 27/12/2020 10:05                                   |                                                       | BOILER MISC. PROBLEM              |
| Gujarat        | BHAVNAGAR CFBC TPP | 2        | 0.00                     | 0.00                            | 250.00                          | 0.00                    | 19/04/2021 03:08                                   |                                                       | MAIN STEAM LINE PROBLEM           |
| Gujarat        | KUTCH LIG. TPS     | 4        | 0.00                     | 0.00                            | 75.00                           | 0.00                    | 13/04/2021 04:00                                   |                                                       | WATER WALL TUBE LEAKAGE           |
| Gujarat        | UKAI TPS           | 3        | 0.00                     | 0.00                            | 200.00                          | 0.00                    | 18/04/2021 13:09                                   | 19/04/2021 20:00                                      | AIR PREHEATERS PROBLEM            |
| Gujarat        | MUNDRA UMTTP       | 1        | 0.00                     | 800.00                          | 0.00                            | 0.00                    | 01/03/2021 12:21                                   |                                                       | HRH LINE LEAKAGE                  |
| Gujarat        | MUNDRA UMTTP       | 2        | 0.00                     | 800.00                          | 0.00                            | 0.00                    | 31/03/2021 15:37                                   |                                                       | BOILER FEED PUMP/MOTOR PROBLEM    |
| Gujarat        | MUNDRA UMTTP       | 3        | 800.00                   | 0.00                            | 0.00                            | 0.00                    | 22/03/2021 13:08                                   |                                                       | CAPITAL MAINTENANCE               |
| Gujarat        | MUNDRA UMTTP       | 4        | 0.00                     | 0.00                            | 800.00                          | 0.00                    | 05/04/2021 15:41                                   |                                                       | COAL SHORTAGE                     |
| Gujarat        | SALAYA TPP         | 1        | 0.00                     | 600.00                          | 0.00                            | 0.00                    | 15/12/2020 12:30                                   |                                                       | BOILER FEED PUMP/MOTOR PROBLEM    |
| Gujarat        | SALAYA TPP         | 2        | 0.00                     | 600.00                          | 0.00                            | 0.00                    | 11/03/2021 10:17                                   |                                                       | COAL SHORTAGE                     |
| Gujarat        | SURAT LIG. TPS     | 2        | 0.00                     | 125.00                          | 0.00                            | 0.00                    | 16/12/2020 23:33                                   |                                                       | BOILER MISC. PROBLEM              |
| Gujarat        | SURAT LIG. TPS     | 3        | 0.00                     | 0.00                            | 125.00                          | 0.00                    | 13/04/2021 13:00                                   |                                                       | WATER WALL TUBE LEAKAGE           |
| Madhya Pradesh | VINDHYACHAL STPS   | 6        | 0.00                     | 0.00                            | 210.00                          | 0.00                    | 17/04/2021 19:13                                   | 19/04/2021 14:20                                      | WATER WALL TUBE LEAKAGE           |
| Madhya Pradesh | SATPURA TPS        | 6        | 0.00                     | 200.00                          | 0.00                            | 0.00                    | 05/03/2021 11:55                                   |                                                       | RSD/LOW SCHEDULE                  |
| Madhya Pradesh | SATPURA TPS        | 7        | 0.00                     | 210.00                          | 0.00                            | 0.00                    | 05/03/2021 10:09                                   |                                                       | RSD/LOW SCHEDULE                  |
| Madhya Pradesh | SATPURA TPS        | 8        | 0.00                     | 0.00                            | 0.00                            | 210.00                  | 29/02/2020 23:54                                   |                                                       | Low system demand/ costly fuel    |
| Madhya Pradesh | SATPURA TPS        | 9        | 0.00                     | 210.00                          | 0.00                            | 0.00                    | 22/02/2020 02:52                                   |                                                       | WATER WALL TUBE LEAKAGE           |
| Madhya Pradesh | SATPURA TPS        | 10       | 0.00                     | 0.00                            | 0.00                            | 0.00                    | 19/04/2021 10:38                                   | 19/04/2021 12:33                                      | DRUM LEVEL LOW                    |

## DAILY MAINTENANCE REPORT (COAL, LIGNITE AND NUCLEAR) 19-04-2021

Sub-Report-10

| State/System   | Power Station                 | Unit No. | Planned Maintenance (MW) | Forced Maintenance (Major) (MW) | Forced Maintenance (Minor) (MW) | Others Maintenance (MW) | Date& Time of Maintenance<br>DD/MM/YYYY<br>HH24:MM | Expected/sync Date of Return<br>DD/MM/YYYY<br>HH24:MM | Reasons/Present Status              |
|----------------|-------------------------------|----------|--------------------------|---------------------------------|---------------------------------|-------------------------|----------------------------------------------------|-------------------------------------------------------|-------------------------------------|
| 1              | 2                             | 3        | 4                        | 5                               | 6                               | 7                       | 8                                                  | 9                                                     | 10                                  |
| Madhya Pradesh | SHREE SINGAJI TPP             | 2        | 0.00                     | 0.00                            | 600.00                          | 0.00                    | 18/04/2021 21:45                                   |                                                       | WATER WALL TUBE LEAKAGE             |
| Madhya Pradesh | SHREE SINGAJI TPP             | 3        | 0.00                     | 660.00                          | 0.00                            | 0.00                    | 05/08/2020 23:56                                   |                                                       | TURBINE VIBRATIONS HIGH             |
| Madhya Pradesh | SHREE SINGAJI TPP             | 4        | 0.00                     | 0.00                            | 660.00                          | 0.00                    | 13/04/2021 12:44                                   |                                                       | TURBINE MISC. PROBLEM               |
| Madhya Pradesh | ANUPPUR TPP                   | 2        | 0.00                     | 600.00                          | 0.00                            | 0.00                    | 06/03/2021 00:05                                   |                                                       | STATOR/ STATOR EARTH FAULT          |
| Madhya Pradesh | MAHAN TPP                     | 1        | 0.00                     | 600.00                          | 0.00                            | 0.00                    | 06/02/2021 13:59                                   |                                                       | RSD/LOW SCHEDULE                    |
| Madhya Pradesh | NIWARI TPP                    | 1        | 0.00                     | 0.00                            | 45.00                           | 0.00                    | 16/04/2021 13:23                                   |                                                       | WATER WALL TUBE LEAKAGE             |
| Madhya Pradesh | NIWARI TPP                    | 2        | 0.00                     | 45.00                           | 0.00                            | 0.00                    | 10/03/2021 21:22                                   |                                                       | RSD/LOW SCHEDULE                    |
| Madhya Pradesh | SASAN UMTTP                   | 2        | 0.00                     | 0.00                            | 660.00                          | 0.00                    | 19/04/2021 11:44                                   |                                                       | ECONOMISER TUBE LEAKAGE             |
| Madhya Pradesh | SASAN UMTTP                   | 3        | 0.00                     | 0.00                            | 660.00                          | 0.00                    | 18/04/2021 13:30                                   |                                                       | ECONOMISER TUBE LEAKAGE             |
| Maharashtra    | SOLAPUR STPS                  | 2        | 0.00                     | 0.00                            | 660.00                          | 0.00                    | 15/04/2021 12:03                                   |                                                       | CONSERVATION OF MAIN FUEL/RSD       |
| Maharashtra    | TARAPUR                       | 1        | 160.00                   | 0.00                            | 0.00                            | 0.00                    | 08/01/2020 00:00                                   |                                                       | ENMASS REFUELLING                   |
| Maharashtra    | TARAPUR                       | 2        | 160.00                   | 0.00                            | 0.00                            | 0.00                    | 13/07/2020 04:38                                   |                                                       | ANNUAL MAINTENANCE                  |
| Maharashtra    | CHANDRAPUR (MAHARASHTRA) STPS | 4        | 0.00                     | 210.00                          | 0.00                            | 0.00                    | 16/03/2021 08:08                                   |                                                       | WATER WALL TUBE LEAKAGE             |
| Maharashtra    | CHANDRAPUR (MAHARASHTRA) STPS | 6        | 500.00                   | 0.00                            | 0.00                            | 0.00                    | 16/04/2021 23:58                                   |                                                       | BOILER INSPECTION/ RE-CERTIFICATION |
| Maharashtra    | CHANDRAPUR (MAHARASHTRA) STPS | 7        | 0.00                     | 500.00                          | 0.00                            | 0.00                    | 20/02/2021 23:43                                   |                                                       | STATOR/ STATOR EARTH FAULT          |
| Maharashtra    | KHAPARKHEDA TPS               | 2        | 0.00                     | 0.00                            | 210.00                          | 0.00                    | 15/04/2021 16:54                                   |                                                       | COAL SHORTAGE                       |
| Maharashtra    | NASIK TPS                     | 3        | 0.00                     | 210.00                          | 0.00                            | 0.00                    | 12/03/2021 06:47                                   |                                                       | P.A. FANS PROBLEM                   |
| Maharashtra    | BELA TPS                      | 1        | 0.00                     | 270.00                          | 0.00                            | 0.00                    | 28/08/2018 21:26                                   |                                                       | NO Power purchase agreement         |
| Maharashtra    | BUTIBORI TPP                  | 1        | 0.00                     | 300.00                          | 0.00                            | 0.00                    | 29/12/2018 00:30                                   |                                                       | COAL SHORTAGE                       |
| Maharashtra    | BUTIBORI TPP                  | 2        | 0.00                     | 300.00                          | 0.00                            | 0.00                    | 17/01/2019 00:15                                   |                                                       | COAL SHORTAGE                       |

## DAILY MAINTENANCE REPORT (COAL, LIGNITE AND NUCLEAR) 19-04-2021

Sub-Report-10

| State/System         | Power Station     | Unit No. | Planned Maintenance (MW) | Forced Maintenance (Major) (MW) | Forced Maintenance (Minor) (MW) | Others Maintenance (MW) | Date& Time of Maintenance<br>DD/MM/YYYY<br>HH24:MM | Expected/sync Date of Return<br>DD/MM/YYYY<br>HH24:MM | Reasons/Present Status      |
|----------------------|-------------------|----------|--------------------------|---------------------------------|---------------------------------|-------------------------|----------------------------------------------------|-------------------------------------------------------|-----------------------------|
| 1                    | 2                 | 3        | 4                        | 5                               | 6                               | 7                       | 8                                                  | 9                                                     | 10                          |
| Maharashtra          | GEPL TPP Ph-I     | 1        | 0.00                     | 60.00                           | 0.00                            | 0.00                    | 29/06/2013 00:00                                   |                                                       | NO Power purchase agreement |
| Maharashtra          | GEPL TPP Ph-I     | 2        | 0.00                     | 60.00                           | 0.00                            | 0.00                    | 20/06/2013 20:27                                   |                                                       | NO Power purchase agreement |
| Maharashtra          | GMR WARORA TPS    | 1        | 0.00                     | 300.00                          | 0.00                            | 0.00                    | 01/04/2021 06:06                                   |                                                       | COAL SHORTAGE               |
| Maharashtra          | JSW RATNAGIRI TPP | 1        | 0.00                     | 300.00                          | 0.00                            | 0.00                    | 01/02/2021 18:00                                   |                                                       | TURBINE BEARING PROBLEM     |
| Maharashtra          | JSW RATNAGIRI TPP | 4        | 0.00                     | 0.00                            | 300.00                          | 0.00                    | 11/04/2021 03:02                                   |                                                       | RSD/LOW SCHEDULE            |
| Maharashtra          | MIHAN TPS         | 1        | 0.00                     | 61.50                           | 0.00                            | 0.00                    | 10/01/2013 15:50                                   |                                                       | NO Power purchase agreement |
| Maharashtra          | MIHAN TPS         | 2        | 0.00                     | 61.50                           | 0.00                            | 0.00                    | 05/11/2013 11:53                                   |                                                       | NO Power purchase agreement |
| Maharashtra          | MIHAN TPS         | 3        | 0.00                     | 61.50                           | 0.00                            | 0.00                    | 10/06/2013 18:00                                   |                                                       | NO Power purchase agreement |
| Maharashtra          | MIHAN TPS         | 4        | 0.00                     | 61.50                           | 0.00                            | 0.00                    | 20/08/2013 10:00                                   |                                                       | NO Power purchase agreement |
| Maharashtra          | NASIK (P) TPS     | 1        | 0.00                     | 270.00                          | 0.00                            | 0.00                    | 04/03/2014 18:10                                   |                                                       | NO Power purchase agreement |
| Maharashtra          | NASIK (P) TPS     | 2        | 0.00                     | 270.00                          | 0.00                            | 0.00                    | 16/02/2017 00:46                                   |                                                       | NO Power purchase agreement |
| Maharashtra          | NASIK (P) TPS     | 3        | 0.00                     | 270.00                          | 0.00                            | 0.00                    | 14/04/2017 01:45                                   |                                                       | NO Power purchase agreement |
| Maharashtra          | NASIK (P) TPS     | 4        | 0.00                     | 270.00                          | 0.00                            | 0.00                    | 20/05/2017 00:25                                   |                                                       | NO Power purchase agreement |
| Maharashtra          | NASIK (P) TPS     | 5        | 0.00                     | 270.00                          | 0.00                            | 0.00                    | 30/05/2017 15:24                                   |                                                       | NO Power purchase agreement |
| Maharashtra          | SHIRPUR TPP       | 1        | 0.00                     | 150.00                          | 0.00                            | 0.00                    | 28/09/2017 21:14                                   |                                                       | NO Power purchase agreement |
| Maharashtra          | TIRORA TPS        | 3        | 0.00                     | 0.00                            | 660.00                          | 0.00                    | 17/04/2021 20:55                                   |                                                       | AIR PREHEATERS PROBLEM      |
| Maharashtra          | WARDHA WARORA TPP | 1        | 0.00                     | 135.00                          | 0.00                            | 0.00                    | 16/02/2016 17:19                                   |                                                       | NO Power purchase agreement |
| <b>Total Western</b> |                   |          | <b>1,840.00</b>          | <b>11,919.00</b>                | <b>7,945.00</b>                 | <b>210.00</b>           |                                                    |                                                       |                             |
| <b>Southern</b>      |                   |          |                          |                                 |                                 |                         |                                                    |                                                       |                             |
| Andhra Pradesh       | SIMHADRI          | 3        | 500.00                   | 0.00                            | 0.00                            | 0.00                    | 06/04/2021 02:41                                   |                                                       | OVERHAULING WORKS           |
| Andhra Pradesh       | SIMHADRI          | 4        | 0.00                     | 0.00                            | 0.00                            | 0.00                    | 16/04/2021 11:54                                   | 19/04/2021 10:32                                      | REHEATER TUBE LEAKAGE       |

**DAILY MAINTENANCE REPORT (COAL, LIGNITE AND NUCLEAR) 19-04-2021**

Sub-Report-10

| State/System   | Power Station             | Unit No. | Planned Maintenance (MW) | Forced Maintenance (Major) (MW) | Forced Maintenance (Minor) (MW) | Others Maintenance (MW) | Date& Time of Maintenance<br>DD/MM/YYYY<br>HH24:MM | Expected/sync Date of Return<br>DD/MM/YYYY<br>HH24:MM | Reasons/Present Status                  |
|----------------|---------------------------|----------|--------------------------|---------------------------------|---------------------------------|-------------------------|----------------------------------------------------|-------------------------------------------------------|-----------------------------------------|
| 1              | 2                         | 3        | 4                        | 5                               | 6                               | 7                       | 8                                                  | 9                                                     | 10                                      |
| Andhra Pradesh | DAMODARAM SANJEEVAIAH TPS | 2        | 0.00                     | 800.00                          | 0.00                            | 0.00                    | 28/03/2021 23:48                                   |                                                       | COAL SHORTAGE                           |
| Andhra Pradesh | RAYALASEEMA TPS           | 2        | 0.00                     | 210.00                          | 0.00                            | 0.00                    | 28/01/2021 12:52                                   |                                                       | AIR PREHEATERS PROBLEM                  |
| Andhra Pradesh | SIMHAPURI TPS             | 1        | 0.00                     | 150.00                          | 0.00                            | 0.00                    | 18/03/2017 00:08                                   |                                                       | RSD/LOW SCHEDULE                        |
| Andhra Pradesh | SIMHAPURI TPS             | 2        | 0.00                     | 150.00                          | 0.00                            | 0.00                    | 27/05/2018 11:06                                   |                                                       | RSD/LOW SCHEDULE                        |
| Andhra Pradesh | SIMHAPURI TPS             | 3        | 0.00                     | 150.00                          | 0.00                            | 0.00                    | 27/05/2018 03:01                                   |                                                       | RSD/LOW SCHEDULE                        |
| Andhra Pradesh | SIMHAPURI TPS             | 4        | 0.00                     | 150.00                          | 0.00                            | 0.00                    | 07/04/2017 05:25                                   |                                                       | RSD/LOW SCHEDULE                        |
| Andhra Pradesh | THAMMINAPATNAM TPS        | 1        | 0.00                     | 0.00                            | 150.00                          | 0.00                    | 16/04/2021 11:45                                   |                                                       | COOLING WATER PUMP PROBLEM              |
| Andhra Pradesh | THAMMINAPATNAM TPS        | 2        | 0.00                     | 0.00                            | 150.00                          | 0.00                    | 12/04/2021 17:41                                   |                                                       | COOLING WATER SUCTION VALVES PROBLEM    |
| Andhra Pradesh | VIZAG TPP                 | 1        | 0.00                     | 520.00                          | 0.00                            | 0.00                    | 18/07/2020 14:15                                   |                                                       | RSD/LOW SCHEDULE                        |
| Andhra Pradesh | VIZAG TPP                 | 2        | 0.00                     | 520.00                          | 0.00                            | 0.00                    | 18/07/2020 23:59                                   |                                                       | RSD/LOW SCHEDULE                        |
| Karnataka      | KUDGI STPP                | 2        | 0.00                     | 0.00                            | 800.00                          | 0.00                    | 15/04/2021 07:52                                   |                                                       | CONSERVATION OF MAIN FUEL/RSD           |
| Karnataka      | KUDGI STPP                | 3        | 0.00                     | 0.00                            | 800.00                          | 0.00                    | 16/04/2021 12:49                                   |                                                       | CONSERVATION OF MAIN FUEL/RSD           |
| Karnataka      | BELLARY TPS               | 1        | 0.00                     | 0.00                            | 0.00                            | 500.00                  | 05/01/2021 11:06                                   |                                                       | GT-STATOR/ROTOR EARTH FAULT             |
| Karnataka      | YERMARUS TPP              | 2        | 0.00                     | 800.00                          | 0.00                            | 0.00                    | 05/12/2020 02:00                                   |                                                       | BOILER MISC. PROBLEM                    |
| Karnataka      | TORANGALLU TPS (SBU-II)   | 4        | 0.00                     | 0.00                            | 0.00                            | 0.00                    | 24/03/2021 22:25                                   | 19/04/2021 10:07                                      | RESERVE SHUT DOWN                       |
| Tamil Nadu     | NEYVELI ( EXT) TPS        | 2        | 0.00                     | 210.00                          | 0.00                            | 0.00                    | 22/03/2021 03:53                                   |                                                       | WATER WALL TUBE LEAKAGE                 |
| Tamil Nadu     | NEYVELI TPS-II            | 5        | 0.00                     | 210.00                          | 0.00                            | 0.00                    | 30/06/2020 09:31                                   |                                                       | BOILER AUX. MISC. PROMLEMS              |
| Tamil Nadu     | TUTICORIN (JV) TPP        | 2        | 0.00                     | 0.00                            | 500.00                          | 0.00                    | 19/04/2021 00:01                                   |                                                       | BOILER MISC. PROBLEM                    |
| Tamil Nadu     | KUDANKULAM                | 2        | 1,000.00                 | 0.00                            | 0.00                            | 0.00                    | 18/01/2021 02:38                                   |                                                       | MISC. SHORT DURATION PLANNED MAINTENACE |
| Tamil Nadu     | MADRAS A.P.S.             | 1        | 0.00                     | 220.00                          | 0.00                            | 0.00                    | 30/01/2018 16:30                                   |                                                       | REACTOR MAINTENANCE WORKS.              |
| Tamil Nadu     | MADRAS A.P.S.             | 2        | 220.00                   | 0.00                            | 0.00                            | 0.00                    | 07/04/2021 23:18                                   |                                                       | ANNUAL MAINTENANCE                      |

**DAILY MAINTENANCE REPORT (COAL, LIGNITE AND NUCLEAR) 19-04-2021**

Sub-Report-10

| State/System          | Power Station            | Unit No. | Planned Maintenance (MW) | Forced Maintenance (Major) (MW) | Forced Maintenance (Minor) (MW) | Others Maintenance (MW) | Date& Time of Maintenance<br>DD/MM/YYYY<br>HH24:MM | Expected/sync Date of Return<br>DD/MM/YYYY<br>HH24:MM | Reasons/Present Status                              |
|-----------------------|--------------------------|----------|--------------------------|---------------------------------|---------------------------------|-------------------------|----------------------------------------------------|-------------------------------------------------------|-----------------------------------------------------|
| 1                     | 2                        | 3        | 4                        | 5                               | 6                               | 7                       | 8                                                  | 9                                                     | 10                                                  |
| Tamil Nadu            | METTUR TPS - II          | 1        | 0.00                     | 0.00                            | 600.00                          | 0.00                    | 15/04/2021 06:11                                   |                                                       | RSD/LOW SCHEDULE                                    |
| Tamil Nadu            | NORTH CHENNAI TPS        | 5        | 0.00                     | 0.00                            | 600.00                          | 0.00                    | 19/04/2021 02:41                                   |                                                       | ASH HANDLING SYSTEM PROBLEM                         |
| Tamil Nadu            | TUTICORIN TPS            | 1        | 0.00                     | 0.00                            | 0.00                            | 210.00                  | 15/04/2021 07:23                                   | 19/04/2021 23:04                                      | RESERVE SHUT DOWN                                   |
| Tamil Nadu            | TUTICORIN TPS            | 2        | 0.00                     | 0.00                            | 210.00                          | 0.00                    | 11/04/2021 13:45                                   |                                                       | MILLING SYSTEM /RC FEEDER PROBLEM                   |
| Tamil Nadu            | ITPCL TPP                | 1        | 0.00                     | 0.00                            | 0.00                            | 0.00                    | 17/04/2021 01:38                                   | 19/04/2021 07:08                                      | RESERVE SHUT DOWN/STANDBY.                          |
| Tamil Nadu            | MUTHIARA TPP             | 1        | 0.00                     | 0.00                            | 0.00                            | 0.00                    | 14/04/2021 23:29                                   | 19/04/2021 10:49                                      | RESERVE SHUT DOWN /STANDBY UNIT                     |
| Tamil Nadu            | MUTHIARA TPP             | 2        | 0.00                     | 600.00                          | 0.00                            | 0.00                    | 18/02/2021 21:30                                   |                                                       | RSD/LOW SCHEDULE                                    |
| Tamil Nadu            | TUTICORIN (P) TPP        | 1        | 0.00                     | 150.00                          | 0.00                            | 0.00                    | 03/04/2016 00:31                                   |                                                       | NO Power purchase agreement                         |
| Tamil Nadu            | TUTICORIN (P) TPP        | 2        | 0.00                     | 150.00                          | 0.00                            | 0.00                    | 16/04/2016 01:42                                   |                                                       | NO Power purchase agreement                         |
| Telangana             | RAMAGUNDEM STPS          | 3        | 200.00                   | 0.00                            | 0.00                            | 0.00                    | 16/01/2021 11:16                                   |                                                       | R AND M / REFURBISHMENT works                       |
| Telangana             | KOTHAGUDEM TPS (NEW)     | 11       | 0.00                     | 0.00                            | 0.00                            | 0.00                    | 19/04/2021 04:41                                   | 19/04/2021 04:41                                      | WATER WALL TUBE LEAKAGE                             |
| Telangana             | KOTHAGUDEM TPS (STAGE-7) | 12       | 0.00                     | 0.00                            | 800.00                          | 0.00                    | 19/04/2021 04:41                                   |                                                       | WATER WALL TUBE LEAKAGE                             |
| <b>Total Southern</b> |                          |          | <b>1,920.00</b>          | <b>4,990.00</b>                 | <b>4,610.00</b>                 | <b>710.00</b>           |                                                    |                                                       |                                                     |
| <b>Eastern</b>        |                          |          |                          |                                 |                                 |                         |                                                    |                                                       |                                                     |
| Bihar                 | BARAUNI TPS              | 6        | 0.00                     | 0.00                            | 105.00                          | 0.00                    | 06/04/2021 12:30                                   |                                                       | TURBINE CONTROL VALVE PROBLEM                       |
| Bihar                 | BARAUNI TPS              | 7        | 0.00                     | 105.00                          | 0.00                            | 0.00                    | 17/03/2021 21:23                                   |                                                       | GEN. TRANSFORMER PROTECTION RELAY OPERATION PROBLEM |
| Bihar                 | BARAUNI TPS              | 9        | 0.00                     | 250.00                          | 0.00                            | 0.00                    | 05/03/2021 23:48                                   |                                                       | GEN. TRANSFORMER PROTECTION RELAY OPERATION PROBLEM |
| Bihar                 | NABINAGAR STPP           | 2        | 0.00                     | 660.00                          | 0.00                            | 0.00                    | 01/04/2021 02:55                                   |                                                       | RSD/LOW SCHEDULE                                    |
| Jharkhand             | BOKARO `B` TPS           | 3        | 0.00                     | 210.00                          | 0.00                            | 0.00                    | 19/06/2020 08:20                                   |                                                       | RESERVE SHUT DOWN /STANDBY UNIT                     |
| Odisha                | TALCHER (OLD) TPS        | 1        | 0.00                     | 60.00                           | 0.00                            | 0.00                    | 22/03/2021 15:13                                   |                                                       | COAL SHORTAGE                                       |

## DAILY MAINTENANCE REPORT (COAL, LIGNITE AND NUCLEAR) 19-04-2021

Sub-Report-10

| State/System | Power Station          | Unit No. | Planned Maintenance (MW) | Forced Maintenance (Major) (MW) | Forced Maintenance (Minor) (MW) | Others Maintenance (MW) | Date& Time of Maintenance<br>DD/MM/YYYY<br>HH24:MM | Expected/sync Date of Return<br>DD/MM/YYYY<br>HH24:MM | Reasons/Present Status           |
|--------------|------------------------|----------|--------------------------|---------------------------------|---------------------------------|-------------------------|----------------------------------------------------|-------------------------------------------------------|----------------------------------|
| 1            | 2                      | 3        | 4                        | 5                               | 6                               | 7                       | 8                                                  | 9                                                     | 10                               |
| Odisha       | TALCHER (OLD) TPS      | 2        | 0.00                     | 60.00                           | 0.00                            | 0.00                    | 23/03/2021 00:39                                   |                                                       | COAL SHORTAGE                    |
| Odisha       | TALCHER (OLD) TPS      | 3        | 0.00                     | 60.00                           | 0.00                            | 0.00                    | 31/03/2021 08:43                                   |                                                       | COAL SHORTAGE                    |
| Odisha       | TALCHER (OLD) TPS      | 4        | 0.00                     | 60.00                           | 0.00                            | 0.00                    | 23/03/2021 00:30                                   |                                                       | COAL SHORTAGE                    |
| Odisha       | TALCHER (OLD) TPS      | 5        | 0.00                     | 110.00                          | 0.00                            | 0.00                    | 23/03/2021 05:05                                   |                                                       | COAL SHORTAGE                    |
| Odisha       | TALCHER (OLD) TPS      | 6        | 0.00                     | 110.00                          | 0.00                            | 0.00                    | 07/03/2021 14:09                                   |                                                       | SEAL OIL SYSTEM PROBLEM          |
| Odisha       | IB VALLEY TPS          | 4        | 0.00                     | 0.00                            | 660.00                          | 0.00                    | 14/04/2021 16:45                                   |                                                       | WATER WALL TUBE LEAKAGE          |
| Odisha       | STERLITE TPP           | 1        | 0.00                     | 600.00                          | 0.00                            | 0.00                    | 23/11/2018 00:22                                   |                                                       | TURBINE VIBRATIONS HIGH          |
| Odisha       | UTKAL TPP (IND BARATH) | 1        | 0.00                     | 350.00                          | 0.00                            | 0.00                    | 01/05/2017 00:00                                   |                                                       | Other Commercial Reason          |
| West Bengal  | DURGAPUR TPS           | 4        | 0.00                     | 210.00                          | 0.00                            | 0.00                    | 31/12/2020 23:50                                   |                                                       | BOILER AUX. MISC. PROMLEMS       |
| West Bengal  | MEJIA TPS              | 3        | 0.00                     | 210.00                          | 0.00                            | 0.00                    | 19/03/2021 09:45                                   |                                                       | HYDROGEN PRESSURE PROBLEM        |
| West Bengal  | RAGHUNATHPUR TPP       | 2        | 0.00                     | 0.00                            | 600.00                          | 0.00                    | 19/04/2021 12:30                                   |                                                       | P.A. FANS PROBLEM                |
| West Bengal  | BANDEL TPS             | 2        | 0.00                     | 60.00                           | 0.00                            | 0.00                    | 13/03/2021 14:10                                   |                                                       | BARRING GEAR PROBLEM             |
| West Bengal  | KOLAGHAT TPS           | 1        | 0.00                     | 210.00                          | 0.00                            | 0.00                    | 07/06/2018 17:28                                   |                                                       | ESP PROBLEM                      |
| West Bengal  | KOLAGHAT TPS           | 2        | 0.00                     | 210.00                          | 0.00                            | 0.00                    | 26/12/2019 22:48                                   |                                                       | E.S.P.MISCELLANEOUS              |
| West Bengal  | KOLAGHAT TPS           | 3        | 210.00                   | 0.00                            | 0.00                            | 0.00                    | 16/04/2021 03:59                                   |                                                       | PG TEST PREPARATION              |
| West Bengal  | BUDGE BUDGE TPS        | 3        | 0.00                     | 0.00                            | 0.00                            | 0.00                    | 17/04/2021 23:27                                   | 19/04/2021 01:01                                      | INSPECTION /MTCE                 |
| West Bengal  | HIRANMAYE TPP          | 2        | 0.00                     | 150.00                          | 0.00                            | 0.00                    | 24/03/2021 03:30                                   |                                                       | WATER WALL TUBE LEAKAGE          |
| West Bengal  | SOUTHERN REPL. TPS     | 1        | 67.50                    | 0.00                            | 0.00                            | 0.00                    | 19/04/2021 02:31                                   |                                                       | ROUTINE MAINTENANCE              |
| West Bengal  | SOUTHERN REPL. TPS     | 2        | 67.50                    | 0.00                            | 0.00                            | 0.00                    | 19/04/2021 02:35                                   |                                                       | ROUTINE MAINTENANCE              |
| West Bengal  | TITAGARH TPS           | 1        | 0.00                     | 60.00                           | 0.00                            | 0.00                    | 10/10/2016 04:57                                   |                                                       | RESERVE SHUT DOWN / STANDBY UNIT |
| West Bengal  | TITAGARH TPS           | 2        | 0.00                     | 60.00                           | 0.00                            | 0.00                    | 09/10/2016 04:57                                   |                                                       | RESERVE SHUT DOWN / STANDBY UNIT |
| West Bengal  | TITAGARH TPS           | 3        | 0.00                     | 60.00                           | 0.00                            | 0.00                    | 10/10/2016 04:18                                   |                                                       | RESERVE SHUT DOWN / STANDBY UNIT |

## DAILY MAINTENANCE REPORT (COAL, LIGNITE AND NUCLEAR) 19-04-2021

Sub-Report-10

| State/System  | Power Station | Unit No. | Planned Maintenance (MW) | Forced Maintenance (Major) (MW) | Forced Maintenance (Minor) (MW) | Others Maintenance (MW) | Date& Time of Maintenance<br>DD/MM/YYYY<br>HH24:MM | Expected/sync Date of Return<br>DD/MM/YYYY<br>HH24:MM | Reasons/Present Status              |
|---------------|---------------|----------|--------------------------|---------------------------------|---------------------------------|-------------------------|----------------------------------------------------|-------------------------------------------------------|-------------------------------------|
| 1             | 2             | 3        | 4                        | 5                               | 6                               | 7                       | 8                                                  | 9                                                     | 10                                  |
| West Bengal   | TITAGARH TPS  | 4        | 0.00                     | 60.00                           | 0.00                            | 0.00                    | 09/10/2016 05:36                                   |                                                       | RESERVE SHUT DOWN /<br>STANDBY UNIT |
| Total Eastern |               |          | 345.00                   | 3,925.00                        | 1,365.00                        | 0.00                    |                                                    |                                                       |                                     |
| Total         |               |          | 7,749.00                 | 25,354.00                       | 17,750.00                       | 1,880.00                |                                                    |                                                       |                                     |