

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 19-05-2022

Sub-Report - 15

| Station | Unit No | Capacity (MW) | Date of Maintanance | Expected/Sync Date of return | remarks |
|---------------------------------|---------|---------------|---------------------|------------------------------|---|
| | | | DD/MM/YYYY HH:24MM | DD/MM/YYYY HH:24MM | |
| 1 | 2 | 3 | 4 | 5 | 6 |
| KORBA STPS | 6 | 500.00 | 19/05/2022 13:35 | 19/05/2022 | TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE |
| MARWA TPS | 1 | 500.00 | 19/05/2022 17:46 | | FURNACE FIRE OUT /FLAME FAILURE |
| OP JINDAL TPS | 2 | 250.00 | 19/05/2022 00:00 | | Fuel Shortage |
| RAIKHEDA TPP | 1 | 685.00 | 19/05/2022 18:32 | | BOILER FEED PUMP/MOTOR PROBLEM |
| GANDHAR CCPP | 3 | 144.30 | 19/05/2022 00:00 | | NO/REDUCED IRRIGATION DEMAND |
| KAWAS CCPP | 1 | 106.00 | 19/05/2022 00:09 | | RSD/LOW SCHEDULE |
| SASAN UMTTP | 4 | 660.00 | 19/05/2022 20:00 | | WATER WALL TUBE LEAKAGE |
| NASIK TPS | 4 | 210.00 | 19/05/2022 22:45 | 22/05/2022 | CONDENSER TUBE LEAKAGE/ CLEANING |
| PARLI TPS | 6 | 250.00 | 19/05/2022 20:00 | | WATER WALL TUBE LEAKAGE |
| WARDHA WARORA TPP | 3 | 135.00 | 19/05/2022 03:00 | | I.D. FANS PROBLEM |
| TROMBAY CCPP | 1 | 120.00 | 19/05/2022 02:44 | | Fuel Shortage |
| BELLARY TPS | 3 | 700.00 | 19/05/2022 11:35 | | REHEATER TUBE LEAKAGE |
| VALLUR TPP | 1 | 500.00 | 19/05/2022 10:10 | 21/05/2022 | WATER WALL TUBE LEAKAGE |
| TUTICORIN TPS | 2 | 210.00 | 19/05/2022 01:26 | | GT SHUT DOWN DUE TO FUEL SHORTAGE |
| TUTICORIN TPS | 3 | 210.00 | 19/05/2022 20:00 | | GT SHUT DOWN DUE TO FUEL SHORTAGE |
| TUTICORIN TPS | 4 | 210.00 | 19/05/2022 00:26 | | GT SHUT DOWN DUE TO FUEL SHORTAGE |
| TUTICORIN TPS | 5 | 210.00 | 19/05/2022 00:51 | | GT SHUT DOWN DUE TO FUEL SHORTAGE |
| BARAUNI TPS | 8 | 250.00 | 19/05/2022 17:26 | | GRID MISCELLANEOUS |
| BARAUNI TPS | 9 | 250.00 | 19/05/2022 17:26 | | GRID MISCELLANEOUS |
| BARAUNI TPS | 9 | | 19/05/2022 09:03 | | C&I PROBLEM |
| NABINAGAR TPP | 4 | 250.00 | 19/05/2022 00:13 | 20/05/2022 | WATER WALL TUBE LEAKAGE |
| MEJIA TPS | 6 | 250.00 | 19/05/2022 08:33 | | ELECTRICAL FAULT |
| KATHALGURI CCPP | 2 | 33.50 | 19/05/2022 13:19 | | MISCELLANEOUS |
| KATHALGURI CCPP | 2 | | 19/05/2022 13:01 | | MISCELLANEOUS |
| LAKWA REPLACEMENT POWER PROJECT | 1 | 9.96 | 19/05/2022 19:42 | 20/05/2022 | MINOR MAINTENANCE WORKS |
| LAKWA REPLACEMENT POWER PROJECT | 1 | | 19/05/2022 19:31 | | MISCELLANEOUS |
| Total | | 6643.77 | | | |