

**DAILY MAINTENANCE REPORT (THERMAL AND NUCLEAR UNITS) FOR 500 AND ABOVE 19-06-2025**

| State/System   | Power Station                       | Unit No. | Planned Maintenance (MW) | Forced Maintenance (Major) (MW) | Forced Maintenance (Minor) (MW) | Others Maintenance (MW) | Date& Time of Maintenance<br>DD/MM/YYYY<br>HH24:MM | Expected/sync Date of Return<br>DD/MM/YYYY<br>HH24:MM | Reasons/Present Status                                   |
|----------------|-------------------------------------|----------|--------------------------|---------------------------------|---------------------------------|-------------------------|----------------------------------------------------|-------------------------------------------------------|----------------------------------------------------------|
| 1              | 2                                   | 3        | 4                        | 5                               | 6                               | 7                       | 8                                                  | 9                                                     | 10                                                       |
| Punjab         | RAJPURA TPP                         | 2        | 0.00                     | 0.00                            | 700.00                          | 0.00                    | 19/06/2025 11:19                                   |                                                       | BOILER MISC. PROBLEM                                     |
| Rajasthan      | CHHABRA-II TPP                      | 5        | 0.00                     | 0.00                            | 660.00                          | 0.00                    | 18/06/2025 12:01                                   |                                                       | Turbine Misc                                             |
| Rajasthan      | SURATGARH STPS                      | 7        | 0.00                     | 0.00                            | 660.00                          | 0.00                    | 16/06/2025 12:54                                   |                                                       | BOILER MISC. PROBLEM                                     |
| Uttar Pradesh  | TANDA TPS                           | 6        | 0.00                     | 0.00                            | 0.00                            | 0.00                    | 19/06/2025 05:20                                   | 19/06/2025 14:53                                      | WATER WALL TUBE LEAKAGE                                  |
| Uttar Pradesh  | JAWAHARPUR STPP                     | 1        | 0.00                     | 0.00                            | 660.00                          | 0.00                    | 11/06/2025 13:37                                   |                                                       | GEN. TRANSORMER<br>PROTECTION RELAY<br>OPERATION PROBLEM |
| Uttar Pradesh  | PANKI TPS EXT                       | 1        | 0.00                     | 0.00                            | 660.00                          | 0.00                    | 18/06/2025 01:00                                   |                                                       | RESERVE SHUT DOWN /<br>STANDBY UNIT                      |
| Chhatisgarh    | SIPAT STPS                          | 1        | 660.00                   | 0.00                            | 0.00                            | 0.00                    | 15/05/2025 02:09                                   |                                                       | OVERHAULING WORKS                                        |
| Gujarat        | KAKRAPARA                           | 4        | 0.00                     | 0.00                            | 700.00                          | 0.00                    | 05/06/2025 20:18                                   |                                                       | REACTOR MAINTENANCE<br>WORKS.                            |
| Gujarat        | SALAYA TPP                          | 2        | 0.00                     | 0.00                            | 600.00                          | 0.00                    | 14/06/2025 12:08                                   |                                                       | ELECTRICAL FAULT                                         |
| Madhya Pradesh | GADARWARA TPP                       | 1        | 800.00                   | 0.00                            | 0.00                            | 0.00                    | 01/06/2025 00:16                                   |                                                       | OVERHAULING WORKS                                        |
| Madhya Pradesh | SHREE SINGAJI TPP                   | 4        | 0.00                     | 0.00                            | 660.00                          | 0.00                    | 15/06/2025 22:34                                   |                                                       | REHEATER TUBE LEAKAGE                                    |
| Madhya Pradesh | NIGRI TPP                           | 2        | 0.00                     | 0.00                            | 660.00                          | 0.00                    | 17/06/2025 02:18                                   |                                                       | SUPER HEATER TUBE LEAKAGE                                |
| Madhya Pradesh | SASAN UMTTP                         | 2        | 0.00                     | 0.00                            | 0.00                            | 0.00                    | 19/06/2025 21:48                                   |                                                       | WATER WALL TUBE LEAKAGE                                  |
| Maharashtra    | MAUDA TPS                           | 1        | 500.00                   | 0.00                            | 0.00                            | 0.00                    | 15/06/2025 00:24                                   |                                                       | OVERHAULING WORKS                                        |
| Maharashtra    | CHANDRAPUR<br>(MAHARASHTRA)<br>STPS | 9        | 0.00                     | 500.00                          | 0.00                            | 0.00                    | 11/01/2025 18:55                                   |                                                       | GENERATOR PROTECTION<br>RELAY OPERATION PROBLEM          |
| Andhra Pradesh | SIMHADRI                            | 3        | 500.00                   | 0.00                            | 0.00                            | 0.00                    | 16/06/2025 00:04                                   |                                                       | OVERHAULING WORKS                                        |
| Andhra Pradesh | DAMODARAM<br>SANJEEVAIAH TPS        | 3        | 800.00                   | 0.00                            | 0.00                            | 0.00                    | 01/06/2025 00:54                                   |                                                       | ANNUAL MAINTENANCE                                       |
| Karnataka      | KUDGI STPP                          | 1        | 0.00                     | 0.00                            | 800.00                          | 0.00                    | 17/06/2025 03:38                                   |                                                       | CONSERVATION OF MAIN                                     |

**DAILY MAINTENANCE REPORT (THERMAL AND NUCLEAR UNITS) FOR 500 AND ABOVE 19-06-2025**

| State/System | Power Station                 | Unit No. | Planned Maintenance (MW) | Forced Maintenance (Major) (MW) | Forced Maintenance (Minor) (MW) | Others Maintenance (MW) | Date& Time of Maintenance<br>DD/MM/YYYY<br>HH24:MM | Expected/sync Date of Return<br>DD/MM/YYYY<br>HH24:MM | Reasons/Present Status              |
|--------------|-------------------------------|----------|--------------------------|---------------------------------|---------------------------------|-------------------------|----------------------------------------------------|-------------------------------------------------------|-------------------------------------|
| 1            | 2                             | 3        | 4                        | 5                               | 6                               | 7                       | 8                                                  | 9                                                     | 10                                  |
| Karnataka    | KUDGI STPP                    | 1        | 0.00                     | 0.00                            | 800.00                          | 0.00                    | 17/06/2025 03:38                                   |                                                       | FUEL/RSD                            |
| Karnataka    | KUDGI STPP                    | 2        | 0.00                     | 800.00                          | 0.00                            | 0.00                    | 31/05/2025 13:35                                   |                                                       | CONSERVATION OF MAIN FUEL/RSD       |
| Karnataka    | BELLARY TPS                   | 1        | 0.00                     | 500.00                          | 0.00                            | 0.00                    | 24/05/2025 00:09                                   |                                                       | RSD/LOW SCHEDULE                    |
| Karnataka    | YERMARUS TPP                  | 1        | 0.00                     | 0.00                            | 800.00                          | 0.00                    | 17/06/2025 11:55                                   |                                                       | RSD/LOW SCHEDULE                    |
| Karnataka    | ADANI POWER LIMITED UDUPI TPP | 1        | 0.00                     | 0.00                            | 600.00                          | 0.00                    | 17/06/2025 00:04                                   |                                                       | RSD/LOW SCHEDULE                    |
| Karnataka    | ADANI POWER LIMITED UDUPI TPP | 2        | 0.00                     | 600.00                          | 0.00                            | 0.00                    | 21/05/2025 01:52                                   |                                                       | RSD/LOW SCHEDULE                    |
| Tamil Nadu   | NEYVELI NEW TPP               | 2        | 500.00                   | 0.00                            | 0.00                            | 0.00                    | 16/06/2025 18:12                                   |                                                       | OVERHAULING WORKS                   |
| Tamil Nadu   | NORTH CHENNAI TPS             | 5        | 0.00                     | 0.00                            | 600.00                          | 0.00                    | 17/06/2025 10:10                                   |                                                       | WATER WALL TUBE LEAKAGE             |
| Tamil Nadu   | MUTHIARA TPP                  | 2        | 0.00                     | 0.00                            | 600.00                          | 0.00                    | 15/06/2025 23:52                                   |                                                       | BOILER AUX. MISC. PROMLEMS          |
| Tamil Nadu   | TUTICORIN TPP ST-IV           | 1        | 525.00                   | 0.00                            | 0.00                            | 0.00                    | 11/06/2025 23:26                                   |                                                       | ANNUAL MAINTENANCE                  |
| Telangana    | SINGARENI TPP                 | 1        | 600.00                   | 0.00                            | 0.00                            | 0.00                    | 09/06/2025 07:04                                   |                                                       | ANNUAL MAINTENANCE                  |
| Bihar        | BARH STPS                     | 5        | 0.00                     | 0.00                            | 660.00                          | 0.00                    | 15/06/2025 21:34                                   | 19/06/2025 19:46                                      | REHEATER TUBE LEAKAGE               |
| Jharkhand    | NORTH KARANPURA TPP           | 1        | 0.00                     | 0.00                            | 660.00                          | 0.00                    | 17/06/2025 17:50                                   |                                                       | WATER WALL TUBE LEAKAGE             |
| Odisha       | TALCHER STPS                  | 3        | 500.00                   | 0.00                            | 0.00                            | 0.00                    | 14/06/2025 00:56                                   |                                                       | BOILER OVERHAUL/ ANNUAL MAINTENANCE |
| Odisha       | VEDANTA TPP                   | 2        | 0.00                     | 600.00                          | 0.00                            | 0.00                    | 31/05/2025 04:15                                   |                                                       | AIR PREHEATERS PROBLEM              |
| West Bengal  | MEJIA TPS                     | 8        | 0.00                     | 0.00                            | 500.00                          | 0.00                    | 18/06/2025 21:40                                   |                                                       | BOILER MISC. PROBLEM                |

|       |          |          |           |      |  |  |  |
|-------|----------|----------|-----------|------|--|--|--|
| Total | 5,385.00 | 3,000.00 | 11,180.00 | 0.00 |  |  |  |
|-------|----------|----------|-----------|------|--|--|--|

Remarks:-

Report Version :-