

CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION

RECOMMISSIONNING OF THERMAL/NUCLEAR UNITS AS ON: 19-06-2025

Sub-Report - 14

Station	Unit No	Capacity (MW)	Date of Maintanance	Sync Date	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
PANIPAT TPS	6	210.00	09/06/2025 15:35	19/06/2025 13:56	C&I PROBLEM
PANIPAT TPS	8	250.00	19/06/2025 12:48	19/06/2025 15:29	CONTROL SYSTEM PROBLEMS
CHHABRA-I PH-1 TPP	2	250.00	17/06/2025 15:45	19/06/2025 01:20	ESP PROBLEM
TANDA TPS	6	660.00	19/06/2025 05:20	19/06/2025 14:53	WATER WALL TUBE LEAKAGE
KORBA-WEST TPS	1	210.00	16/06/2025 08:43	19/06/2025 12:06	WATER WALL TUBE LEAKAGE
BINJKOTE TPP	1	300.00	19/06/2025 12:41	19/06/2025 15:23	FURNACE FIRE OUT /FLAME FAILURE
BINJKOTE TPP	1		19/06/2025 18:05	19/06/2025 20:22	C&I PROBLEM
SANJAY GANDHI TPS	4	210.00	16/06/2025 15:15	19/06/2025 01:15	WATER WALL TUBE LEAKAGE
NIWARI TPP	1	45.00	19/06/2025 13:10	19/06/2025 15:48	EXCITATION PROBLEM
BELA TPS	1	270.00	17/06/2025 18:11	19/06/2025 13:35	MISC. SHORT DURATION MAINTENANCE
Dr. N.TATA RAO TPS	5	210.00	19/06/2025 14:16	19/06/2025 15:53	FURNACE FIRE OUT /FLAME FAILURE
RAYALASEEMA TPS	1	210.00	17/06/2025 08:05	19/06/2025 00:27	REHEATER TUBE LEAKAGE
RAICHUR TPS	4	210.00	19/06/2025 03:45	19/06/2025 20:18	REVERSE POWER RELAY OPERATION
RAICHUR TPS	5	210.00	16/06/2025 09:45	19/06/2025 08:03	RESERVE SHUT DOWN / STANDBY UNIT
METTUR TPS	3	210.00	08/06/2025 06:47	19/06/2025 14:23	MILLING SYSTEM /RC FEEDER PROBLEM
BARH STPS	5	660.00	15/06/2025 21:34	19/06/2025 19:46	REHEATER TUBE LEAKAGE
KAHALGAON TPS	4	210.00	17/06/2025 16:05	19/06/2025 07:39	REHEATER TUBE LEAKAGE
MAHADEV PRASAD STPP	1	270.00	19/06/2025 09:06	19/06/2025 21:29	TURBINE VIBRATIONS HIGH
SANTALDIH TPS	6	250.00	19/06/2025 11:54	19/06/2025 15:27	DC SUPPLY PROBLEM
KATHALGURI CCPP	1	33.50	19/06/2025 00:00	19/06/2025 11:41	LOW SYSTEM DEMAND
KATHALGURI CCPP	2	33.50	19/06/2025 11:45	19/06/2025 13:10	LUB.OIL SYSTEM PROBLEM
KATHALGURI CCPP	2		19/06/2025 13:10	19/06/2025 23:59	LOW SYSTEM DEMAND
KATHALGURI CCPP	7	30.00	19/06/2025 00:00	19/06/2025 23:59	MISCELLANEOUS PLANNED MAINTENANCE
LAKWA GT	8	37.20	12/06/2025 12:05	19/06/2025 05:10	CONDENSATE PUMP problem
AGARTALA GT	3	21.00	19/06/2025 07:01	19/06/2025 23:59	Fuel Shortage
AGARTALA GT	4	21.00	19/06/2025 17:08	19/06/2025 23:59	Fuel Shortage
AGARTALA GT	6	25.50	19/06/2025 17:04	19/06/2025 23:59	Fuel Shortage
MONARCHAK CCPP	1	65.40	19/06/2025 00:00	19/06/2025 10:30	MISCELLANEOUS PLANNED MAINTENANCE
MONARCHAK CCPP	2	35.60	19/06/2025 00:00	19/06/2025 23:59	MISCELLANEOUS PLANNED MAINTENANCE
Total		5,147.70			