

CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION

RECOMMISSIONNING OF THERMAL/NUCLEAR UNITS AS ON: 19-08-2025

Sub-Report - 14

Station	Unit No	Capacity (MW)	Date of Maintanance	Sync Date	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
FARIDABAD CCPP	1	137.76	16/08/2025 23:08	19/08/2025 18:28	CONSERVATION OF MAIN FUEL/RSD
FARIDABAD CCPP	2	137.76	16/08/2025 23:08	19/08/2025 18:10	CONSERVATION OF MAIN FUEL/RSD
PANIPAT TPS	8	250.00	14/08/2025 23:05	19/08/2025 14:49	RSD/LOW SCHEDULE
GH TPS (LEH.MOH.)	4	250.00	18/08/2025 15:16	19/08/2025 19:53	ABNORMAL SOUND
ROPAR TPS	3	210.00	17/08/2025 06:00	19/08/2025 11:55	LOW SYSTEM DEMAND
ANTA CCPP	2	88.71	16/08/2025 23:07	19/08/2025 18:12	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	3	88.71	16/08/2025 23:06	19/08/2025 17:58	CONSERVATION OF MAIN FUEL/RSD
SINGRAULI STPS	2	200.00	17/08/2025 09:05	19/08/2025 11:40	WATER WALL TUBE LEAKAGE
AURAIYA CCPP	3	111.19	16/08/2025 23:10	19/08/2025 18:48	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	4	111.19	16/08/2025 23:08	19/08/2025 18:52	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	1	130.19	16/08/2025 23:07	19/08/2025 18:55	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	2	130.19	16/08/2025 23:09	19/08/2025 19:02	CONSERVATION OF MAIN FUEL/RSD
HARDUAGANJ TPS	8	250.00	19/08/2025 04:52	19/08/2025 08:24	FURNACE FIRE OUT /FLAME FAILURE
HARDUAGANJ TPS	8		19/08/2025 09:32	19/08/2025 11:58	FURNACE DRAFT ABNORMAL
PANKI TPS EXT	1	660.00	18/08/2025 20:08	19/08/2025 14:45	ELECTRICAL MISCELLANEOUS PROBLEMS
PANKI TPS EXT	1		19/08/2025 16:17	19/08/2025 20:47	ELECTRICAL FAULT
MAQSOODPUR TPS	2	45.00	19/08/2025 06:28	19/08/2025 07:10	BOILER AUX. MISC. PROMLEMS
GANDHAR CCPP	1	144.30	16/08/2025 23:24	19/08/2025 17:51	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	2	144.30	16/08/2025 23:30	19/08/2025 18:16	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	3	144.30	16/08/2025 23:43	19/08/2025 18:03	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	2	106.00	16/08/2025 23:18	19/08/2025 18:25	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	3	106.00	16/08/2025 23:29	19/08/2025 18:30	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	4	106.00	16/08/2025 23:24	19/08/2025 18:45	CONSERVATION OF MAIN FUEL/RSD
WANAKBORI TPS	2	210.00	15/08/2025 14:31	19/08/2025 12:28	RESERVE SHUT DOWN / STANDBY UNIT
WANAKBORI TPS	7	210.00	16/08/2025 09:24	19/08/2025 12:08	RESERVE SHUT DOWN / STANDBY UNIT
VINDHYACHAL STPS	3	210.00	19/08/2025 03:12	19/08/2025 17:28	LINE TRIPPING/PROB/MTC/CHARGING
VINDHYACHAL STPS	5	210.00	19/08/2025 03:12	19/08/2025 22:17	LINE TRIPPING/PROB/MTC/CHARGING
SOLAPUR STPS	2	660.00	19/08/2025 17:37	19/08/2025 20:20	P.A. FANS PROBLEM
CHANDRAPUR(MAHARASHTRA) STPS	3	210.00	19/08/2025 00:56	19/08/2025 05:05	DRUM LEVEL LOW
KHAPARKHEDA TPS	4	210.00	16/08/2025 11:55	19/08/2025 13:24	ASH HANDLING SYSTEM PROBLEM
THAMMINAPATNAM TPS	1	150.00	14/08/2025 23:59	19/08/2025 13:30	BOILER MISC. PROBLEM
METTUR TPS	3	210.00	15/08/2025 13:58	19/08/2025 19:46	RESERVE SHUT DOWN / STANDBY UNIT

Station	Unit No	Capacity (MW)	Date of Maintanance	Sync Date	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
BHADRADRI TPP	1	270.00	18/08/2025 23:36	19/08/2025 05:21	P.A. FANS PROBLEM
SANTALDIH TPS	5	250.00	19/08/2025 02:06	19/08/2025 04:04	FURNACE FIRE OUT /FLAME FAILURE
SANTALDIH TPS	5		17/08/2025 10:00	19/08/2025 02:00	ECONOMISER TUBE LEAKAGE
BUDGE BUDGE TPS	3	250.00	18/08/2025 05:25	19/08/2025 21:59	AIR PREHEATERS PROBLEM
KATHALGURI CCPP	1	33.50	19/08/2025 00:00	19/08/2025 23:59	Fuel Shortage
KATHALGURI CCPP	7	30.00	19/08/2025 00:00	19/08/2025 23:59	MISCELLANEOUS PLANNED MAINTENANCE
LAKWA REPLACEMENT POWER PROJECT	7	9.96	18/08/2025 00:31	19/08/2025 23:59	GRID DISTURBANCE
AGARTALA GT	1	21.00	19/08/2025 00:00	19/08/2025 23:59	Fuel Shortage
AGARTALA GT	2	21.00	19/08/2025 00:00	19/08/2025 23:59	Fuel Shortage
AGARTALA GT	5	25.50	19/08/2025 00:00	19/08/2025 23:59	Fuel Shortage
Total		6,742.57			