

CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 19-08-2025

Sub-Report - 15

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
FARIDABAD CCPP	1	137.76	19/08/2025 20:22	19/08/2025	CONSERVATION OF MAIN FUEL/RSD
FARIDABAD CCPP	2	137.76	19/08/2025 20:21	19/08/2025	CONSERVATION OF MAIN FUEL/RSD
RAJIV GANDHI TPS	1	600.00	19/08/2025 06:51		WATER WALL TUBE LEAKAGE
ANTA CCPP	2	88.71	19/08/2025 20:28	19/08/2025	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	3	88.71	19/08/2025 20:28	19/08/2025	CONSERVATION OF MAIN FUEL/RSD
RAMGARH CCPP	2	35.50	19/08/2025 04:23		MISCELLANEOUS
AURAIYA CCPP	3	111.19	19/08/2025 20:25	19/08/2025	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	4	111.19	19/08/2025 20:23	19/08/2025	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	1	130.19	19/08/2025 20:23	19/08/2025	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	2	130.19	19/08/2025 20:23	19/08/2025	CONSERVATION OF MAIN FUEL/RSD
HARDUAGANJ TPS	8	250.00	19/08/2025 09:32		FURNACE DRAFT ABNORMAL
HARDUAGANJ TPS	8		19/08/2025 04:52		FURNACE FIRE OUT /FLAME FAILURE
PANKI TPS EXT	1	660.00	19/08/2025 16:17		ELECTRICAL FAULT
MAQSOODPUR TPS	2	45.00	19/08/2025 06:28		BOILER AUX. MISC. PROMLEMS
KORBA-WEST TPS	2	210.00	19/08/2025 03:30		ECONOMISER TUBE LEAKAGE
UKAI TPS	5	210.00	19/08/2025 20:01		RESERVE SHUT DOWN
VINDHYACHAL STPS	3	210.00	19/08/2025 03:12	19/08/2025	LINE TRIPPING/PROB/MTC/CHARGING
VINDHYACHAL STPS	5	210.00	19/08/2025 03:12	19/08/2025	LINE TRIPPING/PROB/MTC/CHARGING
SOLAPUR STPS	2	660.00	19/08/2025 17:37	19/08/2025	P.A. FANS PROBLEM
CHANDRAPUR(MAHARASHTRA) STPS	3	210.00	19/08/2025 00:56		DRUM LEVEL LOW
PARAS TPS	3	250.00	19/08/2025 23:50		DRUM LEVEL LOW
SIMHADRI	4	500.00	19/08/2025 14:35		RESERVE SHUT DOWN / STANDBY UNIT
NEYVELI TPS-II EXP	2	250.00	19/08/2025 01:58		WATER WALL TUBE LEAKAGE
BARH STPS	1	660.00	19/08/2025 01:31	19/08/2025	REHEATER TUBE LEAKAGE
KAMALANGA TPS	3	350.00	19/08/2025 14:37		AIR PREHEATERS PROBLEM
SANTALDIH TPS	5	250.00	19/08/2025 02:06		FURNACE FIRE OUT /FLAME FAILURE
KATHALGURI CCPP	1	33.50	19/08/2025 00:00		Fuel Shortage
KATHALGURI CCPP	7	30.00	19/08/2025 00:00		MISCELLANEOUS PLANNED MAINTENANCE
LAKWA REPLACEMENT POWER PROJECT	1	9.96	19/08/2025 08:50		Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	2	9.96	19/08/2025 08:56		FUEL OIL SHORTAGE
LAKWA REPLACEMENT POWER PROJECT	3	9.96	19/08/2025 08:51		FUEL OIL SHORTAGE
LAKWA REPLACEMENT POWER PROJECT	4	9.96	19/08/2025 08:52		FUEL OIL SHORTAGE

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
LAKWA REPLACEMENT POWER PROJECT	5	9.96	19/08/2025 08:53		FUEL OIL SHORTAGE
LAKWA REPLACEMENT POWER PROJECT	6	9.96	19/08/2025 09:49		FUEL OIL SHORTAGE
AGARTALA GT	1	21.00	19/08/2025 00:00		Fuel Shortage
AGARTALA GT	2	21.00	19/08/2025 00:00		Fuel Shortage
AGARTALA GT	5	25.50	19/08/2025 00:00		Fuel Shortage
Total		6686.99			