

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 19-10-2024

Sub-Report - 15

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
ANTA CCPP	1	88.71	19/10/2024 20:42	19/10/2024	NO/REDUCED IRRIGATION DEMAND
ANTA CCPP	2	88.71	19/10/2024 20:42	19/10/2024	NO/REDUCED IRRIGATION DEMAND
ANTA CCPP	3	88.71	19/10/2024 20:42	19/10/2024	NO/REDUCED IRRIGATION DEMAND
DADRI (NCTPP)	1	210.00	19/10/2024 06:57	19/10/2024	BOILER AUX. MISC. PROMLEMS
AURAIYA CCPP	1	111.19	19/10/2024 20:43	19/10/2024	NO/REDUCED IRRIGATION DEMAND
AURAIYA CCPP	2	111.19	19/10/2024 20:46	19/10/2024	NO/REDUCED IRRIGATION DEMAND
AURAIYA CCPP	3	111.19	19/10/2024 20:41	19/10/2024	NO/REDUCED IRRIGATION DEMAND
AURAIYA CCPP	4	111.19	19/10/2024 20:39	19/10/2024	NO/REDUCED IRRIGATION DEMAND
DADRI CCPP	1	130.19	19/10/2024 20:41	19/10/2024	NO/REDUCED IRRIGATION DEMAND
DADRI CCPP	4	130.19	19/10/2024 20:54	19/10/2024	NO/REDUCED IRRIGATION DEMAND
ANPARA C TPS	2	600.00	19/10/2024 01:31		WATER WALL TUBE LEAKAGE
ADANI POWER LIMITED RAIGARH TPP	1	600.00	19/10/2024 15:32	20/10/2024	GENERATOR PROTECTION RELAY OPERATION PROBLEM
GANDHAR CCPP	1	144.30	19/10/2024 20:39	19/10/2024	NO/REDUCED IRRIGATION DEMAND
GANDHAR CCPP	2	144.30	19/10/2024 20:33	19/10/2024	NO/REDUCED IRRIGATION DEMAND
KAWAS CCPP	1	106.00	19/10/2024 20:29	19/10/2024	NO/REDUCED IRRIGATION DEMAND
KAWAS CCPP	2	106.00	19/10/2024 20:42	19/10/2024	NO/REDUCED IRRIGATION DEMAND
KAWAS CCPP	3	106.00	19/10/2024 20:34	19/10/2024	NO/REDUCED IRRIGATION DEMAND
KAWAS CCPP	4	106.00	19/10/2024 20:38	19/10/2024	NO/REDUCED IRRIGATION DEMAND
UKAI TPS	5	210.00	19/10/2024 19:35		RSD/LOW SCHEDULE
WANAKBORI TPS	5	210.00	19/10/2024 20:32		RESERVE SHUT DOWN / STANDBY UNIT
UNOSUGEN CCPP	1	382.50	19/10/2024 00:00		RSD/LOW SCHEDULE
RATNAGIRI CCPP	7	213.00	19/10/2024 00:58		GT-MISCELLANEOUS PROBLEMS
RAMAGUNDEM STPS	4	500.00	19/10/2024 17:49	19/10/2024	FURNACE FIRE OUT /FLAME FAILURE
SOUTHERN REPL. TPS	1	67.50	19/10/2024 21:56	20/10/2024	RESERVE SHUT DOWN / STANDBY UNIT
KATHALGURI CCPP	5	33.50	19/10/2024 00:00		Fuel Shortage
KATHALGURI CCPP	7	30.00	19/10/2024 18:03		MISCELLANEOUS
LAKWA REPLACEMENT POWER PROJECT	2	9.96	19/10/2024 07:09		Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	3	9.96	19/10/2024 20:30		GRID DISTURBANCES MISC.
LAKWA REPLACEMENT POWER PROJECT	3		19/10/2024 17:28		Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	7	9.96	19/10/2024 13:16		MISCELLANOUS
LAKWA REPLACEMENT POWER PROJECT	7		19/10/2024 04:41		Fuel Shortage

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
MONARCHAK CCPP	1	65.40	19/10/2024 00:00		MISCELLANEOUS PLANNED MAINTENANCE
MONARCHAK CCPP	2	35.60	19/10/2024 00:00		MISCELLANEOUS PLANNED MAINTENANCE
Total		4871.27			