

**CENTRAL ELECTRICITY AUTHORITY  
G O & D WING  
OPERATION PERFORMANCE MONITORING DIVISION**

**RECOMMISSIONING OF THERMAL/NUCLEAR UNITS AS ON: 19-11-2023**

Sub-Report - 14

Station	Unit No	Capacity (MW)	Date of Maintanance	Sync Date	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
GH TPS (LEH.MOH.)	3	250.00	18/11/2023 20:30	19/11/2023 01:03	TURBINE BEARING COOLING SYS/OIL COOLER
JALIPA KAPURDI TPP	5	135.00	18/11/2023 03:05	19/11/2023 11:31	BOILER MISC. PROBLEM
SIPAT STPS	3	660.00	17/11/2023 20:27	19/11/2023 16:00	WATER WALL TUBE LEAKAGE
WANAKBORI TPS	3	210.00	11/11/2023 09:20	19/11/2023 03:12	RESERVE SHUT DOWN
WANAKBORI TPS	7	210.00	12/11/2023 12:00	19/11/2023 07:02	RESERVE SHUT DOWN
SALAYA TPP	2	600.00	10/11/2023 21:45	19/11/2023 10:18	RESERVE SHUT DOWN / STANDBY UNIT
SANJAY GANDHI TPS	5	500.00	19/11/2023 17:32	19/11/2023 21:08	FURNACE FIRE OUT /FLAME FAILURE
MAHAN TPP	1	600.00	12/11/2023 00:39	19/11/2023 19:09	MISCELLANEOUS
NASIK TPS	4	210.00	17/11/2023 20:22	19/11/2023 13:02	GENERATOR EARTH FAULT
DAMODARAM SANJEEVAIAH TPS	1	800.00	14/11/2023 22:10	19/11/2023 00:09	COOLING WATER SYSTEM PROBLEM/PIPES REPLACE
BELLARY TPS	3	700.00	19/11/2023 05:05	19/11/2023 12:26	ASH HANDLING SYSTEM NOT READY
RAICHUR TPS	5	210.00	12/11/2023 23:58	19/11/2023 23:34	RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	8	250.00	07/11/2023 11:43	19/11/2023 23:58	WET / POOR QUALITY COAL
NABINAGAR STPP	1	660.00	17/11/2023 14:14	19/11/2023 04:14	WATER WALL TUBE LEAKAGE
IB VALLEY TPS	2	210.00	16/11/2023 20:19	19/11/2023 19:51	BOILER MISC. PROBLEM
RAGHUNATHPUR TPP	2	600.00	19/11/2023 04:20	19/11/2023 10:32	MISCELLANOUS
KOLAGHAT TPS	6	210.00	18/11/2023 21:38	19/11/2023 01:52	P.A. FANS PROBLEM
BUDGE BUDGE TPS	1	250.00	19/11/2023 09:48	19/11/2023 13:50	GOVERNING SYSTEM PROBLEM
KATHALGURI CCPP	6	33.50	19/11/2023 00:00	19/11/2023 23:59	Fuel Shortage
AGARTALA GT	3	21.00	19/11/2023 00:00	19/11/2023 23:59	TURBINE MISC.
MONARCHAK CCPP	2	35.60	19/11/2023 11:12	19/11/2023 11:55	LUB.OIL SYSTEM PROBLEM
Total		7,355.10			