

**CENTRAL ELECTRICITY AUTHORITY  
G O & D WING  
OPERATION PERFORMANCE MONITORING DIVISION**

**RECOMMISSIONING OF THERMAL/NUCLEAR UNITS AS ON: 19-12-2024**

Sub-Report - 14

| Station          | Unit No | Capacity (MW) | Date of Maintanance | Sync Date          | remarks                                  |
|------------------|---------|---------------|---------------------|--------------------|--|
|                  |         |               | DD/MM/YYYY HH:24MM  | DD/MM/YYYY HH:24MM |  |
| 1                | 2       | 3             | 4                   | 5                  | 6  |
| ANTA CCPP        | 1       | 88.71         | 19/12/2024 09:45    | 19/12/2024 15:20   | CONSERVATION OF MAIN FUEL/RSD            |
| ANTA CCPP        | 1       |               | 18/12/2024 18:57    | 19/12/2024 06:06   | CONSERVATION OF MAIN FUEL/RSD            |
| ANTA CCPP        | 3       | 88.71         | 18/12/2024 18:58    | 19/12/2024 05:50   | CONSERVATION OF MAIN FUEL/RSD            |
| ANTA CCPP        | 3       |               | 19/12/2024 09:45    | 19/12/2024 15:34   | CONSERVATION OF MAIN FUEL/RSD            |
| KOTA TPS         | 6       | 195.00        | 19/12/2024 09:48    | 19/12/2024 13:09   | I.D. FANS PROBLEM                        |
| AURAIYA CCPP     | 1       | 111.19        | 18/12/2024 18:55    | 19/12/2024 05:45   | CONSERVATION OF MAIN FUEL/RSD            |
| AURAIYA CCPP     | 1       |               | 19/12/2024 09:28    | 19/12/2024 15:09   | CONSERVATION OF MAIN FUEL/RSD            |
| AURAIYA CCPP     | 2       | 111.19        | 19/12/2024 09:23    | 19/12/2024 15:30   | CONSERVATION OF MAIN FUEL/RSD            |
| AURAIYA CCPP     | 2       |               | 18/12/2024 18:55    | 19/12/2024 06:02   | CONSERVATION OF MAIN FUEL/RSD            |
| AURAIYA CCPP     | 4       | 111.19        | 19/12/2024 09:25    | 19/12/2024 15:32   | CONSERVATION OF MAIN FUEL/RSD            |
| AURAIYA CCPP     | 4       |               | 18/12/2024 18:54    | 19/12/2024 06:03   | CONSERVATION OF MAIN FUEL/RSD            |
| DADRI CCPP       | 1       | 130.19        | 19/12/2024 09:42    | 19/12/2024 15:21   | CONSERVATION OF MAIN FUEL/RSD            |
| DADRI CCPP       | 1       |               | 18/12/2024 18:58    | 19/12/2024 05:35   | CONSERVATION OF MAIN FUEL/RSD            |
| DADRI CCPP       | 4       | 130.19        | 18/12/2024 18:58    | 19/12/2024 05:45   | NO/REDUCED IRRIGATION DEMAND             |
| HARDUAGANJ TPS   | 8       | 250.00        | 16/11/2024 00:00    | 19/12/2024 21:09   | RSD/LOW SCHEDULE                         |
| HARDUAGANJ TPS   | 9       | 250.00        | 15/11/2024 23:59    | 19/12/2024 18:19   | RSD/LOW SCHEDULE                         |
| HARDUAGANJ TPS   | 10      | 660.00        | 17/11/2024 22:04    | 19/12/2024 19:48   | RSD/LOW SCHEDULE                         |
| KUNDARKI TPS     | 1       | 45.00         | 16/12/2024 01:10    | 19/12/2024 21:41   | BOILER MISC. PROBLEM                     |
| MAQSOODPUR TPS   | 1       | 45.00         | 17/11/2024 21:45    | 19/12/2024 13:22   | RSD/LOW SCHEDULE                         |
| MAQSOODPUR TPS   | 2       | 45.00         | 19/12/2024 13:30    | 19/12/2024 21:12   | GOVERN.SYSTEM TROUB/EQPT. FAIL/EHG FAULT |
| AKALTARA TPS     | 4       | 600.00        | 20/11/2024 03:57    | 19/12/2024 14:33   | SCHEDULED ANNUAL MAINTENANCE             |
| KAWAS CCPP       | 1       | 106.00        | 19/12/2024 09:57    | 19/12/2024 14:46   | CONSERVATION OF MAIN FUEL/RSD            |
| KAWAS CCPP       | 1       |               | 18/12/2024 18:59    | 19/12/2024 05:15   | CONSERVATION OF MAIN FUEL/RSD            |
| KAWAS CCPP       | 2       | 106.00        | 19/12/2024 09:54    | 19/12/2024 15:01   | CONSERVATION OF MAIN FUEL/RSD            |
| KAWAS CCPP       | 2       |               | 18/12/2024 18:59    | 19/12/2024 05:45   | CONSERVATION OF MAIN FUEL/RSD            |
| KAWAS CCPP       | 3       | 106.00        | 18/12/2024 18:58    | 19/12/2024 05:01   | NO/REDUCED IRRIGATION DEMAND             |
| KAWAS CCPP       | 4       | 106.00        | 18/12/2024 18:57    | 19/12/2024 05:30   | CONSERVATION OF MAIN FUEL/RSD            |
| KAWAS CCPP       | 4       |               | 19/12/2024 09:58    | 19/12/2024 15:20   | CONSERVATION OF MAIN FUEL/RSD            |
| KAKRAPARA        | 4       | 700.00        | 19/12/2024 00:44    | 19/12/2024 02:46   | Turbine Misc                             |
| GANDHI NAGAR TPS | 5       | 210.00        | 10/12/2024 06:23    | 19/12/2024 05:30   | RSD/LOW SCHEDULE                         |
| WANAKBORI TPS    | 3       | 210.00        | 18/12/2024 18:00    | 19/12/2024 08:00   | TURBINE CONTROL VALVE PROBLEM            |
| WANAKBORI TPS    | 8       | 800.00        | 19/12/2024 22:16    | 19/12/2024 23:50   | ELECTRICAL MISCELLANEOUS PROBLEMS        |

| Station                         | Unit No | Capacity (MW) | Date of Maintanance | Sync Date          | remarks                                   |
|---------------------------------|---------|---------------|---------------------|--------------------|---|
|                                 |         |               | DD/MM/YYYY HH:24MM  | DD/MM/YYYY HH:24MM |   |
| 1                               | 2       | 3             | 4                   | 5                  | 6   |
| WANAKBORI TPS                   | 8       |               | 19/12/2024 14:00    | 19/12/2024 15:50   | ELECTRICAL MISCELLANEOUS PROBLEMS         |
| SALAYA TPP                      | 2       | 600.00        | 14/12/2024 20:26    | 19/12/2024 05:06   | RESERVE SHUT DOWN / STANDBY UNIT          |
| MAUDA TPS                       | 1       | 500.00        | 12/12/2024 23:21    | 19/12/2024 03:03   | BOILER INSPECTION/ RE-CERTIFICATION       |
| RATNAGIRI CCPP                  | 4       | 213.00        | 19/12/2024 10:00    | 19/12/2024 14:21   | GT-MISCELLANEOUS PROBLEMS                 |
| RATNAGIRI CCPP                  | 5       | 213.00        | 18/12/2024 11:12    | 19/12/2024 04:41   | GT-MISCELLANEOUS PROBLEMS                 |
| RATNAGIRI CCPP                  | 8       | 213.00        | 18/12/2024 19:54    | 19/12/2024 03:41   | GT-MISCELLANEOUS PROBLEMS                 |
| RATNAGIRI CCPP                  | 8       |               | 19/12/2024 10:26    | 19/12/2024 15:13   | GT-MISCELLANEOUS PROBLEMS                 |
| BHUSAVAL TPS                    | 5       | 500.00        | 17/12/2024 16:56    | 19/12/2024 18:50   | Instrumentation & Control System Abnormal |
| NASIK TPS                       | 3       | 210.00        | 15/12/2024 17:48    | 19/12/2024 04:28   | REHEATER TUBE LEAKAGE                     |
| NASIK TPS                       | 3       |               | 19/12/2024 06:50    | 19/12/2024 09:10   | CONDENSER LOW VACCUM                      |
| URAN CCPP                       | 5       | 108.00        | 19/12/2024 08:15    | 19/12/2024 18:05   | RESERVE SHUT DOWN                         |
| URAN CCPP                       | 5       |               | 19/12/2024 00:00    | 19/12/2024 07:53   | RESERVE SHUT DOWN                         |
| WARDHA WARORA TPP               | 1       | 135.00        | 28/10/2024 16:03    | 19/12/2024 08:46   | ELECTRICAL MISCELLANEOUS PROBLEMS         |
| SIMHAPURI TPS                   | 2       | 150.00        | 30/11/2024 21:10    | 19/12/2024 18:16   | P.A. FANS PROBLEM                         |
| RAICHUR TPS                     | 5       | 210.00        | 17/12/2024 11:25    | 19/12/2024 05:14   | WATER WALL TUBE LEAKAGE                   |
| NEYVELI ( EXT) TPS              | 2       | 210.00        | 19/12/2024 09:10    | 19/12/2024 14:04   | ELECTRICAL FAULT                          |
| NEYVELI TPS-II                  | 5       | 210.00        | 12/12/2024 20:57    | 19/12/2024 02:21   | BOILER MISC. PROBLEM                      |
| METTUR TPS - II                 | 1       | 600.00        | 16/12/2024 08:41    | 19/12/2024 20:21   | WATER WALL TUBE LEAKAGE                   |
| NORTH CHENNAI TPS               | 2       | 210.00        | 19/12/2024 11:06    | 19/12/2024 14:36   | FUEL SUPPLY & OTHER MISC. PROBLEMS        |
| TALCHER STPS                    | 1       | 500.00        | 17/12/2024 23:22    | 19/12/2024 22:00   | REHEATER TUBE LEAKAGE                     |
| HALDIA TPP                      | 1       | 300.00        | 15/12/2024 00:00    | 19/12/2024 10:25   | BOILER OVERHAUL/ ANNUAL MAINTENANCE       |
| BONGAIGAON TPP                  | 1       | 250.00        | 14/11/2024 01:00    | 19/12/2024 16:50   | BOILER OVERHAUL/ ANNUAL MAINTENANCE       |
| BONGAIGAON TPP                  | 1       |               | 19/12/2024 17:05    | 19/12/2024 19:34   | CONDENSER TUBE LEAKAGE/ CLEANING          |
| LAKWA REPLACEMENT POWER PROJECT | 3       | 9.96          | 19/12/2024 14:54    | 19/12/2024 16:30   | GRID DISTURBANCE                          |
| LAKWA REPLACEMENT POWER PROJECT | 6       | 9.96          | 18/12/2024 20:30    | 19/12/2024 07:00   | GRID DISTURBANCE                          |
| LAKWA REPLACEMENT POWER PROJECT | 6       |               | 19/12/2024 10:06    | 19/12/2024 14:39   | GRID DISTURBANCE                          |
| AGARTALA GT                     | 3       | 21.00         | 19/12/2024 00:00    | 19/12/2024 23:59   | Fuel Shortage                             |
| AGARTALA GT                     | 4       | 21.00         | 19/12/2024 00:00    | 19/12/2024 23:59   | Fuel Shortage                             |
| AGARTALA GT                     | 6       | 25.50         | 19/12/2024 00:00    | 19/12/2024 23:59   | Fuel Shortage                             |
| Total                           |         | 10,624.80     |                     |                    |   |