

**CENTRAL ELECTRICITY AUTHORITY  
G O & D WING  
OPERATION PERFORMANCE MONITORING DIVISION**

**THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 20-03-2019**

Sub-Report - 15

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
INDIRA GANDHI STPP	1	500.00	20/03/2019 21:09		RSD/LOW SCHEDULE
INDIRA GANDHI STPP	1		20/03/2019 06:57		FURNACE FIRE OUT /FLAME FAILURE
RAJIV GANDHI TPS	1	600.00	20/03/2019 20:04		RSD/LOW SCHEDULE
TALWANDI SABO TPP	3	660.00	20/03/2019 11:29		BOILER MISC. PROBLEM
KALISINDH TPS	2	600.00	20/03/2019 21:49	24/03/2019	SUPER HEATER TUBE LEAKAGE
KOTA TPS	3	210.00	20/03/2019 10:54		RSD/LOW SCHEDULE
KOTA TPS	5	210.00	20/03/2019 10:47		RSD/LOW SCHEDULE
KOTA TPS	7	195.00	20/03/2019 12:10		RSD/LOW SCHEDULE
DADRI (NCTPP)	3	210.00	20/03/2019 04:03		RSD/LOW SCHEDULE
KORBA-III	2	120.00	20/03/2019 11:47		WATER WALL TUBE LEAKAGE
RAIKHEDA TPP	1	685.00	20/03/2019 23:40		ELECTRICAL MISCELLANEOUS PROBLEMS
SIKKA REP. TPS	3	250.00	20/03/2019 22:40	24/03/2019	RESERVE SHUT DOWN / STANDBY UNIT
SIKKA REP. TPS	4	250.00	20/03/2019 00:16	24/03/2019	RESERVE SHUT DOWN / STANDBY UNIT
UKAI TPS	3	200.00	20/03/2019 10:10		RSD/LOW SCHEDULE
UKAI TPS	5	210.00	20/03/2019 11:49		RSD/LOW SCHEDULE
WANAKBORI TPS	3	210.00	20/03/2019 14:45		RSD/LOW SCHEDULE
KHAPARKHEDA TPS	2	210.00	20/03/2019 17:46		F.D. FANS PROBLEM
GODAVARI CCPP	2	47.00	20/03/2019 17:52	26/03/2019	Fuel Shortage
TALCHER STPS	2	500.00	20/03/2019 13:59		ELECTRICAL MISCELLANEOUS PROBLEMS
BANDEL TPS	1	60.00	20/03/2019 09:20		ECONOMISER TUBE LEAKAGE
SOUTHERN REPL. TPS	2	67.50	20/03/2019 20:45	21/03/2019	RESERVE SHUT DOWN / STANDBY UNIT
LAKWA REPLACEMENT POWER PROJECT	1	9.96	20/03/2019 09:38		Fuel System Abnormal/ Maintenance
LAKWA REPLACEMENT POWER PROJECT	2	9.96	20/03/2019 09:38		Fuel System Abnormal/ Maintenance
LAKWA REPLACEMENT POWER PROJECT	3	9.96	20/03/2019 09:38		Fuel System Abnormal/ Maintenance
LAKWA REPLACEMENT POWER PROJECT	4	9.96	20/03/2019 09:38		Fuel System Abnormal/ Maintenance
LAKWA REPLACEMENT POWER PROJECT	5	9.96	20/03/2019 09:38	20/03/2019	Fuel System Abnormal/ Maintenance
LAKWA REPLACEMENT POWER PROJECT	6	9.96	20/03/2019 09:38		Fuel System Abnormal/ Maintenance
LAKWA REPLACEMENT POWER PROJECT	7	9.96	20/03/2019 09:38		Fuel System Abnormal/ Maintenance
Total		6064.26			