

CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 21-10-2021

Sub-Report - 15

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
GOINDWAL SAHIB TPP	1	270.00	21/10/2021 16:51		FURNACE FIRE OUT /FLAME FAILURE
AURAIYA CCPP	3	111.19	21/10/2021 21:37		RSD/LOW SCHEDULE
AURAIYA CCPP	4	111.19	21/10/2021 21:27		RSD/LOW SCHEDULE
AURAIYA CCPP	6	109.30	21/10/2021 21:29		RSD/LOW SCHEDULE
DADRI CCPP	1	130.19	21/10/2021 00:54		RSD/LOW SCHEDULE
DADRI CCPP	1		21/10/2021 21:00		RSD/LOW SCHEDULE
DADRI CCPP	2	130.19	21/10/2021 19:52		RSD/LOW SCHEDULE
DADRI CCPP	3	130.19	21/10/2021 21:21		RSD/LOW SCHEDULE
DADRI CCPP	5	154.51	21/10/2021 00:49		RSD/LOW SCHEDULE
OBRA TPS	12	200.00	21/10/2021 09:54		AIR PREHEATERS PROBLEM
BARKHERA TPS	2	45.00	21/10/2021 21:30		RSD/LOW SCHEDULE
AVANTHA BHANDAR	1	600.00	21/10/2021 22:33		WATER WALL TUBE LEAKAGE
RAIKHEDA TPP	1	685.00	21/10/2021 22:33		BOILER MISC. PROBLEM
KAWAS CCPP	1	106.00	21/10/2021 21:08		RSD/LOW SCHEDULE
KAWAS CCPP	4	106.00	21/10/2021 21:02		RSD/LOW SCHEDULE
GANDHI NAGAR TPS	4	210.00	21/10/2021 11:32		WATER WALL TUBE LEAKAGE
SANJAY GANDHI TPS	5	500.00	21/10/2021 22:31		TURBINE VIBRATION HIGH
SHREE SINGAJI TPP	1	600.00	21/10/2021 00:00		RESERVE SHUT DOWN
BINA TPS	2	250.00	21/10/2021 22:25		A.V.R. PROBLEM
SASAN UMTTP	1	660.00	21/10/2021 05:27		SUPER HEATER TUBE LEAKAGE
Dr. N.TATA RAO TPS	6	210.00	21/10/2021 19:25		FURNACE FIRE OUT /FLAME FAILURE
RAYALASEEMA TPS	6	600.00	21/10/2021 01:14		WATER WALL TUBE LEAKAGE
JEGURUPADU CCPP PH I	3	52.80	21/10/2021 13:45	31/10/2021	Fuel Shortage
TUTICORIN TPS	5	210.00	21/10/2021 02:00		RESERVE SHUT DOWN
KAHALGAON TPS	7	500.00	21/10/2021 12:12	21/10/2021	BOILER FEED PUMP/MOTOR PROBLEM
NABINAGAR STPP	2	660.00	21/10/2021 01:36		FURNACE DRAFT ABNORMAL
RAGHUNATHPUR TPP	1	600.00	21/10/2021 09:41		TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE
KOLAGHAT TPS	3	210.00	21/10/2021 21:02		ECONOMISER TUBE LEAKAGE
SOUTHERN REPL. TPS	1	67.50	21/10/2021 20:54	22/10/2021	RESERVE SHUT DOWN
SOUTHERN REPL. TPS	1		21/10/2021 12:55		GENERATOR PROTECTION RELAY OPERATION PROBLEM
SOUTHERN REPL. TPS	2	67.50	21/10/2021 21:26	22/10/2021	RESERVE SHUT DOWN
LAKWA REPLACEMENT POWER PROJECT	1	9.96	21/10/2021 10:32		Fuel Shortage

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
LAKWA REPLACEMENT POWER PROJECT	1		21/10/2021 02:50		GRID DISTURBANCES MISC.
LAKWA REPLACEMENT POWER PROJECT	2	9.96	21/10/2021 02:47		GRID DISTURBENCE
LAKWA REPLACEMENT POWER PROJECT	3	9.96	21/10/2021 17:44		Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	3		21/10/2021 02:40		GRID DISTURBENCE
LAKWA REPLACEMENT POWER PROJECT	4	9.96	21/10/2021 02:47		GRID DISTURBENCE
LAKWA REPLACEMENT POWER PROJECT	4		21/10/2021 13:14		Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	5	9.96	21/10/2021 03:18		GRID DISTURBENCE
LAKWA REPLACEMENT POWER PROJECT	5		21/10/2021 19:44		Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	6	9.96	21/10/2021 02:42		GRID DISTURBENCE
LAKWA REPLACEMENT POWER PROJECT	7	9.96	21/10/2021 02:32		GRID DISTURBENCE
LAKWA REPLACEMENT POWER PROJECT	7		21/10/2021 12:45		Fuel Shortage
MONARCHAK CCPP	1	65.40	21/10/2021 06:54		MISCELLANEOUS
MONARCHAK CCPP	1		21/10/2021 03:55		MISCELLANEOUS
MONARCHAK CCPP	1		21/10/2021 11:37		MISCELLANEOUS
MONARCHAK CCPP	2	35.60	21/10/2021 11:48		MISCELLANEOUS
Total		8457.32			