

CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION

RECOMMISSIONNING OF THERMAL/NUCLEAR UNITS AS ON: 22-05-2025

Sub-Report - 14

Station	Unit No	Capacity (MW)	Date of Maintanance	Sync Date	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
PRAGATI CCPP	2	104.60	21/05/2025 22:30	22/05/2025 08:23	Low system demand/ costly fuel
PANIPAT TPS	8	250.00	21/05/2025 18:49	22/05/2025 20:43	GRID DISTURBANCE
RAJIV GANDHI TPS	1	600.00	23/02/2025 21:06	22/05/2025 21:59	WATER WALL TUBE LEAKAGE
GH TPS (LEH.MOH.)	4	250.00	19/05/2025 14:15	22/05/2025 13:47	WATER WALL TUBE LEAKAGE
TALWANDI SABO TPP	3	660.00	22/05/2025 08:47	22/05/2025 22:57	BOILER AUX. MISC. PROMLEMS
RAJASTHAN A.P.S.	2	200.00	22/05/2025 12:39	22/05/2025 13:11	Miscellaneous
RAJASTHAN A.P.S.	2		31/12/2024 21:44	22/05/2025 01:56	ANNUAL MAINTENANCE
RAJASTHAN A.P.S.	2		22/05/2025 04:10	22/05/2025 07:45	Miscellaneous
CHHABRA-I PH-1 TPP	2	250.00	22/05/2025 17:11	22/05/2025 20:38	FURNACE DRAFT ABNORMAL
KOTA TPS	4	210.00	21/05/2025 11:58	22/05/2025 21:41	BOILER MISC. PROBLEM
JALIPA KAPURDI TPP	2	135.00	16/05/2025 15:44	22/05/2025 06:02	BOILER MISC. PROBLEM
DADRI (NCTPP)	1	210.00	21/05/2025 20:08	22/05/2025 21:05	TRIPPING OF TRANSMISSION LINE
DADRI (NCTPP)	2	210.00	21/05/2025 20:01	22/05/2025 16:22	TRIPPING OF TRANSMISSION LINE
DADRI (NCTPP)	3	210.00	21/05/2025 20:01	22/05/2025 20:19	TRIPPING OF TRANSMISSION LINE
DADRI (NCTPP)	4	210.00	21/05/2025 20:01	22/05/2025 07:59	TRIPPING OF TRANSMISSION LINE
DADRI (NCTPP)	5	490.00	21/05/2025 20:25	22/05/2025 07:35	TRIPPING OF TRANSMISSION LINE
DADRI (NCTPP)	6	490.00	21/05/2025 20:12	22/05/2025 14:56	TRIPPING OF TRANSMISSION LINE
MEJA STPP	2	660.00	21/05/2025 19:56	22/05/2025 00:32	BOILER MISC. PROBLEM
SHREE SINGAJI TPP	4	660.00	09/05/2025 01:56	22/05/2025 03:47	WATER WALL TUBE LEAKAGE
SIMHADRI	2	500.00	22/05/2025 00:13	22/05/2025 06:20	ELECTRICAL FAULT
RAYALASEEMA TPS	3	210.00	21/05/2025 21:37	22/05/2025 19:41	ECONOMISER TUBE LEAKAGE
SIMHAPURI TPS	2	150.00	19/05/2025 08:15	22/05/2025 13:29	BOILER AUX. MISC. PROMLEMS
NTPL TUTICORIN TPP	1	500.00	07/05/2025 19:13	22/05/2025 07:59	ESP PROBLEM
NORTH CHENNAI TPS	4	600.00	01/03/2025 11:14	22/05/2025 00:51	TURBINE MISC. PROBLEM
NORTH CHENNAI TPS	4		22/05/2025 18:35	22/05/2025 23:30	TURBINE VIBRATIONS HIGH
KAKATIYA TPS	2	600.00	22/05/2025 13:59	22/05/2025 17:01	BOILER MISC. PROBLEM
KOTHAGUDEM TPS (NEW)	9	250.00	22/05/2025 07:21	22/05/2025 18:01	RSD/LOW SCHEDULE
FARAKKA STPS	2	200.00	20/05/2025 20:29	22/05/2025 16:38	ECONOMISER TUBE LEAKAGE
D.P.L. TPS	8	250.00	07/05/2025 04:10	22/05/2025 11:25	STATION TRANSFORMER PROBLEM
KATHALGURI CCPP	4	33.50	22/05/2025 00:00	22/05/2025 23:59	LOW SYSTEM DEMAND
KATHALGURI CCPP	8	30.00	22/05/2025 00:00	22/05/2025 23:59	MISCELLANEOUS PLANNED MAINTENANCE
KATHALGURI CCPP	9	30.00	22/05/2025 00:00	22/05/2025 16:09	MISCELLANEOUS

Station	Unit No	Capacity (MW)	Date of Maintanance	Sync Date	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
LAKWA REPLACEMENT POWER PROJECT	4	9.96	21/05/2025 09:59	22/05/2025 14:42	GRID DISTURBENCE
LAKWA REPLACEMENT POWER PROJECT	5	9.96	22/05/2025 14:49	22/05/2025 19:54	GRID DISTURBANCE
AGARTALA GT	1	21.00	22/05/2025 00:00	22/05/2025 23:59	Fuel Shortage
AGARTALA GT	2	21.00	22/05/2025 00:00	22/05/2025 23:59	Fuel Shortage
AGARTALA GT	5	25.50	22/05/2025 00:00	22/05/2025 23:59	Fuel Shortage
AGARTALA GT	6	25.50	22/05/2025 05:02	22/05/2025 06:46	MISCELLANEOUS
Total		9,266.03			