

**CENTRAL ELECTRICITY AUTHORITY  
G O & D WING  
OPERATION PERFORMANCE MONITORING DIVISION**

**RECOMMISSIONING OF THERMAL/NUCLEAR UNITS AS ON: 24-02-2021**

Sub-Report - 14

Station	Unit No	Capacity (MW)	Date of Maintanance	Sync Date	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
BARSINGSAR LIGNITE	2	125.00	19/02/2021 14:00	24/02/2021 07:10	BOILER AUX. MISC. PROMLEMS
ANPARA TPS	1	210.00	17/11/2020 05:05	24/02/2021 06:04	RSD/LOW SCHEDULE
WANAKBORI TPS	1	210.00	22/02/2021 09:09	24/02/2021 00:46	ECONOMISER TUBE LEAKAGE
SATPURA TPS	6	200.00	16/02/2021 21:25	24/02/2021 06:23	RSD/LOW SCHEDULE
SATPURA TPS	7	210.00	16/02/2021 21:33	24/02/2021 03:25	RSD/LOW SCHEDULE
SASAN UMTTP	1	660.00	23/02/2021 09:55	24/02/2021 21:43	SUPER HEATER TUBE LEAKAGE
WARDHA WARORA TPP	3	135.00	19/02/2021 23:38	24/02/2021 01:41	ELECTRICAL MISCELLANEOUS PROBLEMS
WARDHA WARORA TPP	4	135.00	19/02/2021 23:03	24/02/2021 02:41	ELECTRICAL MISCELLANEOUS PROBLEMS
RAICHUR TPS	5	210.00	22/02/2021 00:00	24/02/2021 04:25	RSD/LOW SCHEDULE
NEYVELI ( EXT) TPS	2	210.00	24/02/2021 13:26	24/02/2021 18:46	BOILER FEED PUMP/MOTOR PROBLEM
NORTH CHENNAI TPS	3	210.00	20/02/2021 18:20	24/02/2021 13:32	REHEATER TUBE LEAKAGE
BARAUNI TPS	8	250.00	22/02/2021 09:22	24/02/2021 18:16	TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE
TALCHER (OLD) TPS	3	60.00	23/02/2021 10:34	24/02/2021 01:38	WATER WALL TUBE LEAKAGE
TALCHER STPS	5	500.00	16/01/2021 10:34	24/02/2021 02:41	OVERHAULING WORKS
Total		3,325.00			