

**CENTRAL ELECTRICITY AUTHORITY  
G O & D WING  
OPERATION PERFORMANCE MONITORING DIVISION**

**THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 24-02-2021**

Sub-Report - 15

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
RIHAND STPS	3	500.00	24/02/2021 20:20	24/02/2021	WATER WALL TUBE LEAKAGE
SINGRAULI STPS	7	500.00	24/02/2021 15:06	24/02/2021	WATER WALL TUBE LEAKAGE
SIPAT STPS	2	660.00	24/02/2021 23:50	24/02/2021	P.A. FANS PROBLEM
ANUPPUR TPP	1	600.00	24/02/2021 21:52	28/02/2021	BOILER MISC. PROBLEM
SOLAPUR STPS	2	660.00	24/02/2021 03:19	24/02/2021	PG TEST PREPARATION
RAICHUR TPS	5	210.00	24/02/2021 19:47		TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE
NEYVELI ( EXT) TPS	2	210.00	24/02/2021 23:18		BOILER FEED PUMP/MOTOR PROBLEM
NEYVELI ( EXT) TPS	2		24/02/2021 13:26		BOILER FEED PUMP/MOTOR PROBLEM
BARAUNI TPS	9	250.00	24/02/2021 13:17		FUEL OIL PROBLEM
MUZAFFARPUR TPS	4	195.00	24/02/2021 12:59		AIR PREHEATERS PROBLEM
CHANDRAPURA(DVC) TPS	8	250.00	24/02/2021 23:55		CAPITAL MAINTENANCE
TALCHER (OLD) TPS	5	110.00	24/02/2021 08:46	24/02/2021	VARIOUS STEAM LEAKAGES
Total		4145.00			