

**CENTRAL ELECTRICITY AUTHORITY  
G O & D WING  
OPERATION PERFORMANCE MONITORING DIVISION**

**RECOMMISSIONING OF THERMAL/NUCLEAR UNITS AS ON: 24-04-2024**

Sub-Report - 14

Station	Unit No	Capacity (MW)	Date of Maintanance	Sync Date	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
ANTA CCPP	3	88.71	23/04/2024 23:18	24/04/2024 15:08	CONSERVATION OF MAIN FUEL/RSD
SURATGARH STPS	8	660.00	21/04/2024 21:28	24/04/2024 10:51	BOILER MISC. PROBLEM
SURATGARH TPS	3	250.00	18/04/2024 19:28	24/04/2024 15:58	FURNACE FIRE OUT /FLAME FAILURE
AURAIYA CCPP	1	111.19	23/04/2024 23:03	24/04/2024 15:06	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	3	111.19	23/04/2024 23:05	24/04/2024 14:58	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	3	130.19	23/04/2024 23:13	24/04/2024 14:42	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	3	106.00	23/04/2024 22:56	24/04/2024 14:17	CONSERVATION OF MAIN FUEL/RSD
SUGEN CCPP	1	382.50	24/04/2024 03:24	24/04/2024 15:49	RSD/LOW SCHEDULE
NIWARI TPP	1	45.00	24/04/2024 06:15	24/04/2024 13:49	GRID DISTURBANCE
NIWARI TPP	2	45.00	24/04/2024 06:15	24/04/2024 11:38	GRID DISTURBANCE
MAUDA TPS	3	660.00	20/04/2024 21:27	24/04/2024 10:35	SUPER HEATER TUBE LEAKAGE
RATNAGIRI CCPP	5	213.00	23/04/2024 23:19	24/04/2024 13:44	GT-MISCELLANEOUS PROBLEMS
RATNAGIRI CCPP	8	213.00	23/04/2024 23:56	24/04/2024 14:11	GT-MISCELLANEOUS PROBLEMS
BHUSAWAL TPS	4	500.00	18/04/2024 22:33	24/04/2024 11:07	REHEATER TUBE LEAKAGE
KHAPARKHEDA TPS	5	500.00	22/04/2024 07:26	24/04/2024 07:56	WATER WALL TUBE LEAKAGE
ADANI POWER LIMITED TIRODA TPP	1	660.00	23/04/2024 20:15	24/04/2024 10:08	SWITCH YARD/TRIPPING OF TRANSMISSION LINES/BUS BAR PROBLEM
ADANI POWER LIMITED TIRODA TPP	1		24/04/2024 13:31	24/04/2024 16:16	TURBINE MISC.
ADANI POWER LIMITED TIRODA TPP	2	660.00	23/04/2024 20:15	24/04/2024 13:22	SWITCH YARD/TRIPPING OF TRANSMISSION LINES/BUS BAR PROBLEM
ADANI POWER LIMITED TIRODA TPP	3	660.00	23/04/2024 20:15	24/04/2024 08:41	SWITCH YARD/TRIPPING OF TRANSMISSION LINES/BUS BAR PROBLEM
DAHANU TPS	1	250.00	23/04/2024 01:10	24/04/2024 19:57	BOILER MISC. PROBLEM
SIMHADRI	2	500.00	24/04/2024 05:13	24/04/2024 12:20	C&I PROBLEM
KOTHAGUDEM TPS (NEW)	11	500.00	23/04/2024 07:48	24/04/2024 10:23	WATER WALL TUBE LEAKAGE
LAKWA REPLACEMENT POWER PROJECT	1	9.96	24/04/2024 17:49	24/04/2024 23:17	Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	1		24/04/2024 12:47	24/04/2024 14:22	Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	3	9.96	22/04/2024 21:41	24/04/2024 16:12	Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	4	9.96	24/04/2024 01:00	24/04/2024 15:46	GRID DISTURBANCE
LAKWA REPLACEMENT POWER PROJECT	4		23/04/2024 23:00	24/04/2024 01:00	Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	6	9.96	24/04/2024 02:45	24/04/2024 16:24	Fuel Shortage
Total		7,285.64			