

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 24-04-2024

Sub-Report - 15

| Station | Unit No | Capacity (MW) | Date of Maintanance | Expected/Sync Date of return | remarks |
|---------------------------------|---------|---------------|---------------------|------------------------------|---|
| | | | DD/MM/YYYY HH:24MM | DD/MM/YYYY HH:24MM | |
| 1 | 2 | 3 | 4 | 5 | 6 |
| JALIPA KAPURDI TPP | 5 | 135.00 | 24/04/2024 12:53 | | BOILER AUX. MISC. PROMLEMS |
| MARWA TPS | 2 | 500.00 | 24/04/2024 14:30 | | WATER WALL TUBE LEAKAGE |
| CHAKABURA TPP | 2 | 30.00 | 24/04/2024 02:38 | | WATER WALL TUBE LEAKAGE |
| KAKRAPARA | 4 | 700.00 | 24/04/2024 19:24 | | REACTOR MAINTENANCE WORKS. |
| SABARMATI (D-F STATIONS) | 1 | 120.00 | 24/04/2024 06:00 | | BOILER AUX. MISC. PROMLEMS |
| SUGEN CAPP | 1 | 382.50 | 24/04/2024 03:24 | 25/04/2024 | RSD/LOW SCHEDULE |
| NIWARI TPP | 1 | 45.00 | 24/04/2024 06:15 | 24/04/2024 | GRID DISTURBANCE |
| NIWARI TPP | 2 | 45.00 | 24/04/2024 06:15 | 24/04/2024 | GRID DISTURBANCE |
| KHAPARKHEDA TPS | 4 | 210.00 | 24/04/2024 08:00 | | ECONOMISER TUBE LEAKAGE |
| ADANI POWER LIMITED TIRODA TPP | 1 | 660.00 | 24/04/2024 13:31 | | TURBINE MISC. |
| SIMHADRI | 2 | 500.00 | 24/04/2024 05:13 | 24/04/2024 | C&I PROBLEM |
| NEYVELI TPS-II EXP | 1 | 250.00 | 24/04/2024 22:31 | | FBHE (FLUIDISED BED HEAT EXCHANGER) PROBLEM |
| METTUR TPS | 3 | 210.00 | 24/04/2024 23:39 | 25/04/2024 | ECONOMISER TUBE LEAKAGE |
| BHADRADRI TPP | 1 | 270.00 | 24/04/2024 12:11 | | WATER WALL TUBE LEAKAGE |
| LAKWA REPLACEMENT POWER PROJECT | 1 | 9.96 | 24/04/2024 12:47 | | Fuel Shortage |
| LAKWA REPLACEMENT POWER PROJECT | 1 | | 24/04/2024 17:49 | | Fuel Shortage |
| LAKWA REPLACEMENT POWER PROJECT | 4 | 9.96 | 24/04/2024 01:00 | | GRID DISTURBANCE |
| LAKWA REPLACEMENT POWER PROJECT | 6 | 9.96 | 24/04/2024 02:45 | | Fuel Shortage |
| LAKWA REPLACEMENT POWER PROJECT | 7 | 9.96 | 24/04/2024 14:10 | | Fuel Shortage |
| Total | | 4097.36 | | | |