

**CENTRAL ELECTRICITY AUTHORITY  
G O & D WING  
OPERATION PERFORMANCE MONITORING DIVISION**

**RECOMMISSIONING OF THERMAL/NUCLEAR UNITS AS ON: 25-07-2024**

Sub-Report - 14

Station	Unit No	Capacity (MW)	Date of Maintanance	Sync Date	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
ANTA CCPP	1	88.71	23/07/2024 23:45	25/07/2024 19:39	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	2	88.71	23/07/2024 23:45	25/07/2024 18:56	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	3	88.71	23/07/2024 23:45	25/07/2024 19:18	CONSERVATION OF MAIN FUEL/RSD
RAJASTHAN A.P.S.	3	220.00	28/10/2022 00:00	25/07/2024 02:22	ENMASS COOLANT CHANNEL REPLACEMENT
CHHABRA-I PH-1 TPP	2	250.00	01/07/2024 14:03	25/07/2024 00:02	ANNUAL MAINTENANCE
AURAIYA CCPP	1	111.19	23/07/2024 23:43	25/07/2024 19:12	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	2	111.19	23/07/2024 23:44	25/07/2024 19:57	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	3	111.19	23/07/2024 23:43	25/07/2024 19:01	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	4	111.19	23/07/2024 23:43	25/07/2024 19:07	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	2	130.19	23/07/2024 23:42	25/07/2024 19:01	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	3	130.19	23/07/2024 23:42	25/07/2024 19:12	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	4	130.19	23/07/2024 23:42	25/07/2024 19:36	CONSERVATION OF MAIN FUEL/RSD
ANPARA TPS	1	210.00	25/07/2024 03:20	25/07/2024 06:25	MISCELLANEOUS
ANPARA TPS	5	500.00	25/07/2024 01:18	25/07/2024 07:04	ELECTRICAL FAULT
KAWAS CCPP	6	116.10	24/07/2024 12:00	25/07/2024 12:00	BOILER OVERHAUL/ ANNUAL MAINTENANCE
RATNAGIRI CCPP	4	213.00	25/07/2024 00:16	25/07/2024 16:29	GT-MISCELLANEOUS PROBLEMS
RATNAGIRI CCPP	8	213.00	24/07/2024 23:55	25/07/2024 15:53	GT-MISCELLANEOUS PROBLEMS
KHAPARKHEDA TPS	5	500.00	23/07/2024 10:00	25/07/2024 12:39	WATER WALL TUBE LEAKAGE
THAMMINAPATNAM TPS	2	150.00	25/07/2024 08:17	25/07/2024 14:45	DRUM LEVEL HIGH/ low
RAICHUR TPS	3	210.00	20/07/2024 22:38	25/07/2024 21:34	MAIN STEAM LINE PROBLEM
RAICHUR TPS	8	250.00	25/07/2024 12:26	25/07/2024 14:16	FURNACE FIRE OUT /FLAME FAILURE
YERMARUS TPP	2	800.00	23/07/2024 02:28	25/07/2024 17:16	COAL FEEDING PROBLEM IN PLANT
NEYVELI TPS-II	4	210.00	23/07/2024 07:36	25/07/2024 22:39	BOILER AUX. MISC. PROMLEMS
KATHALGURI CCPP	1	33.50	25/07/2024 00:00	25/07/2024 23:59	MISCELLANEOUS PLANNED MAINTENANCE
KATHALGURI CCPP	2	33.50	25/07/2024 01:05	25/07/2024 01:17	MISCELLANEOUS
KATHALGURI CCPP	2		25/07/2024 09:31	25/07/2024 18:24	MISCELLANEOUS
KATHALGURI CCPP	7	30.00	25/07/2024 01:05	25/07/2024 23:59	MISCELLANEOUS
LAKWA REPLACEMENT POWER PROJECT	4	9.96	24/07/2024 22:45	25/07/2024 01:37	Fuel Shortage
NAMRUP CCPP	6	9.00	25/07/2024 11:30	25/07/2024 17:55	GRID SYSTEM PROBLEMS
AGARTALA GT	3	21.00	25/07/2024 00:00	25/07/2024 21:03	Fuel Shortage
AGARTALA GT	6	25.50	25/07/2024 06:40	25/07/2024 09:46	Fuel Shortage
AGARTALA GT	6		25/07/2024 09:46	25/07/2024 23:59	MISCELLANOUS

Total	5,106.02	
-------	----------	--