

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 25-07-2024

Sub-Report - 15

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
ANTA CCPP	1	88.71	25/07/2024 23:57	25/07/2024	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	2	88.71	25/07/2024 23:58	25/07/2024	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	3	88.71	25/07/2024 23:58	25/07/2024	CONSERVATION OF MAIN FUEL/RSD
CHHABRA-I PH-1 TPP	2	250.00	25/07/2024 09:57		GENEATOR TRANSFORMER DAMAGED
JALIPA KAPURDI TPP	4	135.00	25/07/2024 14:30		BOILER MISC. PROBLEM
AURAIYA CCPP	1	111.19	25/07/2024 23:57	25/07/2024	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	2	111.19	25/07/2024 23:56	25/07/2024	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	3	111.19	25/07/2024 20:42	25/07/2024	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	4	111.19	25/07/2024 23:56	25/07/2024	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	2	130.19	25/07/2024 23:53	25/07/2024	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	3	130.19	25/07/2024 23:53	25/07/2024	NO/REDUCED IRRIGATION DEMAND
DADRI CCPP	4	130.19	25/07/2024 23:53	25/07/2024	CONSERVATION OF MAIN FUEL/RSD
ANPARA TPS	1	210.00	25/07/2024 03:20		MISCELLANEOUS
ANPARA TPS	5	500.00	25/07/2024 01:18		ELECTRICAL FAULT
BINJKOTE TPP	2	300.00	25/07/2024 23:04		P.A. FANS PROBLEM
KAWAS CCPP	6	116.10	25/07/2024 12:00	25/07/2024	NO/REDUCED IRRIGATION DEMAND
KAKRAPARA	1	220.00	25/07/2024 10:12		TURBINE MISC.
UKAI TPS	4	200.00	25/07/2024 00:41		COAL FEEDING SYSTEM FAILURE.
WANAKBORI TPS	1	210.00	25/07/2024 06:32		FURNACE DRAFT ABNORMAL
SALAYA TPP	2	600.00	25/07/2024 23:00		RESERVE SHUT DOWN / STANDBY UNIT
VINDHYACHAL STPS	2	210.00	25/07/2024 09:32	25/07/2024	REHEATER TUBE LEAKAGE
VINDHYACHAL STPS	9	500.00	25/07/2024 09:46	25/07/2024	WATER WALL TUBE LEAKAGE
AMARKANTAK EXT TPS	3	210.00	25/07/2024 00:00		ANNUAL MAINTENANCE
MAUDA TPS	4	660.00	25/07/2024 14:20	25/07/2024	WATER WALL TUBE LEAKAGE
RATNAGIRI CCPP	4	213.00	25/07/2024 00:16		GT-MISCELLANEOUS PROBLEMS
CHANDRAPUR(MAHARASHTRA) STPS	7	500.00	25/07/2024 00:00		AIR PREHEATERS PROBLEM
THAMMINAPATNAM TPS	2	150.00	25/07/2024 08:17		DRUM LEVEL HIGH/ low
RAICHUR TPS	2	210.00	25/07/2024 06:23		WATER WALL TUBE LEAKAGE
RAICHUR TPS	8	250.00	25/07/2024 12:26		FURNACE FIRE OUT /FLAME FAILURE
D.P.L. TPS	7	300.00	25/07/2024 02:03		CONDENSER TUBE LEAKAGE/ CLEANING
KATHALGURI CCPP	1	33.50	25/07/2024 00:00		MISCELLANEOUS PLANNED MAINTENANCE
KATHALGURI CCPP	2	33.50	25/07/2024 09:31		MISCELLANEOUS

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
KATHALGURI CCPP	2		25/07/2024 01:05		MISCELLANEOUS
KATHALGURI CCPP	7	30.00	25/07/2024 01:05		MISCELLANEOUS
NAMRUP CCPP	6	9.00	25/07/2024 11:30	25/07/2024	GRID SYSTEM PROBLEMS
AGARTALA GT	3	21.00	25/07/2024 00:00		Fuel Shortage
AGARTALA GT	6	25.50	25/07/2024 06:40		Fuel Shortage
AGARTALA GT	6		25/07/2024 09:46		MISCELLANOUS
Total		7198.06			