

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

RECOMMISSIONNING OF THERMAL/NUCLEAR UNITS AS ON: 25-11-2020

Sub-Report - 14

Station	Unit No	Capacity (MW)	Date of Maintanance	Sync Date	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
YAMUNA NAGAR TPS	1	300.00	13/11/2020 18:47	25/11/2020 03:33	RSD/LOW SCHEDULE
RAJPURA TPP	2	700.00	29/10/2020 09:00	25/11/2020 18:22	COAL SHORTAGE
KALISINDH TPS	2	600.00	25/11/2020 02:10	25/11/2020 04:47	DRUM LEVEL HIGH/ low
RIHAND STPS	1	500.00	29/09/2020 17:34	25/11/2020 21:12	BOILER OVERHAUL/ ANNUAL MAINTENANCE
OBRA TPS	10	200.00	23/11/2020 14:20	25/11/2020 02:28	I.D. FANS PROBLEM
HAZIRA CCPP	1	52.00	24/11/2020 21:12	25/11/2020 11:21	RSD/LOW SCHEDULE
HAZIRA CCPP	2	52.00	24/11/2020 20:53	25/11/2020 14:18	RSD/LOW SCHEDULE
HAZIRA CCPP	3	52.10	24/11/2020 20:59	25/11/2020 13:02	RSD/LOW SCHEDULE
SHREE SINGAJI TPP	2	600.00	18/11/2020 09:18	25/11/2020 15:48	WATER WALL TUBE LEAKAGE
MAHAN TPP	1	600.00	24/11/2020 04:09	25/11/2020 15:47	C&I PROBLEM
KHAPARKHEDA TPS	5	500.00	24/11/2020 16:09	25/11/2020 19:16	WATER WALL TUBE LEAKAGE
GODAVARI CCPP	2	47.00	21/11/2020 15:00	25/11/2020 09:52	FUEL SUPPLY & OTHER MISC. PROBLEMS
GODAVARI CCPP	4	67.00	20/11/2020 05:25	25/11/2020 12:42	FUEL SUPPLY & OTHER MISC. PROBLEMS
RAICHUR TPS	4	210.00	10/11/2020 20:10	25/11/2020 13:41	GT-GEN./FIELD BREAKER PROBLEM
NEYVELI TPS-II	6	210.00	22/11/2020 15:13	25/11/2020 02:24	WATER WALL TUBE LEAKAGE
D.P.L. TPS	8	250.00	24/10/2020 21:00	25/11/2020 12:57	ASH HANDLING SYSTEM PROBLEM
Total		4,940.10			