

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 25-11-2020

Sub-Report - 15

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
KALISINDH TPS	2	600.00	25/11/2020 02:10	25/11/2020	DRUM LEVEL HIGH/ low
KOTA TPS	1	110.00	25/11/2020 00:52		Low system demand/ costly fuel
KOTA TPS	2	110.00	25/11/2020 01:00		Low system demand/ costly fuel
OBRA TPS	11	200.00	25/11/2020 05:55	27/11/2020	BOILER INSPECTION/ RE-CERTIFICATION
KORBA STPS	6	500.00	25/11/2020 00:15		BOILER OVERHAUL/ ANNUAL MAINTENANCE
WANAKBORI TPS	4	210.00	25/11/2020 20:10		RSD/LOW SCHEDULE
WANAKBORI TPS	5	210.00	25/11/2020 21:00		RSD/LOW SCHEDULE
WANAKBORI TPS	5		25/11/2020 15:27		FUEL SUPPLY & OTHER MISC. PROBLEMS
WANAKBORI TPS	6	210.00	25/11/2020 18:53		RSD/LOW SCHEDULE
MUNDRA UMTTP	2	800.00	25/11/2020 16:57		HRH LINE LEAKAGE
SOLAPUR	1	660.00	25/11/2020 05:52		MAIN STEAM LINE PROBLEM
RAICHUR TPS	5	210.00	25/11/2020 00:00		BOILER MISC. PROBLEM
NEYVELI TPS-II	6	210.00	25/11/2020 18:52		LIGNITE SHORTAGE
NORTH CHENNAI TPS	3	210.00	25/11/2020 22:43	30/11/2020	GRID MISCELLANEOUS
Total		4240.00			