

**CENTRAL ELECTRICITY AUTHORITY  
G O & D WING  
OPERATION PERFORMANCE MONITORING DIVISION**

**RECOMMISSIONNING OF THERMAL/NUCLEAR UNITS AS ON: 26-02-2020**

Sub-Report - 14

Station	Unit No	Capacity (MW)	Date of Maintanance	Sync Date	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
KOTA TPS	3	210.00	26/02/2020 09:48	26/02/2020 11:31	FURNACE FIRE OUT /FLAME FAILURE
BINJKOTE TPP	2	300.00	26/02/2020 21:51	26/02/2020 23:25	P.A. FANS PROBLEM
HAZIRA CCPP EXT	1	351.00	03/01/2020 00:00	26/02/2020 23:28	GT- LOW SYSTEM DAMAND
BHUSAWAL TPS	4	500.00	26/02/2020 19:33	26/02/2020 22:59	FURNACE FIRE OUT /FLAME FAILURE
KHAPARKHEDA TPS	5	500.00	24/02/2020 06:28	26/02/2020 22:05	WATER WALL TUBE LEAKAGE
PARLI TPS	8	250.00	24/02/2020 22:00	26/02/2020 20:55	WATER WALL TUBE LEAKAGE
AMARAVATI TPS	1	270.00	08/02/2020 00:00	26/02/2020 03:50	RSD/LOW SCHEDULE
TIRORA TPS	2	660.00	22/02/2020 21:42	26/02/2020 06:55	AIR PREHEATERS PROBLEM
TROMBAY CCPP	1	120.00	02/02/2020 00:34	26/02/2020 01:32	TURBINE MISC. PROBLEM
TROMBAY CCPP	2	60.00	02/02/2020 00:16	26/02/2020 06:28	TURBINE MISC. PROBLEM
Dr. N.TATA RAO TPS	3	210.00	25/02/2020 14:43	26/02/2020 11:43	MILLING SYSTEM /RC FEEDER PROBLEM
YERMARUS TPP	1	800.00	26/02/2020 16:22	26/02/2020 22:46	F.D. FANS PROBLEM
VALLUR TPP	1	500.00	19/02/2020 21:08	26/02/2020 18:21	RESERVE SHUT DOWN / STANDBY UNIT
NORTH CHENNAI TPS	5	600.00	21/02/2020 06:51	26/02/2020 01:34	BOILER MISC. PROBLEM
TUTICORIN TPS	2	210.00	22/02/2020 17:37	26/02/2020 06:38	RESERVE SHUT DOWN / STANDBY UNIT
VALUTHUR CCPP	4	32.40	13/02/2020 06:33	26/02/2020 01:09	GT- GAS FLAME OFF/ DISTURBED FLAME
LAKWA REPLACEMENT POWER PROJECT	3	9.96	26/02/2020 08:48	26/02/2020 09:08	ELECTRICAL MISCELLANEOUS PROBLEMS
Total		5,583.36			