

**CENTRAL ELECTRICITY AUTHORITY**  
**G O & D WING**  
**OPERATION PERFORMANCE MONITORING DIVISION**

**RECOMMISSIONNING OF THERMAL/NUCLEAR UNITS AS ON: 26-03-2025**

Sub-Report - 14

| Station                         | Unit No | Capacity (MW) | Date of Maintanance | Sync Date          | remarks                           |
|---------------------------------|---------|---------------|---------------------|--------------------|-----------------------------------|
|                                 |         |               | DD/MM/YYYY HH:24MM  | DD/MM/YYYY HH:24MM |                                   |
| 1                               | 2       | 3             | 4                   | 5                  | 6                                 |
| CHHABRA-I PH-2 TPP              | 4       | 250.00        | 25/03/2025 00:30    | 26/03/2025 16:06   | WATER WALL TUBE LEAKAGE           |
| KOTA TPS                        | 7       | 195.00        | 24/03/2025 20:30    | 26/03/2025 08:01   | FURNACE DRAFT ABNORMAL            |
| RAMGARH CCPP                    | 2       | 35.50         | 14/03/2025 07:00    | 26/03/2025 10:34   | MINOR MAINTENANCE WORKS           |
| JAWAHARPUR STPP                 | 1       | 660.00        | 26/03/2025 16:55    | 26/03/2025 22:39   | BOILER MISC. PROBLEM              |
| JAWAHARPUR STPP                 | 2       | 660.00        | 24/03/2025 20:28    | 26/03/2025 11:12   | ECONOMISER TUBE LEAKAGE           |
| GANDHAR CCPP                    | 1       | 144.30        | 25/03/2025 17:41    | 26/03/2025 13:50   | CONSERVATION OF MAIN FUEL/RSD     |
| KAWAS CCPP                      | 3       | 106.00        | 25/03/2025 17:43    | 26/03/2025 14:02   | NO/REDUCED IRRIGATION DEMAND      |
| MUNDRA UMTTP                    | 1       | 800.00        | 24/03/2025 01:53    | 26/03/2025 17:51   | BOILER AUX. MISC. PROMLEMS        |
| SUGEN CCPP                      | 3       | 382.50        | 24/03/2025 21:24    | 26/03/2025 14:45   | RSD/LOW SCHEDULE                  |
| GADARWARA TPP                   | 2       | 800.00        | 23/03/2025 03:30    | 26/03/2025 05:38   | WATER WALL TUBE LEAKAGE           |
| PARAS TPS                       | 4       | 250.00        | 26/03/2025 03:57    | 26/03/2025 12:00   | STATOR/ STATOR EARTH FAULT        |
| RAICHUR TPS                     | 3       | 210.00        | 24/03/2025 08:10    | 26/03/2025 01:46   | FURNACE FIRE OUT /FLAME FAILURE   |
| NEYVELI ( EXT) TPS              | 1       | 210.00        | 22/03/2025 10:54    | 26/03/2025 06:33   | WATER WALL TUBE LEAKAGE           |
| RAMAGUNDEM STPS                 | 6       | 500.00        | 22/03/2025 17:48    | 26/03/2025 10:28   | WATER WALL TUBE LEAKAGE           |
| TALCHER STPS                    | 3       | 500.00        | 22/03/2025 00:11    | 26/03/2025 05:08   | BOILER MISC. PROBLEM              |
| JSW Energy Utkal Limited        | 1       | 350.00        | 26/03/2025 16:45    | 26/03/2025 20:56   | FURNACE DRAFT ABNORMAL            |
| MEJIA TPS                       | 5       | 250.00        | 24/03/2025 23:48    | 26/03/2025 17:20   | TURBINE VIBRATIONS HIGH           |
| MEJIA TPS                       | 5       |               | 26/03/2025 18:19    | 26/03/2025 20:38   | GENERATOR PROTECTION              |
| BUDGE BUDGE TPS                 | 3       | 250.00        | 25/03/2025 23:01    | 26/03/2025 00:36   | P.A. FANS PROBLEM                 |
| KATHALGURI CCPP                 | 3       | 33.50         | 26/03/2025 00:00    | 26/03/2025 11:11   | LOW SYSTEM DEMAND                 |
| KATHALGURI CCPP                 | 6       | 33.50         | 26/03/2025 11:18    | 26/03/2025 23:59   | LOW SYSTEM DEMAND                 |
| LAKWA REPLACEMENT POWER PROJECT | 1       | 9.96          | 25/03/2025 23:06    | 26/03/2025 05:57   | MISC. SHORT DURATION MAINTENANCE  |
| LAKWA REPLACEMENT POWER PROJECT | 1       |               | 26/03/2025 07:39    | 26/03/2025 17:51   | MISCELLANEOUS                     |
| AGARTALA GT                     | 3       | 21.00         | 26/03/2025 00:00    | 26/03/2025 23:59   | Fuel Shortage                     |
| AGARTALA GT                     | 4       | 21.00         | 26/03/2025 00:00    | 26/03/2025 23:59   | MISCELLANEOUS PLANNED MAINTENANCE |
| AGARTALA GT                     | 6       | 25.50         | 26/03/2025 00:00    | 26/03/2025 23:59   | Fuel Shortage                     |
| Total                           |         | 6,697.77      |                     |                    |                                   |