

CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 26-03-2025

Sub-Report - 15

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
TALWANDI SABO TPP	2	660.00	26/03/2025 12:06		AIR PREHEATERS PROBLEM
AURAIYA CCPP	5	109.30	26/03/2025 12:00	26/03/2025	NO/REDUCED IRRIGATION DEMAND
ANPARA TPS	3	210.00	26/03/2025 17:48		ECONOMISER TUBE LEAKAGE
JAWAHARPUR STPP	1	660.00	26/03/2025 16:55		BOILER MISC. PROBLEM
GANDHAR CCPP	1	144.30	26/03/2025 17:45	26/03/2025	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	3	106.00	26/03/2025 17:47		NO/REDUCED IRRIGATION DEMAND
KAWAS CCPP	5	116.10	26/03/2025 12:00	26/03/2025	NO/REDUCED IRRIGATION DEMAND
SANJAY GANDHI TPS	2	210.00	26/03/2025 00:29		SUPER HEATER TUBE LEAKAGE
SASAN UMTTP	3	660.00	26/03/2025 10:42		WATER WALL TUBE LEAKAGE
BHUSAWAL TPS	3	210.00	26/03/2025 04:26		WATER WALL TUBE LEAKAGE
PARAS TPS	4	250.00	26/03/2025 03:57		STATOR/ STATOR EARTH FAULT
RAYALASEEMA TPS	4	210.00	26/03/2025 20:04		WATER WALL TUBE LEAKAGE
JSW Energy Utkal Limited	1	350.00	26/03/2025 16:45	26/03/2025	FURNACE DRAFT ABNORMAL
MEJIA TPS	5	250.00	26/03/2025 18:19		GENERATOR PROTECTION
MEJIA TPS	7	500.00	26/03/2025 16:05		BOILER MISC. PROBLEM
KATHALGURI CCPP	3	33.50	26/03/2025 00:00		LOW SYSTEM DEMAND
KATHALGURI CCPP	6	33.50	26/03/2025 11:18		LOW SYSTEM DEMAND
LAKWA REPLACEMENT POWER PROJECT	1	9.96	26/03/2025 07:39		MISCELLANEOUS
AGARTALA GT	3	21.00	26/03/2025 00:00		Fuel Shortage
AGARTALA GT	4	21.00	26/03/2025 00:00		MISCELLANEOUS PLANNED MAINTENANCE
AGARTALA GT	6	25.50	26/03/2025 00:00		Fuel Shortage
Total		4790.16			