

**CENTRAL ELECTRICITY AUTHORITY  
G O & D WING  
OPERATION PERFORMANCE MONITORING DIVISION**

**RECOMMISSIONING OF THERMAL/NUCLEAR UNITS AS: 26-Jun-2026**

**Sub - Report 14**

| Station                  | Unit No. | Capacity(MW) | Date of Maintanance<br>DD/MM/YYYY HH24:MM | Sync Date<br>DD/MM/YYYY HH24:MM | Reasons/Present Status                  |
|--------------------------|----------|--------------|---|---------------------------------|---|
| 1                        | 2        | 3            | 4   | 5                               | 6                                       |
| ROPAR TPS                | 3        | 210.0        | 6/23/26, 3:00 AM                          | 6/26/26, 8:19 AM                | BOILER MISC. PROBLEM                    |
| FARIDABAD CCPP           | 1        | 137.76       | 6/26/26, 12:51 AM                         | 6/26/26, 8:15 PM                | CONSERVATION OF MAIN FUEL/RSD           |
| FARIDABAD CCPP           | 2        | 137.76       | 6/26/26, 12:59 AM                         | 6/26/26, 9:29 PM                | CONSERVATION OF MAIN FUEL/RSD           |
| SURATGARH TPS            | 3        | 250.0        | 6/24/26, 6:08 PM                          | 6/26/26, 3:45 AM                | MISC. SHORT DURATION MAINTENANCE        |
| ANTA CCPP                | 1        | 88.71        | 6/26/26, 12:35 AM                         | 6/26/26, 8:42 PM                | CONSERVATION OF MAIN FUEL/RSD           |
| ANTA CCPP                | 2        | 88.71        | 6/26/26, 12:36 AM                         | 6/26/26, 8:31 PM                | CONSERVATION OF MAIN FUEL/RSD           |
| ANTA CCPP                | 3        | 88.71        | 6/26/26, 12:36 AM                         | 6/26/26, 8:50 PM                | CONSERVATION OF MAIN FUEL/RSD           |
| SHREE CEMENT LTD TPS     | 3        | 19.0         | 6/26/26, 5:07 AM                          | 6/26/26, 5:06 PM                | RSD/LOW SCHEDULE                        |
| SHREE CEMENT LTD TPS     | 4        | 19.0         | 6/26/26, 5:07 AM                          | 6/26/26, 4:59 PM                | RSD/LOW SCHEDULE                        |
| SHREE CEMENT LTD TPS     | 5        | 6.0          | 6/26/26, 5:00 AM                          | 6/26/26, 5:08 PM                | RSD/LOW SCHEDULE                        |
| PARICHHA TPS             | 5        |              | 6/24/26, 10:45 PM                         | 6/26/26, 1:11 AM                | WATER WALL TUBE LEAKAGE                 |
| PARICHHA TPS             | 5        | 250.0        | 6/26/26, 1:33 AM                          | 6/26/26, 11:50 PM               | TURBINE VIBRATIONS HIGH                 |
| JAWAHARPUR STPP          | 2        | 660.0        | 6/20/26, 1:49 AM                          | 6/26/26, 11:00 AM               | WATER WALL TUBE LEAKAGE                 |
| AURAIYA CCPP             | 1        | 111.19       | 6/26/26, 12:35 AM                         | 6/26/26, 7:53 PM                | CONSERVATION OF MAIN FUEL/RSD           |
| AURAIYA CCPP             | 2        | 111.19       | 6/26/26, 12:33 AM                         | 6/26/26, 8:12 PM                | CONSERVATION OF MAIN FUEL/RSD           |
| AURAIYA CCPP             | 4        | 111.19       | 6/26/26, 12:32 AM                         | 6/26/26, 8:20 PM                | CONSERVATION OF MAIN FUEL/RSD           |
| DADRI CCPP               | 1        | 130.19       | 6/26/26, 12:25 AM                         | 6/26/26, 8:58 PM                | CONSERVATION OF MAIN FUEL/RSD           |
| DADRI CCPP               | 2        | 130.19       | 6/26/26, 12:28 AM                         | 6/26/26, 8:32 PM                | CONSERVATION OF MAIN FUEL/RSD           |
| DADRI CCPP               | 4        | 130.19       | 6/26/26, 12:27 AM                         | 6/26/26, 8:57 PM                | CONSERVATION OF MAIN FUEL/RSD           |
| SABARMATI (D-F STATIONS) | 2        | 121.0        | 6/23/26, 7:19 PM                          | 6/26/26, 3:03 AM                | TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE |
| KAWAS CCPP               | 1        | 106.0        | 6/26/26, 12:20 AM                         | 6/26/26, 7:50 PM                | CONSERVATION OF MAIN FUEL/RSD           |
| KAWAS CCPP               | 2        | 106.0        | 6/26/26, 12:22 AM                         | 6/26/26, 8:16 PM                | CONSERVATION OF MAIN FUEL/RSD           |
| KAWAS CCPP               | 4        | 106.0        | 6/26/26, 12:21 AM                         | 6/26/26, 8:21 PM                | CONSERVATION OF MAIN FUEL/RSD           |
| GANDHAR CCPP             | 1        | 144.3        | 6/26/26, 12:34 AM                         | 6/26/26, 8:14 PM                | CONSERVATION OF MAIN FUEL/RSD           |
| GANDHAR CCPP             | 2        | 144.3        | 6/26/26, 12:41 AM                         | 6/26/26, 8:44 PM                | CONSERVATION OF MAIN FUEL/RSD           |
| GANDHAR CCPP             | 3        | 144.3        | 6/26/26, 12:34 AM                         | 6/26/26, 8:29 PM                | CONSERVATION OF MAIN FUEL/RSD           |
| PARLI TPS                | 6        | 250.0        | 6/25/26, 3:17 AM                          | 6/26/26, 10:14 PM               | DRUM LEVEL LOW                          |
| RAICHUR TPS              | 6        | 210.0        | 6/25/26, 11:59 PM                         | 6/26/26, 6:22 PM                | BOILER AUX. MISC. PROMLEMS              |
| NEYVELI TPS-II           | 1        | 210.0        | 6/25/26, 11:09 PM                         | 6/26/26, 12:55 AM               | TURBINE MISC. PROBLEM                   |

| Station         | Unit No. | Capacity(MW) | Date of Maintanance<br>DD/MM/YYYY HH24:MM | Sync Date<br>DD/MM/YYYY HH24:MM | Reasons/Present Status                  |
|-----------------|----------|--------------|---|---------------------------------|---|
| 1               | 2        | 3            | 4   | 5                               | 6                                       |
| NEYVELI TPS(Z)  | 1        | 250.0        | 6/23/26, 9:29 PM                          | 6/26/26, 9:29 AM                | ASH HANDLING SYSTEM PROBLEM             |
| RAMAGUNDEM STPS | 5        | 500.0        | 6/24/26, 4:43 AM                          | 6/26/26, 1:26 PM                | WATER WALL TUBE LEAKAGE                 |
| BARH STPS       | 1        | 660.0        | 6/23/26, 7:28 AM                          | 6/26/26, 2:50 AM                | TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE |
| MEJIA TPS       | 7        | 500.0        | 6/26/26, 8:10 AM                          | 6/26/26, 12:47 PM               | INSTRUMENTATION PROBLEM                 |
| AGARTALA GT     | 1        | 21.0         | 6/26/26, 12:00 AM                         | 6/26/26, 11:59 PM               | Fuel Shortage                           |
| KATHALGURI CCPP | 1        | 33.5         | 6/26/26, 12:00 AM                         | 6/26/26, 11:59 PM               | R AND M / REFURBISHMENT works           |
| <b>Total</b>    |          | 6186.19      |   |                                 |   |

Note: 1.Actual generation is gross generation from stations above 25 MW. It excludes generation from RES.  
2.Data published in this report is for operational purpose only and not for commercial purpose.  
3.Generation data/Outage data are compiled based on data submitted directly by the utilities."

**Remarks:-**

**Report Version :-**