

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 26-Jun-2026

Sub - Report 15

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
INDIRA GANDHI STPP	3	500.00	6/26/26, 9:59 PM		WATER WALL TUBE LEAKAGE
FARIDABAD CCPP	1	137.76	6/26/26, 12:51 AM	2026-06-26 20:15:00	CONSERVATION OF MAIN FUEL/RSD
FARIDABAD CCPP	2	137.76	6/26/26, 12:59 AM	2026-06-26 21:29:00	CONSERVATION OF MAIN FUEL/RSD
BARSINGSAR LIGNITE	1	125.00	6/26/26, 5:47 AM		BOILER AUX. MISC. PROMLEMS
ANTA CCPP	1	88.71	6/26/26, 12:35 AM	2026-06-26 20:42:00	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	2	88.71	6/26/26, 12:36 AM	2026-06-26 20:31:00	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	3	88.71	6/26/26, 12:36 AM	2026-06-26 20:50:00	CONSERVATION OF MAIN FUEL/RSD
SHREE CEMENT LTD TPS	3	19.00	6/26/26, 5:07 AM	2026-06-26 17:06:00	RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	4	19.00	6/26/26, 5:07 AM	2026-06-26 16:59:00	RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	5	6.00	6/26/26, 5:00 AM	2026-06-26 17:08:00	RSD/LOW SCHEDULE
PARICHHA TPS	5	250.00	6/26/26, 1:33 AM	2026-06-26 23:50:00	TURBINE VIBRATIONS HIGH
AURAIYA CCPP	1	111.19	6/26/26, 12:35 AM	2026-06-26 19:53:00	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	2	111.19	6/26/26, 12:33 AM	2026-06-26 20:12:00	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	4	111.19	6/26/26, 12:32 AM	2026-06-26 20:20:00	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	1	130.19	6/26/26, 12:25 AM	2026-06-26 20:58:00	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	2	130.19	6/26/26, 12:28 AM	2026-06-26 20:32:00	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	4	130.19	6/26/26, 12:27 AM	2026-06-26 20:57:00	CONSERVATION OF MAIN FUEL/RSD
SASAN UMTTP	6	660.00	6/26/26, 1:55 PM		WATER WALL TUBE LEAKAGE
KAWAS CCPP	1	106.00	6/26/26, 12:20 AM	2026-06-26 19:50:00	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	2	106.00	6/26/26, 12:22 AM	2026-06-26 20:16:00	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	4	106.00	6/26/26, 12:21 AM	2026-06-26 20:21:00	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	1	144.30	6/26/26, 12:34 AM	2026-06-26 20:14:00	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	2	144.30	6/26/26, 12:41 AM	2026-06-26 20:44:00	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	3	144.30	6/26/26, 12:34 AM	2026-06-26 20:29:00	CONSERVATION OF MAIN FUEL/RSD
CHANDRAPUR(MAHARASHTRA) STPS	6	500.00	6/26/26, 2:58 PM		FURNACE CLINKER FORMATION
NEYVELI TPS-II EXP	1	250.00	6/26/26, 11:33 AM		I.D. FANS PROBLEM
Dr. N.TATA RAO TPS	8	800.00	6/26/26, 1:18 AM		WATER WALL TUBE LEAKAGE
PAINAMPURAM TPP	2	660.00	6/26/26, 11:05 AM	2026-06-28	BOILER AUX. MISC. PROMLEMS
SIMHADRI	2	500.00	6/26/26, 8:15 AM	2026-06-27	WATER WALL TUBE LEAKAGE

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 26-Jun-2026

Sub - Report 15

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
BARH STPS	2	660.00	6/26/26, 1:34 AM	2026-06-27	OVERHAULING WORKS
BARH STPS	5	660.00	6/26/26, 6:00 PM	2026-06-27	WATER WALL TUBE LEAKAGE
MEJIA TPS	7	500.00	6/26/26, 8:10 AM	2026-06-26 12:47:00	INSTRUMENTATION PROBLEM
KOLAGHAT TPS	6	210.00	6/26/26, 5:10 PM		ECONOMISER TUBE LEAKAGE
NORTH KARANPURA TPP	3	660.00	6/26/26, 9:51 AM	2026-06-27	WATER WALL TUBE LEAKAGE
AGARTALA GT	1	21.00	6/26/26, 12:00 AM	2026-06-26 23:59:59	Fuel Shortage
KATHALGURI CCPP	1	33.50	6/26/26, 12:00 AM	2026-06-26 23:59:59	R AND M / REFURBISHMENT works
Total		9050.19			

Note: 1.Actual generation is gross generation from stations above 25 MW. It excludes generation from RES.
 2.Data published in this report is for operational purpose only and not for commercial purpose.
 3.Generation data/Outage data are compiled based on data submitted directly by the utilities."

Remarks:-

Report Version :-