

**CENTRAL ELECTRICITY AUTHORITY  
G O & D WING  
OPERATION PERFORMANCE MONITORING DIVISION**

**THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 27-06-2024**

Sub-Report - 15

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
ROPAR TPS	3	210.00	27/06/2024 14:28		GENERATOR EARTH FAULT
CHHABRA-II TPP	5	660.00	27/06/2024 12:03	22/07/2024	ANNUAL MAINTENANCE
RAMGARH CCPP	4	37.50	27/06/2024 17:03		TRIPPING OF TRANSMISSION LINE
JALIPA KAPURDI TPP	1	135.00	27/06/2024 22:24		BOILER MISC. PROBLEM
SIPAT STPS	4	500.00	27/06/2024 12:48	27/06/2024	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	1	144.30	27/06/2024 08:38	27/06/2024	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	3	144.30	27/06/2024 08:23	27/06/2024	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	4	224.49	27/06/2024 08:33	27/06/2024	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	2	106.00	27/06/2024 08:32	27/06/2024	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	3	106.00	27/06/2024 00:27	27/06/2024	NO/REDUCED IRRIGATION DEMAND
KAWAS CCPP	4	106.00	27/06/2024 08:39	27/06/2024	NO/REDUCED IRRIGATION DEMAND
KAWAS CCPP	5	116.10	27/06/2024 08:26	27/06/2024	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	6	116.10	27/06/2024 08:33	27/06/2024	CONSERVATION OF MAIN FUEL/RSD
AMARKANTAK EXT TPS	3	210.00	27/06/2024 12:20		ELECTRICAL FAULT
SANJAY GANDHI TPS	3	210.00	27/06/2024 08:55		WATER WALL TUBE LEAKAGE
RATNAGIRI CCPP	5	213.00	27/06/2024 09:45		GT-MISCELLANEOUS PROBLEMS
RATNAGIRI CCPP	6	237.54	27/06/2024 09:41		GT-MISCELLANEOUS PROBLEMS
RATNAGIRI CCPP	8	213.00	27/06/2024 09:25		GT-MISCELLANEOUS PROBLEMS
RATNAGIRI CCPP	9	237.54	27/06/2024 09:15		GT-MISCELLANEOUS PROBLEMS
YERMARUS TPP	2	800.00	27/06/2024 17:52		WATER WALL TUBE LEAKAGE
NEYVELI TPS-II	3	210.00	27/06/2024 23:13		BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	3	210.00	27/06/2024 08:00		RESERVE SHUT DOWN
TUTICORIN TPS	4	210.00	27/06/2024 22:40		FURNACE FIRE OUT /FLAME FAILURE
BHADRADRI TPP	1	270.00	27/06/2024 22:36		WATER WALL TUBE LEAKAGE
TENUGHAT TPS	2	210.00	27/06/2024 21:45		WATER WALL TUBE LEAKAGE
UTKAL TPP (IND BARATH)	1	350.00	27/06/2024 01:30		FURNACE FIRE OUT /FLAME FAILURE
KATHALGURI CCPP	5	33.50	27/06/2024 00:00		Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	4	9.96	27/06/2024 00:45		Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	4		27/06/2024 01:30		GRID DISTURBANCES MISC.
LAKWA REPLACEMENT POWER PROJECT	7	9.96	27/06/2024 06:09		Fuel Shortage
<b>Total</b>		<b>6240.30</b>			