

CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION

RECOMMISSIONNING OF THERMAL/NUCLEAR UNITS AS: 27-Aug-2026

Sub - Report 14

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
SHREE CEMENT LTD TPS	4	19.0	8/27/26, 8:16AM		RSD/LOW SCHEDULE
SIKKA REP. TPS	3	250.0	8/27/26, 10:44AM		P.A. FANS PROBLEM
CHANDRAPUR(MAHARASHTRA) STPS	4	210.0	8/27/26, 7:50PM		ELECTRICAL MISCELLANEOUS PROBLEMS
RAICHUR TPS	5	210.0	8/27/26, 4:04PM		P.A. FANS PROBLEM
TUTICORIN TPS	5	210.0	8/25/26, 11:51AM		BOILER MISC. PROBLEM
METTUR TPS	3	210.0	8/25/26, 1:37PM		ECONOMISER TUBE LEAKAGE
OPG Power Generation Private Limited	1	77.0	8/16/26, 2:15PM		COAL FEEDING PROBLEM IN PLANT
SINGARENI TPP	2	600.0	8/24/26, 9:05PM		FURNACE CLINKER FORMATION
RAMAGUNDEM STPS	4	500.0	8/24/26, 4:31AM		REHEATER TUBE LEAKAGE
Dr. N.TATA RAO TPS	2	210.0	8/25/26, 7:51PM		FURNACE FIRE OUT /FLAME FAILURE
RAYALASEEMA TPS	5	210.0	8/20/26, 2:44AM		ECONOMISER TUBE LEAKAGE
MEENAKSHI ENERGY LTD	3	350.0	8/27/26, 5:09AM		ELECTRICAL MISCELLANEOUS PROBLEMS
FARAKKA STPS	5	500.0	8/27/26, 3:51PM		BOILER FEED PUMP/MOTOR PROBLEM
JSW Energy Utkal Limited	1	350.0	8/25/26, 3:24AM		A.V.R. PROBLEM
JSW Energy Utkal Limited	2	350.0	8/27/26, 1:21AM		P.A. FANS PROBLEM
AGARTALA GT	1	21.0	8/27/26, 12:00AM		Fuel Shortage
AGARTALA GT	2	21.0	8/27/26, 12:00AM		MINOR MAINTENANCE WORKS
AGARTALA GT	3	21.0	8/27/26, 12:00AM		Fuel Shortage
AGARTALA GT	5	25.5	8/27/26, 12:00AM		Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	3	9.965	8/27/26, 1:03AM		GRID DISTURBENCE
LAKWA REPLACEMENT POWER PROJECT	5	9.965	8/27/26, 7:59AM		GRID DISTURBENCE
LAKWA REPLACEMENT POWER PROJECT	6	9.965	8/27/26, 12:42PM		GRID DISTURBENCE
KATHALGURI CCPP	4	33.5	8/27/26, 12:00AM		Low system demand/ costly fuel
KATHALGURI CCPP	8	30.0	8/27/26, 12:00AM		MISCELLANEOUS PLANNED MAINTENANCE

Total	4437.90			
-------	---------	--	--	--

Remarks:-

Report Version :-