

CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 27-Aug-2026

Sub - Report 15

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
GH TPS (LEH.MOH.)	2	210.00	8/27/26, 7:35PM		ELECTRICAL MISCELLANEOUS PROBLEMS
KALISINDH TPS	1	600.00	8/27/26, 4:33PM		FURNACE DRAFT ABNORMAL
SHREE CEMENT LTD TPS	3	19.00	8/27/26, 8:06AM	2026-08-28	RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	4	19.00	8/27/26, 8:16AM	2026-08-27 17:26:00	RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	5	6.00	8/27/26, 8:00AM	2026-08-28	RSD/LOW SCHEDULE
NIGRI TPP	1	660.00	8/27/26, 4:15AM	2026-09-01	ECONOMISER TUBE LEAKAGE
VINDHYACHAL STPS	7	500.00	8/27/26, 7:01PM	2026-08-27	GENERATOR PROTECTION
SIKKA REP. TPS	3	250.00	8/27/26, 10:44AM	2026-08-27 12:49:00	P.A. FANS PROBLEM
MUNDRA UMTTP	1	800.00	8/27/26, 1:43AM		TURBINE MISC. PROBLEM
CHANDRAPUR(MAHARASHTRA) STPS	4	210.00	8/27/26, 7:50PM	2026-08-27 21:36:00	ELECTRICAL MISCELLANEOUS PROBLEMS
RATNAGIRI CCPP	4	213.00	8/27/26, 1:08AM		GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	5	213.00	8/27/26, 2:27AM		GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	6	237.54	8/27/26, 2:21AM		GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	7	213.00	8/27/26, 1:36AM		GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	8	213.00	8/27/26, 12:45AM		GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	9	237.54	8/27/26, 1:28AM		GT- LOW SYSTEM DAMAND
ADANI POWER LIMITED TIRODA TPP	5	660.00	8/27/26, 11:16PM		AIR PREHEATERS PROBLEM
RAICHUR TPS	5	210.00	8/27/26, 4:04PM	2026-08-27 18:59:00	P.A. FANS PROBLEM
TUTICORIN TPS	3	210.00	8/27/26, 11:55AM		WATER WALL TUBE LEAKAGE
NORTH CHENNAI TPS STAGE 2	4	600.00	8/27/26, 1:07PM		WATER WALL TUBE LEAKAGE
BHADRADRI TPP	2	270.00	8/27/26, 11:22AM		WATER WALL TUBE LEAKAGE
YADADRI TPS	3	800.00	8/27/26, 3:41PM		FURNACE FIRE OUT /FLAME FAILURE
MEENAKSHI ENERGY LTD	3	350.00	8/27/26, 5:09AM	2026-08-27 12:57:00	ELECTRICAL MISCELLANEOUS PROBLEMS
FARAKKA STPS	5	500.00	8/27/26, 3:51PM	2026-08-27 23:26:00	BOILER FEED PUMP/MOTOR PROBLEM
JSW Energy Utkal Limited	2	350.00	8/27/26, 1:21AM	2026-08-27 17:10:00	P.A. FANS PROBLEM
AGARTALA GT	1	21.00	8/27/26, 12:00AM	2026-08-27 23:59:59	Fuel Shortage
AGARTALA GT	2	21.00	8/27/26, 12:00AM	2026-08-27 23:59:59	MINOR MAINTENANCE WORKS
AGARTALA GT	3	21.00	8/27/26, 12:00AM	2026-08-27 23:59:59	Fuel Shortage
AGARTALA GT	5	25.50	8/27/26, 12:00AM	2026-08-27 23:59:59	Fuel Shortage

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
NAMRUP CCPP	8	36.15	8/27/26, 9:32AM		BOILER MISC. PROBLEM
LAKWA REPLACEMENT POWER PROJECT	3	9.96	8/27/26, 1:03AM	2026-08-27 06:04:00	GRID DISTURBENCE
LAKWA REPLACEMENT POWER PROJECT	5	9.96	8/27/26, 7:59AM	2026-08-27 12:31:00	GRID DISTURBENCE
LAKWA REPLACEMENT POWER PROJECT	6	9.96	8/27/26, 12:42PM	2026-08-27 18:57:00	GRID DISTURBENCE
KATHALGURI CCPP	4	33.50	8/27/26, 12:00AM	2026-08-27 23:59:59	Low system demand/ costly fuel
KATHALGURI CCPP	8	30.00	8/27/26, 12:00AM	2026-08-27 23:59:59	MISCELLANEOUS PLANNED MAINTENANCE
Total		8769.12			

Remarks:-

Report Version :-