

CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION

THERMAL/NUCLEAR UNITS OUT OF GRID FOR MORE THAN 15 DAYS DURING 2025-26 as on: 27-Nov-2025

Sub - Report 12

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
PRAGATI CCPP	1		7/28/25, 4:31PM	28-07-2025	MISCELLANOUS
PRAGATI CCPP	1		7/17/25, 10:45PM	25-07-2025	Low system demand/ costly fuel
PRAGATI CCPP	1	104.60	6/29/25, 4:39AM	29-06-2025	GRID DISTURBENCE
PRAGATI CCPP	1		5/25/25, 2:19PM	25-05-2025	LOW SYSTEM DEMAND
PRAGATI CCPP	1		5/19/25, 4:49PM	20-05-2025	MINOR MAINTENANCE WORKS
PRAGATI CCPP	1		9/30/25, 12:32PM		LOW SYSTEM DEMAND
PRAGATI CCPP	1		5/25/25, 7:15PM	25-05-2025	MISCELLANOUS
PRAGATI CCPP	1		7/25/25, 10:15AM	26-07-2025	GT- LUB OIL SYSTEM PROB.
PRAGATI CCPP	1		7/9/25, 5:36PM	09-07-2025	GRID DISTURBENCE
PRAGATI CCPP	2		5/21/25, 8:21PM	21-05-2025	GRID DISTURBENCE
PRAGATI CCPP	2		5/24/25, 2:00AM	24-05-2025	Cooling Water System Abnormal/ Maintenance
PRAGATI CCPP	2	104.60	5/22/25, 6:08PM	22-05-2025	Cooling Water System Abnormal/ Maintenance
PRAGATI CCPP	2		6/15/25, 3:53AM	15-06-2025	GRID DISTURBENCE
PRAGATI CCPP	2		5/2/25, 11:00AM	02-05-2025	Electrical Scheduled Maitenance
PRAGATI CCPP	2		5/2/25, 5:22AM	02-05-2025	GRID DISTURBENCE
PRAGATI CCPP	3	121.20	5/2/25, 6:22AM	02-05-2025	GRID DISTURBENCE
PRAGATI CCPP	3		1/13/25, 11:00AM	22-01-2025	CONDENSER TUBE LEAKAGE/ CLEANING
PRAGATI CCPP	3		5/2/25, 11:00AM		Electrical Scheduled Maitenance
PANIPAT TPS	6	210.00	10/20/25, 12:33AM		RESERVE SHUT DOWN / STANDBY UNIT
PANIPAT TPS	8	250.00	11/10/25, 6:15PM	13-11-2025	TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE
RAJIV GANDHI TPS	1	600.00	10/9/25, 11:06AM		RESERVE SHUT DOWN / STANDBY UNIT
RAJIV GANDHI TPS	2	600.00	10/6/25, 10:33PM		Turbine Misc
INDIRA GANDHI STPP	1	500.00	5/2/25, 5:14AM		GENERATOR PROTECTION
INDIRA GANDHI STPP	1		8/9/25, 12:01AM		GENERATOR PROTECTION RELAY OPERATION PROBLEM
INDIRA GANDHI STPP	1		8/31/25, 1:34PM		GENERATOR PROTECTION RELAY OPERATION PROBLEM
INDIRA GANDHI STPP	1		5/2/25, 5:45PM		GOVERNING SYSTEM PROBLEM
INDIRA GANDHI STPP	2	500.00	10/31/25, 11:00PM		ANNUAL MAINTENANCE
MAHATMA GANDHI TPS	1	660.00	10/28/25, 12:01PM		ANNUAL MAINTENANCE
MAHATMA GANDHI TPS	2	660.00	10/16/25, 11:52PM		WATER WALL TUBE LEAKAGE

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
FARIDABAD CCPP	1	137.76	9/9/25, 11:33PM	09-09-2025	CONSERVATION OF MAIN FUEL/RSD
FARIDABAD CCPP	2	137.76	9/9/25, 11:32PM	09-09-2025	CONSERVATION OF MAIN FUEL/RSD
FARIDABAD CCPP	3	156.07	7/23/25, 10:38PM	20-08-2025	CONSERVATION OF MAIN FUEL/RSD
GH TPS (LEH.MOH.)	1	210.00	3/21/25, 3:58PM	01-04-2025	STATOR EARTH FAULT
GH TPS (LEH.MOH.)	2	210.00	8/25/25, 1:31PM	29-08-2025	INSPECTION /MTCE
GH TPS (LEH.MOH.)	2		8/29/25, 8:37AM	31-08-2025	GT-TURBINE BEARING PROBLEM
GH TPS (LEH.MOH.)	2		8/31/25, 11:00AM	08-09-2025	LOW SYSTEM DEMAND
GH TPS (LEH.MOH.)	4	250.00	5/7/25, 10:55PM	10-05-2025	MISC. SHORT DURATION MAINTENANCE
ROPAR TPS	3	210.00	8/25/25, 9:37AM		FURNACE DRAFT ABNORMAL
ROPAR TPS	3		8/16/25, 10:36PM		FUEL SUPPLY & OTHER MISC. PROBLEMS
ROPAR TPS	4		8/10/25, 9:22AM		FURNACE DRAFT ABNORMAL
ROPAR TPS	4		10/17/25, 10:35AM		FURNACE DRAFT ABNORMAL
ROPAR TPS	4	210.00	6/18/25, 12:09AM		WATER WALL TUBE LEAKAGE
ROPAR TPS	5	210.00	10/17/25, 3:22PM		REHEATER TUBE LEAKAGE
ROPAR TPS	5		8/16/25, 9:25AM		FUEL SUPPLY & OTHER MISC. PROBLEMS
ROPAR TPS	6		8/27/25, 2:48PM		AIR PREHEATERS PROBLEM
ROPAR TPS	6	210.00	8/28/25, 8:30PM		RSD/LOW SCHEDULE
ROPAR TPS	6		1/15/25, 6:52AM		GENEARTOR MISC.
ROPAR TPS	6		8/10/25, 7:25AM		REHEATER TUBE LEAKAGE
ROPAR TPS	6		10/13/25, 4:37PM		BOILER MISC. PROBLEM
KOTA TPS	2	110.00	10/28/25, 5:55AM		BOILER AUX. MISC. PROMLEMS
RAJASTHAN A.P.S.	7	700.00	10/4/25, 4:34PM	01-12-2025	TURBINE VIBRATION HIGH
SURATGARH TPS	2	250.00	12/2/24, 7:32PM		WATER WALL TUBE LEAKAGE
SURATGARH TPS	6		6/2/25, 7:48AM		RSD/LOW SCHEDULE
SURATGARH TPS	6	250.00	7/25/25, 12:09PM		TURBINE VIBRATION HIGH
CHHABRA-I PH-2 TPP	4	250.00	10/24/25, 2:00AM		ANNUAL MAINTENANCE
RAMGARH CCPP	1	3.00	5/9/25, 4:07PM		Fuel Shortage
DHOLPUR CCPP	1	110.00	8/21/25, 11:56PM		MISCELLANOUS
DHOLPUR CCPP	2	110.00	8/21/25, 11:56PM		MISCELLANOUS
ANTA CCPP	1	88.71	8/26/25, 12:00AM	26-08-2025	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	1		5/3/25, 4:09AM	03-05-2025	NO Power purchase agreement

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
ANTA CCPP	2		3/12/25, 11:14PM	16-03-2025	NO/REDUCED IRRIGATION DEMAND
ANTA CCPP	2	88.71	2/19/25, 7:30AM	20-02-2025	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	2		2/18/25, 11:36AM	19-02-2025	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	2		8/26/25, 12:00AM	26-08-2025	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	3	88.71	8/26/25, 12:00AM	26-08-2025	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	4	153.20	9/17/25, 12:23AM	18-09-2025	CONSERVATION OF MAIN FUEL/RSD
SHREE CEMENT LTD TPS	1	150.00	11/1/25, 12:00AM	20-12-2025	ANNUAL MAINTENANCE
SHREE CEMENT LTD TPS	2	150.00	11/1/25, 12:00AM	22-11-2025	ANNUAL MAINTENANCE
HARDUAGANJ TPS	7	105.00	10/3/25, 11:17PM		RESERVE SHUT DOWN / STANDBY UNIT
HARDUAGANJ TPS	8		1/10/25, 7:50PM		WATER WALL TUBE LEAKAGE
HARDUAGANJ TPS	8	250.00	10/3/25, 11:15PM		RESERVE SHUT DOWN / STANDBY UNIT
HARDUAGANJ TPS	9	250.00	10/3/25, 11:13PM		RESERVE SHUT DOWN / STANDBY UNIT
ANPARA TPS	7	500.00	10/31/25, 1:00AM		OVERHAULING WORKS
JAWAHARPUR STPP	1	660.00	10/7/25, 1:19AM		RESERVE SHUT DOWN / STANDBY UNIT
JAWAHARPUR STPP	2	660.00	10/7/25, 12:58AM		RESERVE SHUT DOWN / STANDBY UNIT
PANKI TPS EXT	1	660.00	7/9/25, 3:30PM		ELECTRICAL MISCELLANEOUS PROBLEMS
ANPARA C TPS	1	600.00	11/9/25, 12:24AM		BOILER OVERHAUL/ ANNUAL MAINTENANCE
RIHAND STPS	4	500.00	10/29/25, 11:54PM	27-11-2025	OVERHAULING WORKS
DADRI (NCTPP)	2	210.00	6/18/25, 11:47AM		RSD/LOW SCHEDULE
DADRI (NCTPP)	5	490.00	5/23/25, 11:35AM	25-05-2025	BOILER AUX. MISC. PROMLEMS
TANDA TPS	1	110.00	6/30/25, 11:05PM	04-09-2025	CONSERVATION OF MAIN FUEL/RSD
TANDA TPS	2	110.00	6/30/25, 11:17PM	04-09-2025	CONSERVATION OF MAIN FUEL/RSD
TANDA TPS	3	110.00	8/31/25, 11:58PM	04-09-2025	CONSERVATION OF MAIN FUEL/RSD
TANDA TPS	4	110.00	8/31/25, 11:58PM		RESERVE SHUT DOWN / STANDBY UNIT
TANDA TPS	4		3/27/25, 2:55AM	28-03-2025	BOILER AUX. MISC. PROMLEMS
AURAIYA CCPP	2		3/25/25, 12:00AM	27-03-2025	NO/REDUCED IRRIGATION DEMAND
AURAIYA CCPP	2	111.19	3/12/25, 11:13PM	25-03-2025	NO/REDUCED IRRIGATION DEMAND
AURAIYA CCPP	3		1/6/25, 6:00AM	07-01-2025	NO/REDUCED IRRIGATION DEMAND
AURAIYA CCPP	3	111.19	1/3/25, 9:28AM	06-01-2025	NO/REDUCED IRRIGATION DEMAND
AURAIYA CCPP	4		1/14/25, 9:50AM	07-02-2025	NO/REDUCED IRRIGATION DEMAND
AURAIYA CCPP	4	111.19	9/8/25, 11:40PM	08-09-2025	CONSERVATION OF MAIN FUEL/RSD

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
AURAIYA CCPP	5		3/24/25, 12:00PM	25-03-2025	NO/REDUCED IRRIGATION DEMAND
AURAIYA CCPP	5		3/25/25, 12:00PM	26-03-2025	NO/REDUCED IRRIGATION DEMAND
AURAIYA CCPP	5		9/20/25, 10:33PM	27-11-2025	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	5	109.30	12/18/24, 9:05AM	24-03-2025	NO/REDUCED IRRIGATION DEMAND
AURAIYA CCPP	6	109.30	1/25/25, 12:00PM	25-01-2025	NO/REDUCED IRRIGATION DEMAND
AURAIYA CCPP	6		2/4/25, 12:00PM	07-02-2025	NO/REDUCED IRRIGATION DEMAND
AURAIYA CCPP	6		1/24/25, 12:00PM	25-01-2025	NO/REDUCED IRRIGATION DEMAND
AURAIYA CCPP	6		2/2/25, 12:00PM	03-02-2025	NO/REDUCED IRRIGATION DEMAND
AURAIYA CCPP	6		12/18/24, 9:02AM	24-01-2025	NO/REDUCED IRRIGATION DEMAND
AURAIYA CCPP	6		9/20/25, 10:44PM	27-11-2025	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	6		2/3/25, 12:00PM	04-02-2025	NO/REDUCED IRRIGATION DEMAND
AURAIYA CCPP	6		1/31/25, 12:00PM	01-02-2025	NO/REDUCED IRRIGATION DEMAND
DADRI CCPP	2		10/13/25, 7:49PM	13-10-2025	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	2		2/25/25, 12:16PM	26-02-2025	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	2	130.19	7/9/25, 12:43AM		CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	2		4/13/25, 8:19AM	14-04-2025	GENERATOR TRANSFORMER
DADRI CCPP	3		8/25/25, 8:51PM	27-08-2025	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	3		2/10/25, 9:59AM	11-02-2025	NO/REDUCED IRRIGATION DEMAND
DADRI CCPP	3	130.19	12/7/24, 7:58AM	07-12-2024	NO/REDUCED IRRIGATION DEMAND
DADRI CCPP	3		12/16/24, 8:00AM	21-12-2024	NO/REDUCED IRRIGATION DEMAND
DADRI CCPP	4	130.19	12/25/24, 6:12PM	02-01-2025	NO/REDUCED IRRIGATION DEMAND
DADRI CCPP	4		3/5/25, 7:56PM	07-03-2025	NO/REDUCED IRRIGATION DEMAND
DADRI CCPP	5		7/23/25, 10:29PM	21-08-2025	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	5	154.51	12/18/24, 8:23AM	26-02-2025	NO/REDUCED IRRIGATION DEMAND
DADRI CCPP	6	154.51	7/5/25, 12:39AM	21-07-2025	CONSERVATION OF MAIN FUEL/RSD
BARKHERA TPS	1	45.00	12/6/24, 7:30PM		BOILER MISC. PROBLEM
KUNDARKI TPS	1	45.00	10/11/25, 11:41PM		RSD/LOW SCHEDULE
UTRAULA TPS	1	45.00	10/11/25, 11:43PM		RESERVE SHUT DOWN / STANDBY UNIT
UKAI TPS	3		2/22/25, 7:45AM		WATER WALL TUBE LEAKAGE
UKAI TPS	3	200.00	6/26/25, 1:57PM		TURBINE MISC.
UKAI TPS	4	200.00	12/22/24, 5:45PM		WATER WALL TUBE LEAKAGE

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
UKAI TPS	5	210.00	2/3/25, 6:38PM		WATER WALL TUBE LEAKAGE
GANDHI NAGAR TPS	3		1/8/25, 12:00AM		SCHEDULED ANNUAL MAINTENANCE
GANDHI NAGAR TPS	3	210.00	7/23/25, 11:28AM		RAW WATER SUPPLY MISC.
GANDHI NAGAR TPS	4	210.00	7/23/25, 11:53AM		RAW WATER SUPPLY MISC.
GANDHI NAGAR TPS	5	210.00	3/7/25, 5:17PM		WATER WALL TUBE LEAKAGE
UTRAN CCPP	5	240.00	2/10/25, 8:28PM		RESERVE SHUT DOWN
UTRAN CCPP	5		5/17/25, 10:43PM		RESERVE SHUT DOWN / STANDBY UNIT
UTRAN CCPP	5		5/19/25, 8:00AM		MISC. SHORT DURATION PLANNED MAINTENACE
UTRAN CCPP	6		5/17/25, 10:40PM		RESERVE SHUT DOWN / STANDBY UNIT
UTRAN CCPP	6	134.00	5/19/25, 8:00AM		MISC. SHORT DURATION PLANNED MAINTENACE
UTRAN CCPP	6		2/10/25, 8:25PM		RESERVE SHUT DOWN / STANDBY UNIT
HAZIRA CCPP EXT	1	351.00	6/15/25, 1:22AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	3		4/17/25, 11:59PM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	3		4/18/25, 11:59PM		RESERVE SHUT DOWN/ STANDBY.
DHUVARAN CCPP	3		8/26/25, 10:19PM		RESERVE SHUT DOWN/ STANDBY.
DHUVARAN CCPP	3		4/4/25, 12:00AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	3		4/1/25, 12:00AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	3		4/2/25, 12:00AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	3		3/20/25, 3:06PM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	3		4/3/25, 12:00AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	3	72.00	4/8/25, 12:00AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	3		4/17/25, 12:00AM		RESERVE SHUT DOWN/ STANDBY.
DHUVARAN CCPP	3		4/18/25, 12:00AM		RESERVE SHUT DOWN/ STANDBY.
DHUVARAN CCPP	4		2/28/25, 12:00AM		RESERVE SHUT DOWN/ STANDBY.
DHUVARAN CCPP	4		4/18/25, 11:59PM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	4		4/1/25, 12:00AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	4	40.00	4/25/25, 7:26PM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	4		4/17/25, 11:59PM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	4		4/8/25, 12:00AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	4		8/26/25, 10:18PM		RESERVE SHUT DOWN/ STANDBY.
DHUVARAN CCPP	4		2/7/25, 12:00AM		RESERVE SHUT DOWN / STANDBY UNIT

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
DHUVARAN CCPP	4		4/3/25, 12:00AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	4		4/4/25, 12:00AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	4		4/2/25, 12:00AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	4		3/20/25, 1:45PM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	5		12/16/24, 7:00PM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	5		2/4/25, 12:00AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	5		3/20/25, 12:00AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	5		4/2/25, 12:00AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	5		9/11/25, 7:20PM		RESERVE SHUT DOWN
DHUVARAN CCPP	5		8/12/25, 12:00AM		RESERVE SHUT DOWN/ STANDBY.
DHUVARAN CCPP	5		4/1/25, 12:00AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	5		5/9/25, 12:00AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	5		4/17/25, 11:59PM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	5		4/18/25, 12:00AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	5		4/18/25, 11:00AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	5		4/3/25, 12:00AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	5		4/18/25, 11:59PM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	5		4/4/25, 12:00AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	5		4/8/25, 12:00AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	5	376.10	4/17/25, 12:00AM		RESERVE SHUT DOWN/ STANDBY.
WANAKBORI TPS	3	210.00	5/29/25, 1:33PM		TURBINE MISC. PROBLEM
WANAKBORI TPS	3		12/14/24, 8:13PM		RSD/LOW SCHEDULE
WANAKBORI TPS	4	210.00	4/8/25, 10:33PM		WATER WALL TUBE LEAKAGE
WANAKBORI TPS	5	210.00	5/25/25, 2:09PM		TURBINE BEARING PROBLEM
KUTCH LIG. TPS	3	75.00	7/29/25, 10:06AM		WATER WALL TUBE LEAKAGE
SUGEN CCPP	2	382.50	7/27/25, 12:00AM		RSD/LOW SCHEDULE
SUGEN CCPP	3	382.50	10/17/25, 10:46AM	27-10-2025	RSD/LOW SCHEDULE
UNOSUGEN CCPP	1	382.50	10/1/25, 12:00AM	10-10-2025	RSD/LOW SCHEDULE
DGEN MEGA CCPP	1	400.00	1/3/25, 12:06AM	01-04-2025	GT-NO SCHEDULE FROM BENIFICIARIES
DGEN MEGA CCPP	2	400.00	1/3/25, 12:09AM	01-04-2025	GT-NO SCHEDULE FROM BENIFICIARIES
DGEN MEGA CCPP	3	400.00	1/2/25, 12:00AM		GT-NO SCHEDULE FROM BENIFICIARIES

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
DGEN MEGA CCPP	3		1/3/25, 12:10AM	01-04-2025	GT-NO SCHEDULE FROM BENIFICIARIES
SABARMATI (D-F STATIONS)	3	121.00	11/11/25, 12:01AM		BOILER OVERHAUL/ ANNUAL MAINTENANCE
SURAT LIG. TPS	2	125.00	7/28/25, 4:27AM		WATER WALL TUBE LEAKAGE
ADANI POWER LIMITED MUNDRA TPP - III	9	660.00	11/1/25, 5:20AM		WATER WALL TUBE LEAKAGE
MUNDRA UMTPP	1	800.00	7/3/25, 11:54AM		AIR PREHEATERS PROBLEM
MUNDRA UMTPP	2	800.00	7/2/25, 10:59PM		F.D. FANS PROBLEM
MUNDRA UMTPP	3	800.00	7/2/25, 12:22AM		TURBINE CONTROL VALVE PROBLEM
MUNDRA UMTPP	4	800.00	7/1/25, 8:55AM		COOLING WATER SYSTEM PROBLEM/PIPES REPLACE
MUNDRA UMTPP	5	800.00	7/2/25, 8:55AM		TURBINE MISC. PROBLEMS
KAWAS CCPP	1	106.00	10/11/25, 7:20PM	12-10-2025	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	2	106.00	9/21/25, 12:30AM	21-09-2025	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	3	106.00	8/25/25, 11:57PM	27-08-2025	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	3		6/4/25, 11:35PM	05-06-2025	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	4		9/23/25, 7:44PM	24-09-2025	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	4		11/28/24, 7:58AM	02-12-2024	NO/REDUCED IRRIGATION DEMAND
KAWAS CCPP	4	106.00	3/25/25, 5:42PM	27-03-2025	NO/REDUCED IRRIGATION DEMAND
KAWAS CCPP	4		12/2/24, 10:00AM	04-12-2024	GT/WHRB/ST PLANNED OVERHAUL
KAWAS CCPP	4		3/27/25, 11:00PM	27-03-2025	NO/REDUCED IRRIGATION DEMAND
KAWAS CCPP	5		3/23/25, 12:00PM	24-03-2025	NO/REDUCED IRRIGATION DEMAND
KAWAS CCPP	5		3/24/25, 12:00PM	25-03-2025	NO/REDUCED IRRIGATION DEMAND
KAWAS CCPP	5		3/17/25, 8:23PM	21-03-2025	NO/REDUCED IRRIGATION DEMAND
KAWAS CCPP	5		3/13/25, 12:00PM	14-03-2025	NO/REDUCED IRRIGATION DEMAND
KAWAS CCPP	5		3/22/25, 12:00PM	23-03-2025	NO/REDUCED IRRIGATION DEMAND
KAWAS CCPP	5	116.10	2/26/25, 12:00PM	28-02-2025	GT/WHRB/ST PLANNED OVERHAUL
KAWAS CCPP	5		3/2/25, 12:00AM	03-03-2025	NO/REDUCED IRRIGATION DEMAND
KAWAS CCPP	5		3/21/25, 12:00PM	22-03-2025	NO/REDUCED IRRIGATION DEMAND
KAWAS CCPP	5		3/7/25, 12:00PM	12-03-2025	NO/REDUCED IRRIGATION DEMAND
KAWAS CCPP	5		3/12/25, 12:00AM	13-03-2025	NO/REDUCED IRRIGATION DEMAND
KAWAS CCPP	5		3/25/25, 12:00PM	26-03-2025	NO/REDUCED IRRIGATION DEMAND
KAWAS CCPP	5		12/18/24, 10:00AM	20-12-2024	NO/REDUCED IRRIGATION DEMAND
KAWAS CCPP	5		9/21/25, 12:32AM	21-09-2025	CONSERVATION OF MAIN FUEL/RSD

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
KAWAS CCPP	5		12/20/24, 5:30AM	26-02-2025	NO/REDUCED IRRIGATION DEMAND
KAWAS CCPP	6		4/21/25, 11:12PM	22-04-2025	NO/REDUCED IRRIGATION DEMAND
KAWAS CCPP	6	116.10	12/2/24, 10:00AM	04-12-2024	GT/WHRB/ST PLANNED OVERHAUL
KAWAS CCPP	6		5/17/25, 7:37PM	05-06-2025	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	6		7/25/25, 5:15PM	07-08-2025	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	1		3/22/25, 11:55PM	22-03-2025	NO/REDUCED IRRIGATION DEMAND
GANDHAR CCPP	1		8/26/25, 12:00AM	26-08-2025	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	1	144.30	3/21/25, 8:23PM	22-03-2025	NO/REDUCED IRRIGATION DEMAND
GANDHAR CCPP	2	144.30	1/20/25, 9:29AM	05-02-2025	NO/REDUCED IRRIGATION DEMAND
GANDHAR CCPP	4		9/13/25, 11:11PM	14-09-2025	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	4		12/18/24, 9:03AM	03-01-2025	NO/REDUCED IRRIGATION DEMAND
GANDHAR CCPP	4		4/27/25, 12:55AM	30-05-2025	NO/REDUCED IRRIGATION DEMAND
GANDHAR CCPP	4	224.49	4/21/25, 7:40PM	27-04-2025	NO/REDUCED IRRIGATION DEMAND
KAKRAPARA	1		3/14/25, 6:39AM	15-03-2025	Turbine Misc
KAKRAPARA	1	220.00	3/13/25, 6:39AM	14-03-2025	Miscellaneous
KORBA-WEST TPS	4	210.00	10/14/25, 11:53PM		CAPITAL MAINTENANCE
SEIONI TPP	1	600.00	5/6/25, 6:38PM		ELECTRICAL MISCELLANEOUS PROBLEMS
KORBA STPS	2	200.00	4/15/25, 11:59PM	16-04-2025	BOILER OVERHAUL/ ANNUAL MAINTENANCE
KORBA STPS	2		4/16/25, 12:00AM	24-04-2025	BOILER OVERHAUL/ ANNUAL MAINTENANCE
GADARWARA TPP	2	800.00	4/10/25, 10:59PM	11-04-2025	GENERATOR INSPECTION/TESTING/MTCE
RATIJA TPS	1	50.00	5/10/25, 11:59AM	12-05-2025	BOILER MISC. PROBLEM
RATIJA TPS	1		5/9/25, 12:00AM		BOILER AUX. MISC. PROMLEMS
ADANI POWER LIMITED RAIPUR TPP	1	685.00	10/20/25, 2:02AM		P.A. FANS PROBLEM
BALCO TPS	2	300.00	11/9/25, 12:08AM		GENERATOR MISCLLANEOUS MAINTENANCE
AKALTARA TPS	2	600.00	10/11/25, 10:44PM		
BARADARHA TPS	2	600.00	11/5/25, 12:11AM		BOILER OVERHAUL/ ANNUAL MAINTENANCE
TAMNAR TPP	4	600.00	11/1/25, 4:10AM		ANNUAL MAINTENANCE
UCHPINDA TPP	3	360.00	11/2/25, 10:38PM		BOILER MISC. PROBLEM
SOLAPUR STPS	2	660.00	6/22/25, 1:16AM		CONSERVATION OF MAIN FUEL/RSD
BHUSAWAL TPS	3	210.00	10/1/25, 12:05AM		RESERVE SHUT DOWN / STANDBY UNIT
BHUSAWAL TPS	4	500.00	10/20/25, 9:01PM		RESERVE SHUT DOWN / STANDBY UNIT

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
BHUSAWAL TPS	5	500.00	10/1/25, 10:00PM		RSD/LOW SCHEDULE
PARLI TPS	6	250.00	10/20/25, 9:45PM		RSD/LOW SCHEDULE
PARLI TPS	7		10/20/25, 9:45PM		RSD/LOW SCHEDULE
PARLI TPS	7	250.00	10/27/25, 9:45PM		RSD/LOW SCHEDULE
PARLI TPS	8	250.00	9/29/25, 1:00PM		BOILER OVERHAUL/ ANNUAL MAINTENANCE
CHANDRAPUR(MAHARASHTRA) STPS	3	210.00	11/7/25, 10:32PM		WATER WALL TUBE LEAKAGE
CHANDRAPUR(MAHARASHTRA) STPS	4	210.00	11/3/25, 11:59PM		RESERVE SHUT DOWN / STANDBY UNIT
CHANDRAPUR(MAHARASHTRA) STPS	5	500.00	10/21/25, 5:15AM		RESERVE SHUT DOWN / STANDBY UNIT
URAN CCPP	5		12/21/24, 12:00AM	22-12-2024	RESERVE SHUT DOWN/ STANDBY.
URAN CCPP	5		8/7/25, 12:00AM	08-08-2025	FUEL SUPPLY & OTHER MISC. PROBLEMS
URAN CCPP	5	108.00	12/19/24, 6:58PM	20-12-2024	RESERVE SHUT DOWN / STANDBY UNIT
URAN CCPP	5		12/23/24, 12:00AM	24-12-2024	RESERVE SHUT DOWN/ STANDBY.
URAN CCPP	5		5/2/25, 12:32AM		BEARING
URAN CCPP	5		2/19/25, 7:29AM		TURBINE VIBRATIONS HIGH
URAN CCPP	6		2/14/25, 8:00AM		RESERVE SHUT DOWN / STANDBY UNIT
URAN CCPP	6		4/13/25, 7:59PM		TRANSMISSION CONSTRAINTS
URAN CCPP	6	108.00	7/1/25, 5:28PM	07-08-2025	Fuel Shortage
URAN CCPP	9	120.00	6/19/25, 12:00AM	04-08-2025	Fuel Shortage
TARAPUR	3	540.00	11/4/25, 10:00PM	13-01-2026	ANNUAL MAINTENANCE
KOTHAGUDEM TPS (NEW)	9	250.00	9/29/25, 9:47PM		ECONOMISER TUBE LEAKAGE
DAMODARAM SANJEEVAIAH TPS	1	800.00	11/1/25, 2:34AM		ANNUAL MAINTENANCE
SINGARENI TPP	1	600.00	5/24/25, 2:34AM	24-05-2025	WATER WALL TUBE LEAKAGE
RAYALASEEMA TPS	2		4/10/25, 8:21PM		REHEATER TUBE LEAKAGE
RAYALASEEMA TPS	2	210.00	7/22/25, 7:05PM		WATER WALL TUBE LEAKAGE
RAYALASEEMA TPS	2		8/26/25, 1:12PM		WATER WALL TUBE LEAKAGE
RAYALASEEMA TPS	3	210.00	8/27/25, 2:57PM		RESERVE SHUT DOWN / STANDBY UNIT
RAYALASEEMA TPS	3		8/31/25, 2:00PM		ECONOMISER TUBE LEAKAGE
RAYALASEEMA TPS	4	210.00	8/12/25, 4:49AM		ECONOMISER TUBE LEAKAGE
RAYALASEEMA TPS	5	210.00	10/1/25, 9:35AM		TURBINE VIBRATIONS HIGH
SIMHAPURI TPS	3		10/19/25, 12:06AM		P.A. FANS PROBLEM
SIMHAPURI TPS	3	150.00	10/23/25, 12:00AM		BOILER OVERHAUL/ ANNUAL MAINTENANCE

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
THAMMINAPATNAM TPS	1	150.00	9/1/25, 3:01PM		TURBINE MISC. PROBLEM
THAMMINAPATNAM TPS	2	150.00	7/7/25, 10:40PM		GENERATOR PROTECTION RELAY OPERATION PROBLEM
THAMMINAPATNAM TPS	3	350.00	10/19/25, 12:37AM		I.D. FANS PROBLEM
THAMMINAPATNAM TPS	4	350.00	11/1/25, 12:00AM		BOILER FEED PUMP/MOTOR PROBLEM
VIZAG TPP	1	520.00	11/27/24, 11:30PM		BOILER INSPECTION/ RE-CERTIFICATION
VIZAG TPP	2		9/27/25, 11:31PM		MISCELLANEOUS
VIZAG TPP	2	520.00	10/18/25, 2:31AM		GEN.PROTECTION RELAY OPERATION
RAMAGUNDEM STPS	3	200.00	7/3/25, 11:30PM	07-07-2025	GENERATOR MISCLLANEOUS MAINTENANCE
RAMAGUNDEM STPS	6	500.00	10/10/25, 12:49PM		ELECTRICAL MISCELLANEOUS PROBLEMS
RAMAGUNDEM STPS	6		8/10/25, 10:15AM		RESERVE SHUT DOWN / STANDBY UNIT
YADADRI TPS	1	800.00	10/30/25, 1:00PM		RSD/LOW SCHEDULE
YADADRI TPS	2	800.00	10/20/25, 9:05PM		BREAKER/ISOLATOR PROBLEM
RAICHUR TPS	2	210.00	4/14/25, 12:26PM	20-04-2025	BOILER AUX. MISC. PROMLEMS
RAICHUR TPS	3	210.00	11/2/25, 5:00AM		BOILER OVERHAUL/ ANNUAL MAINTENANCE
RAICHUR TPS	5	210.00	8/31/25, 9:12AM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	5		8/14/25, 9:34PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	7	210.00	7/27/25, 8:07AM		RSD/LOW SCHEDULE
RAICHUR TPS	8	250.00	8/7/25, 8:45AM	08-08-2025	ECONOMISER TUBE LEAKAGE
KAIGA	1	220.00	3/31/25, 11:11PM		MISCELLANEOUS PLANNED MAINTENANCE
KUDGI STPP	2	800.00	5/31/25, 1:35PM		RSD/LOW SCHEDULE
BELLARY TPS	1	500.00	5/24/25, 12:09AM	06-06-2025	RSD/LOW SCHEDULE
BELLARY TPS	3	700.00	4/10/25, 4:08AM	13-04-2025	ECONOMISER TUBE LEAKAGE
BELLARY TPS	3		5/26/25, 2:28PM		WATER WALL TUBE LEAKAGE
TUTICORIN TPS	1	210.00	3/15/25, 9:50PM		FIRE IN CABLE GALLERY.
TUTICORIN TPS	2		3/15/25, 10:01PM		FIRE IN CABLE GALLERY
TUTICORIN TPS	2		3/15/25, 5:30AM		RESERVE SHUT DOWN / STANDBY UNIT
TUTICORIN TPS	2		3/14/25, 12:01AM	15-03-2025	BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	2	210.00	3/5/25, 12:21AM		REHEATER TUBE LEAKAGE
TUTICORIN TPS	3		5/28/25, 8:47AM		BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	3		5/20/25, 11:40PM		BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	3		11/2/25, 10:55AM	03-11-2025	TURBINE PIPES AND VALVES PROBLEM

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
TUTICORIN TPS	3	210.00	4/7/25, 12:02AM		BOILER MISC. PROBLEM
TUTICORIN TPS	3		8/15/25, 11:29AM		DRUM LEVEL HIGH/ low
TUTICORIN TPS	4		7/15/25, 8:02PM		CONDENSER LOW VACCUM
TUTICORIN TPS	4		4/9/25, 10:05PM		CONDENSER LOW VACCUM
TUTICORIN TPS	4		9/18/25, 7:16PM		CONDENSER TUBE LEAKAGE/ CLEANING
TUTICORIN TPS	4	210.00	10/31/25, 3:04PM		BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	5	210.00	9/14/25, 10:48AM		CONDENSER TUBE LEAKAGE/ CLEANING
TUTICORIN TPS	5		11/5/25, 2:05PM	05-12-2025	BOILER OVERHAUL/ ANNUAL MAINTENANCE
METTUR TPS	3	210.00	9/24/25, 1:16AM	25-12-2025	BOILER AUX. MISC. PROMLEMS
NORTH CHENNAI TPS STAGE 1	2	210.00	11/11/25, 3:43AM	19-12-2025	BOILER OVERHAUL/ ANNUAL MAINTENANCE
MUTHIARA TPP	1	600.00	10/10/25, 1:20AM		MILLING SYSTEM /RC FEEDER PROBLEM
NEYVELI TPS-II	2	210.00	8/18/25, 5:20PM		MILLING SYSTEM /RC FEEDER PROBLEM
NEYVELI TPS-II	5		10/24/25, 12:00AM		ANNUAL MAINTENANCE
NEYVELI TPS-II	5	210.00	10/19/25, 11:38AM		RESERVE SHUT DOWN / STANDBY UNIT
NEYVELI TPS-II EXP	2	250.00	10/22/25, 12:27AM		ANNUAL MAINTENANCE
KUDANKULAM	1	1,000.00	8/3/25, 12:00AM	30-09-2025	ANNUAL MAINTENANCE
KUDANKULAM	1		8/1/25, 4:30AM		RSD/LOW SCHEDULE
KUDANKULAM	1		10/3/25, 12:30AM	07-10-2025	MISC. SHORT DURATION PLANNED MAINTENACE
KUDANKULAM	2	1,000.00	10/27/25, 6:06AM	13-01-2026	ANNUAL MAINTENANCE
ITPCL TPP	1	600.00	11/1/25, 11:46AM		RSD/LOW SCHEDULE
ITPCL TPP	2	600.00	5/24/25, 12:53AM		RSD/LOW SCHEDULE
KARAIKAL CCPP	1	32.50	4/15/25, 11:57PM		SCHEDULED ANNUAL MAINTENANCE
OPG Power Generation Private Limited	1	77.00	6/30/25, 11:59PM		RSD/LOW SCHEDULE
OPG Power Generation Private Limited	2	77.00	10/18/25, 11:59PM		RSD/LOW SCHEDULE
OPG Power Generation Private Limited	4	180.00	10/19/25, 12:29AM		RSD/LOW SCHEDULE
NABINAGAR TPP	2	250.00	11/6/25, 12:00AM	20-12-2025	BOILER OVERHAUL/ ANNUAL MAINTENANCE
KAHALGAON TPS	7	500.00	1/22/25, 4:38PM	24-01-2025	CONSERVATION OF MAIN FUEL/RSD
MEJIA TPS	4	210.00	11/9/25, 11:25PM		BOILER OVERHAUL/ ANNUAL MAINTENANCE
TALCHER STPS	5		3/9/25, 10:40PM	09-03-2025	WATER WALL TUBE LEAKAGE
TALCHER STPS	5	500.00	3/10/25, 12:00AM	10-03-2025	WATER WALL TUBE LEAKAGE
DARLIPALI STPS	2	800.00	6/25/25, 5:53PM	15-07-2025	WATER WALL TUBE LEAKAGE

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
KAMALANGA TPS	3	350.00	11/2/25, 3:43AM		SCHEDULED ANNUAL MAINTENANCE
SAGARDIGHI TPS	3	500.00	11/3/25, 12:31AM		BOILER OVERHAUL/ ANNUAL MAINTENANCE
SOUTHERN REPL. TPS	1	67.50	10/3/25, 12:01PM	31-10-2025	RESERVE SHUT DOWN / STANDBY UNIT
SOUTHERN REPL. TPS	2	67.50	12/11/24, 9:25PM	23-02-2025	RESERVE SHUT DOWN / STANDBY UNIT
FARAKKA STPS	4	500.00	10/31/25, 3:28AM		BOILER OVERHAUL/ ANNUAL MAINTENANCE
FARAKKA STPS	5	500.00	9/2/25, 2:43AM		DRUM LEVEL HIGH/ low
NAMRUP CCPP	2	17.00	8/6/25, 9:14AM		GENEATOR TRANSFORMER MISC.
NAMRUP CCPP	6	9.00	8/6/25, 9:10AM		GT-MISCELLANEOUS PROBLEMS
LAKWA GT	6	20.00	6/1/25, 12:00AM	02-06-2025	GRID DISTURBENCE
LAKWA GT	8	37.20	6/1/25, 12:00AM	02-06-2025	GRID DISTURBANCE
LAKWA REPLACEMENT POWER PROJECT	3	9.96	10/14/25, 8:59PM		GRID DISTURBENCE
KATHALGURI CCPP	1	33.50	4/22/25, 12:00AM		MISCELLANOUS
KATHALGURI CCPP	2	33.50	7/16/25, 12:00AM		LOW SYSTEM DEMAND
KATHALGURI CCPP	2		7/16/25, 11:59PM		LOW SYSTEM DEMAND
AGARTALA GT	5	25.50	1/16/25, 12:00AM		Fuel Shortage
MONARCHAK CCPP	2	35.60	7/18/25, 12:14AM		ROTOR EARTH FAULT
Total		57,750.73			

Remarks:-

Report Version :-