

CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION

RECOMMISSIONNING OF THERMAL/NUCLEAR UNITS AS: 27-Nov-2025

Sub - Report 14

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
SURATGARH STPS	7	660.0	11/27/25, 11:28AM		BOILER MISC. PROBLEM
JALIPA KAPURDI TPP	6	135.0	11/22/25, 6:48AM		BOILER MISC. PROBLEM
SHREE CEMENT LTD TPS	3	19.0	11/27/25, 12:15AM		RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	4	19.0	11/27/25, 12:15AM		RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	5	6.0	11/27/25, 12:15AM		RSD/LOW SCHEDULE
OBRA TPS	14	660.0	11/25/25, 9:33PM		WATER WALL TUBE LEAKAGE
DADRI (NCTPP)	3	210.0	11/26/25, 7:04PM		FURNACE DRAFT ABNORMAL
AURAIYA CCPP	1	111.19	11/26/25, 6:36PM		CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	2	111.19	11/26/25, 6:31PM		CONSERVATION OF MAIN FUEL/RSD
SASAN UMTPP	4	660.0	11/26/25, 1:00PM		REHEATER TUBE LEAKAGE
NIWARI TPP	1	45.0	11/18/25, 10:47AM		WATER WALL TUBE LEAKAGE
SEIONI TPP	1	600.0	11/23/25, 11:51PM		WATER WALL TUBE LEAKAGE
SABARMATI (D-F STATIONS)	1	120.0	11/24/25, 12:49PM		GENERATOR MISCLLANEOUS MAINTENANCE
SABARMATI (D-F STATIONS)	3	121.0	11/11/25, 12:01AM		BOILER OVERHAUL/ ANNUAL MAINTENANCE
SURAT LIG. TPS	4	125.0	11/22/25, 10:20PM		WATER WALL TUBE LEAKAGE
GANDHAR CCPP	2	144.3	11/26/25, 6:29PM		CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	3	144.3	11/26/25, 6:30PM		CONSERVATION OF MAIN FUEL/RSD
RAICHUR TPS	7	210.0	11/26/25, 7:02PM		GEN. TRANSORMER PROTECTION RELAY OPERATION PROBLEM
ADANI POWER LIMITED UDUPI TPP	1	600.0	11/23/25, 11:44AM		BOILER MISC. PROBLEM
NORTH CHENNAI TPS STAGE 1	1	210.0	11/27/25, 2:23PM		DRUM LEVEL LOW
TELANGANA STPP PH-1	1	800.0	11/24/25, 5:38AM		WATER WALL TUBE LEAKAGE
Dr. N.TATA RAO TPS	8	800.0	11/24/25, 11:55PM		TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE
TALCHER STPS	2	500.0	11/22/25, 11:24PM		WATER WALL TUBE LEAKAGE
LAKWA REPLACEMENT POWER PROJECT	2	9.965	11/26/25, 7:33PM		GRID DISTURBENCE
KATHALGURI CCPP	7	30.0	11/27/25, 12:00AM		MISC. SHORT DURATION MAINTENANCE

Total	7050.95			
-------	---------	--	--	--

Remarks:-

Report Version :-