

CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION

THERMAL/NUCLEAR UNITS OUT OF GRID FOR MORE THAN 15 DAYS DURING 2025-26 as on: 28-Mar-2026

Sub - Report 12

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
PRAGATI CCPP	1		5/25/25, 2:19 PM	25-05-2025	LOW SYSTEM DEMAND
PRAGATI CCPP	1	104.60	5/25/25, 7:15 PM	25-05-2025	MISCELLANOUS
PRAGATI CCPP	1		7/28/25, 4:31 PM	28-07-2025	MISCELLANOUS
PRAGATI CCPP	1		7/17/25, 10:45 PM	25-07-2025	Low system demand/ costly fuel
PRAGATI CCPP	1		6/29/25, 4:39 AM	29-06-2025	GRID DISTURBENCE
PRAGATI CCPP	1		7/25/25, 10:15 AM	26-07-2025	GT- LUB OIL SYSTEM PROB.
PRAGATI CCPP	1		1/13/26, 8:11 PM		Low system demand/ costly fuel
PRAGATI CCPP	1		7/9/25, 5:36 PM	09-07-2025	GRID DISTURBENCE
PRAGATI CCPP	1		12/31/25, 3:02 AM	01-01-2026	GT-MISCELLANEOUS PROBLEMS
PRAGATI CCPP	1		5/19/25, 4:49 PM	20-05-2025	MINOR MAINTENANCE WORKS
PRAGATI CCPP	2		5/2/25, 5:22 AM	02-05-2025	GRID DISTURBENCE
PRAGATI CCPP	2	104.60	5/22/25, 6:08 PM	22-05-2025	Cooling Water System Abnormal/ Maintenance
PRAGATI CCPP	2		1/6/26, 8:03 PM		Low system demand/ costly fuel
PRAGATI CCPP	2		5/24/25, 2:00 AM	24-05-2025	Cooling Water System Abnormal/ Maintenance
PRAGATI CCPP	2		12/14/25, 7:35 AM	14-12-2025	MINOR MAINTENANCE WORKS
PRAGATI CCPP	2		5/2/25, 11:00 AM	02-05-2025	Electrical Scheduled Maitenance
PRAGATI CCPP	2		6/15/25, 3:53 AM	15-06-2025	GRID DISTURBENCE
PRAGATI CCPP	2		5/21/25, 8:21 PM	21-05-2025	GRID DISTURBENCE
PRAGATI CCPP	3		1/6/26, 11:31 AM		Low system demand/ costly fuel
PRAGATI CCPP	3	121.20	5/2/25, 6:22 AM	02-05-2025	GRID DISTURBENCE
PRAGATI CCPP	3		5/2/25, 11:00 AM		Electrical Scheduled Maitenance
YAMUNA NAGAR TPS	2	300.00	2/15/26, 12:22 AM		BOILER OVERHAUL/ ANNUAL MAINTENANCE
RAJIV GANDHI TPS	2	600.00	10/6/25, 10:33 PM		Turbine Misc
MAHATMA GANDHI TPS	2	660.00	3/11/26, 3:42 AM		SCHEDULED ANNUAL MAINTENANCE
MAHATMA GANDHI TPS	2		10/16/25, 11:52 PM		WATER WALL TUBE LEAKAGE
GH TPS (LEH.MOH.)	2		8/25/25, 1:31 PM	29-08-2025	INSPECTION /MTCE
GH TPS (LEH.MOH.)	2	210.00	8/31/25, 11:00 AM	08-09-2025	LOW SYSTEM DEMAND
GH TPS (LEH.MOH.)	2		5/2/25, 9:14 PM	04-05-2025	WATER WALL TUBE LEAKAGE
GH TPS (LEH.MOH.)	2		8/29/25, 8:37 AM	31-08-2025	GT-TURBINE BEARING PROBLEM

THERMAL/NUCLEAR UNITS OUT OF GRID FOR MORE THAN 15 DAYS DURING 2025-26 as on: 28-Mar-2026

Sub - Report 12

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
ROPAR TPS	3	210.00	8/16/25, 10:36 PM		FUEL SUPPLY & OTHER MISC. PROBLEMS
ROPAR TPS	4	210.00	10/17/25, 10:35 AM		FURNACE DRAFT ABNORMAL
ROPAR TPS	5	210.00	10/17/25, 3:22 PM		REHEATER TUBE LEAKAGE
ROPAR TPS	6	210.00	8/10/25, 7:25 AM		REHEATER TUBE LEAKAGE
KOTA TPS	2	110.00	10/28/25, 5:55 AM		BOILER AUX. MISC. PROMLEMS
KOTA TPS	4	210.00	3/3/26, 12:00 AM		BOILER OVERHAUL/ ANNUAL MAINTENANCE
SURATGARH TPS	6	250.00	6/2/25, 7:48 AM		RSD/LOW SCHEDULE
RAMGARH CCPP	1	3.00	5/9/25, 4:07 PM		Fuel Shortage
HARDUAGANJ TPS	9	250.00	1/14/26, 10:03 PM		RESERVE SHUT DOWN / STANDBY UNIT
PANKI TPS EXT	1	660.00	3/4/26, 9:00 PM		RSD/LOW SCHEDULE
PANKI TPS EXT	1		7/9/25, 3:30 PM		ELECTRICAL MISCELLANEOUS PROBLEMS
SINGRAULI STPS	7	500.00	3/8/26, 11:31 PM		BOILER OVERHAUL/ ANNUAL MAINTENANCE
UNCHAHAR TPS	6	500.00	3/10/26, 12:49 AM		BOILER OVERHAUL/ ANNUAL MAINTENANCE
GHATAMPUR TPP	2	660.00	1/29/26, 7:00 AM	07-02-2026	COAL FEEDING PROBLEM IN PLANT
TANDA TPS	1	110.00	6/30/25, 11:05 PM	04-09-2025	CONSERVATION OF MAIN FUEL/RSD
TANDA TPS	2	110.00	6/30/25, 11:17 PM	04-09-2025	CONSERVATION OF MAIN FUEL/RSD
TANDA TPS	3	110.00	8/31/25, 11:58 PM	04-09-2025	CONSERVATION OF MAIN FUEL/RSD
TANDA TPS	4	110.00	8/31/25, 11:58 PM		RESERVE SHUT DOWN / STANDBY UNIT
KUNDARKI TPS	1	45.00	10/11/25, 11:41 PM		RSD/LOW SCHEDULE
KUNDARKI TPS	2	45.00	2/6/26, 4:13 PM		BOILER OVERHAUL/ ANNUAL MAINTENANCE
UTRAULA TPS	1		10/11/25, 11:43 PM		RSD/LOW SCHEDULE
UTRAULA TPS	1	45.00	2/7/26, 10:11 PM		RSD/LOW SCHEDULE
UTRAULA TPS	1		2/16/26, 12:00 AM		ESP PROBLEM
UKAI TPS	3		11/13/25, 10:10 PM		WATER WALL TUBE LEAKAGE
UKAI TPS	3	200.00	11/20/25, 12:00 AM		R AND M / REFURBISHMENT works
UKAI TPS	3		6/26/25, 1:57 PM		TURBINE MISC.
UKAI TPS	3		11/15/25, 3:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
GANDHI NAGAR TPS	3	210.00	7/23/25, 11:28 AM		BOILER MISC. PROBLEM
GANDHI NAGAR TPS	4	210.00	11/14/25, 6:54 PM		RSD/LOW SCHEDULE
GANDHI NAGAR TPS	4		12/20/25, 12:00 AM		SCHEDULED ANNUAL MAINTENANCE
GANDHI NAGAR TPS	4		7/23/25, 11:53 AM		BOILER MISC. PROBLEM

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
GANDHI NAGAR TPS	5	210.00	11/15/25, 12:02 AM		SCHEDULED ANNUAL MAINTENANCE
UTRAN CCPP	5	240.00	5/19/25, 8:00 AM		MISC. SHORT DURATION PLANNED MAINTENACE
UTRAN CCPP	5		5/17/25, 10:43 PM		RESERVE SHUT DOWN / STANDBY UNIT
UTRAN CCPP	6		5/19/25, 8:00 AM		MISC. SHORT DURATION PLANNED MAINTENACE
UTRAN CCPP	6	134.00	5/17/25, 10:40 PM		RESERVE SHUT DOWN / STANDBY UNIT
HAZIRA CCPP EXT	1	351.00	6/15/25, 1:22 AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	3		4/17/25, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	3		4/18/25, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
DHUVARAN CCPP	3		4/1/25, 12:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	3		4/2/25, 12:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	3		4/4/25, 12:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	3		4/3/25, 12:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	3		4/18/25, 12:00 AM		RESERVE SHUT DOWN/ STANDBY.
DHUVARAN CCPP	3		4/8/25, 12:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	3	72.00	4/17/25, 12:00 AM		RESERVE SHUT DOWN/ STANDBY.
DHUVARAN CCPP	4		4/18/25, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	4		8/26/25, 10:18 PM		RESERVE SHUT DOWN/ STANDBY.
DHUVARAN CCPP	4		4/25/25, 7:26 PM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	4		4/8/25, 12:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	4	40.00	4/1/25, 12:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	4		4/2/25, 12:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	4		4/4/25, 12:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	4		4/17/25, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	4		4/3/25, 12:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	5		4/18/25, 11:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	5		4/18/25, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	5		4/1/25, 12:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	5		9/11/25, 7:20 PM		RESERVE SHUT DOWN
DHUVARAN CCPP	5		4/8/25, 12:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	5		4/4/25, 12:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	5		8/12/25, 12:00 AM		RESERVE SHUT DOWN/ STANDBY.

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
DHUVARAN CCPP	5		4/17/25, 12:00 AM		RESERVE SHUT DOWN/ STANDBY.
DHUVARAN CCPP	5		4/17/25, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	5		4/18/25, 12:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	5		4/3/25, 12:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	5		4/2/25, 12:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	5	376.10	5/9/25, 12:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
WANAKBORI TPS	3	210.00	5/29/25, 1:33 PM		TURBINE MISC. PROBLEM
WANAKBORI TPS	4	210.00	4/8/25, 10:33 PM		WATER WALL TUBE LEAKAGE
WANAKBORI TPS	5	210.00	5/25/25, 2:09 PM		TURBINE BEARING PROBLEM
WANAKBORI TPS	6	210.00	1/1/26, 6:47 PM		RSD/LOW SCHEDULE
KUTCH LIG. TPS	3		7/29/25, 10:06 AM		WATER WALL TUBE LEAKAGE
KUTCH LIG. TPS	3		1/13/26, 6:00 PM		RSD/LOW SCHEDULE
KUTCH LIG. TPS	3	75.00	1/11/26, 11:32 AM		AIR PREHEATERS PROBLEM
SUGEN CCPP	2	382.50	7/27/25, 12:00 AM		RSD/LOW SCHEDULE
SUGEN CCPP	2		3/4/26, 12:00 AM	05-03-2026	RSD/LOW SCHEDULE
SURAT LIG. TPS	2	125.00	7/28/25, 4:27 AM		WATER WALL TUBE LEAKAGE
MUNDRA UMTTP	1	800.00	7/3/25, 11:54 AM		AIR PREHEATERS PROBLEM
MUNDRA UMTTP	2	800.00	7/2/25, 10:59 PM		F.D. FANS PROBLEM
MUNDRA UMTTP	3	800.00	7/2/25, 12:22 AM		TURBINE CONTROL VALVE PROBLEM
MUNDRA UMTTP	4	800.00	7/1/25, 8:55 AM		COOLING WATER SYSTEM PROBLEM/PIPES REPLACE
MUNDRA UMTTP	5	800.00	7/2/25, 8:55 AM		TURBINE MISC. PROBLEMS
SHREE SINGAJI TPP	4	660.00	2/10/26, 12:04 AM		CAPITAL MAINTENANCE
SANJAY GANDHI TPS	4	210.00	1/21/26, 12:00 AM		BOILER OVERHAUL/ ANNUAL MAINTENANCE
NIWARI TPP	1	45.00	2/20/26, 12:25 AM		BOILER MISC. PROBLEM
SEIONI TPP	1	600.00	5/6/25, 6:38 PM		ELECTRICAL MISCELLANEOUS PROBLEMS
VINDHYACHAL STPS	12	500.00	3/8/26, 12:05 AM	29-03-2026	OVERHAULING WORKS
PATHADI TPP	2	300.00	12/7/25, 3:30 AM		BOILER MISC. PROBLEM
RATIJA TPS	1	50.00	5/9/25, 12:00 AM		BOILER AUX. MISC. PROMLEMS
RATIJA TPS	1		5/10/25, 11:59 AM	12-05-2025	BOILER MISC. PROBLEM
RATIJA TPS	2	50.00	1/31/26, 9:45 PM		I.D. FANS PROBLEM
JSW Mahanadi Power Company Limited	2	600.00	10/11/25, 9:00 PM		RESERVE SHUT DOWN / STANDBY UNIT

Station	Unit No.	Capacity(MW)	Date & Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
URAN CCPP	5		2/18/26, 3:09 PM	18-02-2026	INSTRUMENTATION PROBLEM
URAN CCPP	5		5/2/25, 12:32 AM		BEARING
URAN CCPP	5	108.00	3/10/26, 10:43 AM	12-03-2026	Fuel Shortage
URAN CCPP	6	108.00	4/13/25, 7:59 PM		TRANSMISSION CONSTRAINTS
URAN CCPP	7	108.00	3/6/26, 4:22 PM		FUEL SUPPLY & OTHER MISC. PROBLEMS
JSW RATNAGIRI TPP	1	300.00	2/17/26, 9:41 PM		TURBINE VIBRATIONS HIGH
RATNAGIRI CCPP	4	213.00	12/26/25, 7:50 PM		GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	5	213.00	12/26/25, 7:21 PM		GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	6	237.54	12/26/25, 7:47 PM		GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	7	213.00	12/26/25, 7:32 PM		GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	8	213.00	12/26/25, 8:08 PM		GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	9	237.54	12/26/25, 8:08 PM		GT- LOW SYSTEM DAMAND
BELA TPS	1	270.00	1/30/26, 4:19 PM	04-04-2026	GENERATOR PROTECTION RELAY OPERATION PROBLEM
TARAPUR	1	160.00	2/18/26, 1:18 PM		ELECTRICAL MISCELLANEOUS PROBLEMS
KOTHAGUDEM TPS (NEW)	10	250.00	1/25/26, 6:30 AM		WATER WALL TUBE LEAKAGE
SINGARENI TPP	1	600.00	5/24/25, 2:34 AM	24-05-2025	WATER WALL TUBE LEAKAGE
RAYALASEEMA TPS	2		4/10/25, 8:21 PM		REHEATER TUBE LEAKAGE
RAYALASEEMA TPS	2		8/26/25, 1:12 PM		WATER WALL TUBE LEAKAGE
RAYALASEEMA TPS	2	210.00	7/22/25, 7:05 PM		WATER WALL TUBE LEAKAGE
RAYALASEEMA TPS	3		8/27/25, 2:57 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAYALASEEMA TPS	3	210.00	8/31/25, 2:00 PM		ECONOMISER TUBE LEAKAGE
RAYALASEEMA TPS	4	210.00	8/12/25, 4:49 AM		ECONOMISER TUBE LEAKAGE
RAYALASEEMA TPS	5	210.00	10/1/25, 9:35 AM		TURBINE VIBRATIONS HIGH
RAYALASEEMA TPS	5		1/13/26, 12:18 PM		AIR PREHEATERS PROBLEM
SIMHAPURI TPS	3	150.00	10/19/25, 12:06 AM		P.A. FANS PROBLEM
MEENAKSHI ENERGY LTD	1	150.00	9/1/25, 3:01 PM	08-02-2026	BOILER MISC. PROBLEM
MEENAKSHI ENERGY LTD	2	150.00	7/7/25, 10:40 PM		GENERATOR PROTECTION RELAY OPERATION PROBLEM
VIZAG TPP	2		10/18/25, 2:31 AM		GEN.PROTECTION RELAY OPERATION
VIZAG TPP	2	520.00	9/27/25, 11:31 PM		MISCELLANEOUS
RAMAGUNDEM STPS	6	500.00	3/5/26, 1:12 AM	11-03-2026	SUPER HEATER TUBE LEAKAGE
YADADRI TPS	2	800.00	10/20/25, 9:05 PM		BREAKER/ISOLATOR PROBLEM

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
RAICHUR TPS	2	210.00	4/14/25, 12:26 PM	20-04-2025	BOILER AUX. MISC. PROMLEMS
RAICHUR TPS	5		8/31/25, 9:12 AM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	5	210.00	8/14/25, 9:34 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	6	210.00	2/14/26, 12:44 AM		TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE
RAICHUR TPS	7	210.00	7/27/25, 8:07 AM		RSD/LOW SCHEDULE
RAICHUR TPS	8	250.00	8/7/25, 8:45 AM	08-08-2025	ECONOMISER TUBE LEAKAGE
KAIGA	1	220.00	3/31/25, 11:11 PM		MISCELLANEOUS PLANNED MAINTENANCE
BELLARY TPS	1	500.00	5/24/25, 12:09 AM	06-06-2025	RSD/LOW SCHEDULE
BELLARY TPS	3	700.00	5/26/25, 2:28 PM		WATER WALL TUBE LEAKAGE
BELLARY TPS	3		4/10/25, 4:08 AM	13-04-2025	ECONOMISER TUBE LEAKAGE
TUTICORIN TPS	3		5/20/25, 11:40 PM		BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	3	210.00	5/28/25, 8:47 AM		BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	3		4/7/25, 12:02 AM		BOILER MISC. PROBLEM
TUTICORIN TPS	3		11/2/25, 10:55 AM	03-11-2025	TURBINE PIPES AND VALVES PROBLEM
TUTICORIN TPS	3		8/15/25, 11:29 AM		DRUM LEVEL HIGH/ low
TUTICORIN TPS	4		4/9/25, 10:05 PM		CONDENSER LOW VACCUM
TUTICORIN TPS	4		7/15/25, 8:02 PM		CONDENSER LOW VACCUM
TUTICORIN TPS	4	210.00	9/18/25, 7:16 PM		CONDENSER TUBE LEAKAGE/ CLEANING
TUTICORIN TPS	4		10/31/25, 3:04 PM		BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	5	210.00	9/14/25, 10:48 AM		CONDENSER TUBE LEAKAGE/ CLEANING
MUTHIARA TPP	1	600.00	10/10/25, 1:20 AM		MILLING SYSTEM /RC FEEDER PROBLEM
NEYVELI TPS-II	1	210.00	12/2/25, 7:59 AM		I.D. FANS PROBLEM
NEYVELI TPS-II	2	210.00	8/18/25, 5:20 PM		MILLING SYSTEM /RC FEEDER PROBLEM
NEYVELI TPS-II	3	210.00	11/24/25, 9:20 AM		COAL FEEDING PROBLEM IN PLANT
NEYVELI TPS-II	4	210.00	11/15/25, 10:22 AM		WATER WALL TUBE LEAKAGE
NEYVELI TPS-II	5	210.00	10/19/25, 11:38 AM		RESERVE SHUT DOWN / STANDBY UNIT
NEYVELI TPS-II	6		12/1/25, 3:30 PM		BOILER AUX. MISC. PROMLEMS
NEYVELI TPS-II	6	210.00	11/28/25, 11:58 PM		RESERVE SHUT DOWN / STANDBY UNIT
NEYVELI TPS-II	7	210.00	1/4/26, 12:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
KUDANKULAM	1		8/3/25, 12:00 AM	30-09-2025	ANNUAL MAINTENANCE
KUDANKULAM	1	1,000.00	10/3/25, 12:30 AM	07-10-2025	MISC. SHORT DURATION PLANNED MAINTENACE

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
KUDANKULAM	1		8/1/25, 4:30 AM		RSD/LOW SCHEDULE
ITPCL TPP	2	600.00	5/24/25, 12:53 AM		RSD/LOW SCHEDULE
KARAIKAL CCPP	1	32.50	4/15/25, 11:57 PM		SCHEDULED ANNUAL MAINTENANCE
BARAUNI TPS	8	250.00	3/9/26, 11:43 PM	29-03-2026	OVERHAULING WORKS
NABINAGAR TPP	1	250.00	12/4/25, 10:25 AM		STATOR/ STATOR EARTH FAULT
NABINAGAR TPP	2	250.00	12/31/25, 1:30 AM	10-01-2026	GENERATOR STATOR DAMAGED
MEJIA TPS	2	210.00	1/7/26, 8:28 PM		STATOR/ STATOR EARTH FAULT
MEJIA TPS	7	500.00	2/26/26, 12:12 AM		BOILER OVERHAUL/ ANNUAL MAINTENANCE
IB VALLEY TPS	1	210.00	3/6/26, 1:08 AM		AIR PREHEATERS PROBLEM
FARAKKA STPS	6	500.00	2/26/26, 5:03 AM	26-02-2026	TURBINE VIBRATIONS HIGH
NAMRUP CCPP	2	17.00	8/6/25, 9:14 AM		GENERATOR TRANSFORMER MISC.
NAMRUP CCPP	6	9.00	8/6/25, 9:10 AM		GT-MISCELLANEOUS PROBLEMS
LAKWA GT	6	20.00	6/1/25, 12:00 AM	02-06-2025	GRID DISTURBENCE
LAKWA GT	8	37.20	6/1/25, 12:00 AM	02-06-2025	GRID DISTURBANCE
LAKWA REPLACEMENT POWER PROJECT	3	9.96	10/14/25, 8:59 PM		GRID DISTURBENCE
KATHALGURI CCPP	1	33.50	4/22/25, 12:00 AM		MISCELLANOUS
KATHALGURI CCPP	2	33.50	7/16/25, 12:00 AM		LOW SYSTEM DEMAND
KATHALGURI CCPP	2		7/16/25, 11:59 PM		LOW SYSTEM DEMAND
MONARCHAK CCPP	2	35.60	7/18/25, 12:14 AM		ROTOR EARTH FAULT
Total		32,688.35			

" ** " CAPACITY FIGURES ARE TAKEN FROM MONTHLY REPORT OF P.D.M DIVISION AS ON THE LAST DAY OF THE PREVIOUS MONTH

Note: 1.Actual generation is generation from stations above 25 MW. It excludes generation from RES.

2.Data published in this report is for operational purpose only and not for commercial purpose.

3.Generation data/Outage data are compiled based on data submitted directly by the utilities."

Remarks:-

Report Version :-