

**CENTRAL ELECTRICITY AUTHORITY  
G O & D WING  
OPERATION PERFORMANCE MONITORING DIVISION**

**RECOMMISSIONING OF THERMAL/NUCLEAR UNITS AS: 28-Mar-2026**

Sub - Report 14

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
RAJIV GANDHI TPS	1	600.0	3/27/26, 10:38 PM		FURNACE FIRE OUT /FLAME FAILURE
BARSINGSAR LIGNITE	2	125.0	3/24/26, 1:27 PM		BOILER MISC. PROBLEM
SHREE CEMENT LTD TPS	3	19.0	3/28/26, 12:00 AM		RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	4	19.0	3/28/26, 12:00 AM		RSD/LOW SCHEDULE
SINGRAULI STPS	3	200.0	3/27/26, 12:00 AM		SUPER HEATER TUBE LEAKAGE
AKRIMOTA LIG TPS	2	125.0	3/27/26, 12:50 PM		COAL FEEDING PROBLEM IN PLANT
AKRIMOTA LIG TPS	2		3/28/26, 6:14 PM		TURBINE CONTROL VALVE PROBLEM
RAYALASEEMA TPS	6	600.0	3/25/26, 12:52 PM		TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE
KOLAGHAT TPS	5	210.0	3/25/26, 2:58 AM		TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE
HIRANMAYE TPP	1	150.0	3/28/26, 1:04 AM		GENERATOR PROTECTION RELAY OPERATION PROBLEM
AGARTALA GT	4	21.0	3/28/26, 12:00 AM		Fuel Shortage
AGARTALA GT	6	25.5	3/28/26, 12:00 AM		MISCELLANEOUS PLANNED MAINTENANCE
LAKWA REPLACEMENT POWER PROJECT	4	9.965	3/28/26, 12:00 AM		SCHEDULED ANNUAL MAINTENANCE
KATHALGURI CCPP	5	33.5	3/28/26, 12:00 AM		Low system demand/ costly fuel
<b>Total</b>		2137.97			

" \*\* " CAPACITY FIGURES ARE TAKEN FROM MONTHLY REPORT OF P.D.M DIVISION AS ON THE LAST DAY OF THE PREVIOUS MONTH

Note: 1.Actual generation is generation from stations above 25 MW. It excludes generation from RES.

2.Data published in this report is for operational purpose only and not for commercial purpose.

3.Generation data/Outage data are compiled based on data submitted directly by the utilities."

**Remarks:-**

**Report Version :-**