

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 28-Mar-2026

Sub - Report 15

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
PANIPAT TPS	6	210.00	3/28/26, 12:41 PM	2026-03-31	BOILER AUX. MISC. PROMLEMS
INDIRA GANDHI STPP	1	500.00	3/28/26, 12:00 AM		RSD/LOW SCHEDULE
INDIRA GANDHI STPP	2	500.00	3/28/26, 4:30 AM		ELECTRICAL MISCELLANEOUS PROBLEMS
SHREE CEMENT LTD TPS	3	19.00	3/28/26, 12:00 AM	2026-03-28 17:30:00	RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	4	19.00	3/28/26, 12:00 AM	2026-03-28 17:28:00	RSD/LOW SCHEDULE
MEJA STPP	2	660.00	3/28/26, 3:30 AM		WATER WALL TUBE LEAKAGE
GHATAMPUR TPP	2	660.00	3/28/26, 10:39 PM		I.D. FANS PROBLEM
Vedanta Ltd Chhattisgarh TPP	1	600.00	3/28/26, 12:00 AM	2026-04-04	CONDENSER LOW VACCUM
SASAN UMTPP	5	660.00	3/28/26, 8:44 PM		REHEATER TUBE LEAKAGE
UKAI TPS	5	210.00	3/28/26, 11:19 AM		RSD/LOW SCHEDULE
AKRIMOTA LIG TPS	1	125.00	3/28/26, 10:12 PM		COAL FEEDING PROBLEM IN PLANT
AKRIMOTA LIG TPS	2	125.00	3/28/26, 6:14 PM	2026-03-28 21:52:00	TURBINE CONTROL VALVE PROBLEM
SUGEN CCPP	1	382.50	3/28/26, 12:00 AM	2026-03-31	RESERVE SHUT DOWN / STANDBY UNIT
SUGEN CCPP	3	382.50	3/28/26, 12:00 AM		RSD/LOW SCHEDULE
NEYVELI TPS-II	5	210.00	3/28/26, 9:40 AM		RESERVE SHUT DOWN / STANDBY UNIT
RAMAGUNDEM STPS	2	200.00	3/28/26, 10:15 AM		RSD/LOW SCHEDULE
RAMAGUNDEM STPS	4	500.00	3/28/26, 10:51 AM		RSD/LOW SCHEDULE
RAMAGUNDEM STPS	5	500.00	3/28/26, 10:30 AM		RSD/LOW SCHEDULE
RAMAGUNDEM STPS	7	500.00	3/28/26, 10:12 AM		RSD/LOW SCHEDULE
TELANGANA STPP PH-1	2	800.00	3/28/26, 10:20 AM		RSD/LOW SCHEDULE
YADADRI TPS	2	800.00	3/28/26, 1:52 PM		BOILER AUX. MISC. PROMLEMS
BARH STPS	1	660.00	3/28/26, 6:04 PM	2026-03-28	GENERATOR PROTECTION
SAGARDIGHI TPS	2	300.00	3/28/26, 12:16 PM		AIR PREHEATERS PROBLEM
HIRANMAYE TPP	1	150.00	3/28/26, 1:04 AM	2026-03-28 03:39:00	GENERATOR PROTECTION RELAY OPERATION PROBLEM
JSW Energy Utkal Limited	2	350.00	3/28/26, 8:17 PM	2026-03-31	TURBINE MISC. PROBLEM
AGARTALA GT	4	21.00	3/28/26, 12:00 AM	2026-03-28 23:59:59	Fuel Shortage
AGARTALA GT	6	25.50	3/28/26, 12:00 AM	2026-03-28 23:59:59	MISCELLANEOUS PLANNED MAINTENANCE
LAKWA REPLACEMENT POWER PROJECT	4	9.96	3/28/26, 12:00 AM	2026-03-28 18:07:00	SCHEDULED ANNUAL MAINTENANCE
LAKWA REPLACEMENT POWER PROJECT	4		3/28/26, 6:47 PM		GRID DISTURBENCE

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 28-Mar-2026

Sub - Report 15

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
KATHALGURI CCPP	5	33.50	3/28/26, 12:00 AM	2026-03-28 23:59:59	Low system demand/ costly fuel
Total		10112.97			

" ** " CAPACITY FIGURES ARE TAKEN FROM MONTHLY REPORT OF P.D.M DIVISION AS ON THE LAST DAY OF THE PREVIOUS MONTH

Note: 1.Actual generation is generation from stations above 25 MW. It excludes generation from RES.

2.Data published in this report is for operational purpose only and not for commercial purpose.

3.Generation data/Outage data are compiled based on data submitted directly by the utilities."

Remarks:-

Report Version :-