

CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION

RECOMMISSIONNING OF THERMAL/NUCLEAR UNITS AS ON: 28-09-2023

Sub-Report - 14

Station	Unit No	Capacity (MW)	Date of Maintanance	Sync Date	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
ROPAR TPS	4	210.00	16/09/2023 23:59	28/09/2023 21:48	LOW SYSTEM DEMAND
ANTA CCPP	1	88.71	27/09/2023 22:55	28/09/2023 16:06	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	2	88.71	27/09/2023 22:55	28/09/2023 16:23	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	3	88.71	27/09/2023 22:55	28/09/2023 16:48	CONSERVATION OF MAIN FUEL/RSD
RAMGARH CCPP	4	37.50	28/09/2023 11:35	28/09/2023 12:30	DRUM LEVEL HIGH/ low
RAMGARH CCPP	5	110.00	27/09/2023 18:00	28/09/2023 15:00	FUEL SUPPLY & OTHER MISC. PROBLEMS
AURAIYA CCPP	1	111.19	27/09/2023 23:00	28/09/2023 17:09	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	2	111.19	27/09/2023 22:43	28/09/2023 17:51	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	3	111.19	27/09/2023 22:57	28/09/2023 17:02	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	4	111.19	27/09/2023 22:58	28/09/2023 17:07	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	1	130.19	27/09/2023 22:58	28/09/2023 16:33	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	2	130.19	27/09/2023 22:58	28/09/2023 16:52	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	3	130.19	27/09/2023 22:58	28/09/2023 16:43	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	4	130.19	27/09/2023 22:59	28/09/2023 17:01	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	1	144.30	27/09/2023 22:50	28/09/2023 16:44	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	2	144.30	27/09/2023 22:57	28/09/2023 16:30	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	3	144.30	27/09/2023 23:07	28/09/2023 17:00	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	1	106.00	27/09/2023 22:52	28/09/2023 17:00	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	4	106.00	27/09/2023 22:49	28/09/2023 17:16	CONSERVATION OF MAIN FUEL/RSD
AKRIMOTA LIG TPS	1	125.00	12/08/2023 17:06	28/09/2023 15:15	TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE
BHAVNAGAR CFBC TPP	1	250.00	28/09/2023 19:16	28/09/2023 23:50	CONDENSER TUBE LEAKAGE/ CLEANING
BHAVNAGAR CFBC TPP	1		28/09/2023 12:52	28/09/2023 18:13	WATER WALL TUBE LEAKAGE
WANAKBORI TPS	3	210.00	28/09/2023 10:45	28/09/2023 12:46	FURNACE FIRE OUT /FLAME FAILURE
VINDHYACHAL STPS	2	210.00	07/08/2023 00:32	28/09/2023 21:59	BOILER AUX. MISC. PROMLEMS
Dr. N.TATA RAO TPS	5	210.00	26/09/2023 19:48	28/09/2023 13:33	WATER WALL TUBE LEAKAGE
RAYALASEEMA TPS	1	210.00	26/09/2023 05:21	28/09/2023 07:44	SUPER HEATER TUBE LEAKAGE
METTUR TPS	4	210.00	28/09/2023 07:34	28/09/2023 14:58	RESERVE SHUT DOWN
NORTH CHENNAI TPS	3	210.00	28/09/2023 00:00	28/09/2023 23:25	MILLING SYSTEM /RC FEEDER PROBLEM
TUTICORIN TPS	4	210.00	28/09/2023 07:34	28/09/2023 15:51	RESERVE SHUT DOWN
RAMAGUNDEM STPS	1	200.00	27/09/2023 23:22	28/09/2023 06:34	BOILER FEED PUMP/MOTOR PROBLEM
TALCHER STPS	4	500.00	10/08/2023 01:24	28/09/2023 16:28	OVERHAULING WORKS
DERANG TPP	2	600.00	27/09/2023 13:30	28/09/2023 00:51	TURBINE OIL SYSTEM PROBLEM

Station	Unit No	Capacity (MW)	Date of Maintanance	Sync Date	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
BAKRESWAR TPS	1	210.00	27/09/2023 00:00	28/09/2023 17:51	TURBINE VIBRATION
KATHALGURI CCPP	2	33.50	28/09/2023 00:00	28/09/2023 23:59	Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	2	9.96	28/09/2023 11:10	28/09/2023 15:57	Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	3	9.96	27/09/2023 20:05	28/09/2023 06:19	FUEL OIL SHORTAGE
LAKWA REPLACEMENT POWER PROJECT	5	9.96	27/09/2023 11:47	28/09/2023 06:55	FUEL OIL SHORTAGE
LAKWA REPLACEMENT POWER PROJECT	7	9.96	27/09/2023 20:27	28/09/2023 06:38	FUEL OIL SHORTAGE
AGARTALA GT	3	21.00	28/09/2023 00:00	28/09/2023 23:59	TURBINE MISC.
MONARCHAK CCPP	1	65.40	28/09/2023 04:22	28/09/2023 06:34	MISCELLANEOUS
MONARCHAK CCPP	2	35.60	28/09/2023 04:22	28/09/2023 06:35	MISCELLANEOUS
Total		5,784.41			