

CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 28-09-2023

Sub-Report - 15

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
ANTA CCPP	1	88.71	28/09/2023 21:08	28/09/2023	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	2	88.71	28/09/2023 21:09	28/09/2023	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	3	88.71	28/09/2023 21:09	28/09/2023	CONSERVATION OF MAIN FUEL/RSD
SURATGARH TPS	5	250.00	28/09/2023 21:33		FURNACE DRAFT ABNORMAL
RAMGARH CCPP	4	37.50	28/09/2023 11:35		DRUM LEVEL HIGH/ low
AURAIYA CCPP	1	111.19	28/09/2023 23:00	28/09/2023	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	2	111.19	28/09/2023 22:43	28/09/2023	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	3	111.19	28/09/2023 22:57	28/09/2023	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	4	111.19	28/09/2023 22:58	28/09/2023	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	1	130.19	28/09/2023 21:07	28/09/2023	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	2	130.19	28/09/2023 21:28	28/09/2023	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	3	130.19	28/09/2023 21:25		CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	4	130.19	28/09/2023 21:04	28/09/2023	CONSERVATION OF MAIN FUEL/RSD
AKALTARA TPS	3	600.00	28/09/2023 00:00	06/11/2023	CAPITAL MAINTENANCE
AKALTARA TPS	4	600.00	28/09/2023 05:13		TURBINE VIBRATION HIGH
PATHADI TPP	2	300.00	28/09/2023 06:15		WATER SHORTAGE DUE TO INTERNAL PLANT PROBLEM
GANDHAR CCPP	1	144.30	28/09/2023 20:43	28/09/2023	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	2	144.30	28/09/2023 20:59	28/09/2023	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	3	144.30	28/09/2023 21:14	28/09/2023	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	1	106.00	28/09/2023 21:11	28/09/2023	CONSERVATION OF MAIN FUEL/RSD
BHAVNAGAR CFBC TPP	1	250.00	28/09/2023 19:16		CONDENSER TUBE LEAKAGE/ CLEANING
BHAVNAGAR CFBC TPP	1		28/09/2023 12:52		WATER WALL TUBE LEAKAGE
WANAKBORI TPS	3	210.00	28/09/2023 10:45		FURNACE FIRE OUT /FLAME FAILURE
SUGEN CCPP	2	382.50	28/09/2023 01:23	29/09/2023	RSD/LOW SCHEDULE
PAINAMPURAM TPP	1	660.00	28/09/2023 05:24	30/09/2023	TURBINE MISC. PROBLEM
METTUR TPS	4	210.00	28/09/2023 07:34	28/09/2023	RESERVE SHUT DOWN
METTUR TPS - II	1	600.00	28/09/2023 16:53		WATER WALL TUBE LEAKAGE
NORTH CHENNAI TPS	3	210.00	28/09/2023 00:00		MILLING SYSTEM /RC FEEDER PROBLEM
TUTICORIN TPS	4	210.00	28/09/2023 07:34		RESERVE SHUT DOWN
TUTICORIN TPS	5	210.00	28/09/2023 23:17		BOILER AUX. MISC. PROMLEMS
HALDIA TPP	1	300.00	28/09/2023 21:48		INSTRUMENTATION PROBLEM
KATHALGURI CCPP	2	33.50	28/09/2023 00:00		Fuel Shortage

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
LAKWA REPLACEMENT POWER PROJECT	2	9.96	28/09/2023 11:10		Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	5	9.96	28/09/2023 11:35		Fuel Shortage
AGARTALA GT	3	21.00	28/09/2023 00:00		TURBINE MISC.
MONARCHAK CCPP	1	65.40	28/09/2023 04:22		MISCELLANEOUS
MONARCHAK CCPP	2	35.60	28/09/2023 04:22		MISCELLANEOUS
Total		6975.98			