

**CENTRAL ELECTRICITY AUTHORITY  
G O & D WING  
OPERATION PERFORMANCE MONITORING DIVISION**

**THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 28-11-2024**

Sub-Report - 15

| Station                      | Unit No | Capacity (MW) | Date of Maintanance | Expected/Sync Date of return | remarks                            |
|------------------------------|---------|---------------|---------------------|------------------------------|------------------------------------|
|                              |         |               | DD/MM/YYYY HH:24MM  | DD/MM/YYYY HH:24MM           |                                    |
| 1                            | 2       | 3             | 4                   | 5                            | 6                                  |
| MAHATMA GANDHI TPS           | 1       | 660.00        | 28/11/2024 04:17    |                              | GENEATOR TRANSFORMER MISC.         |
| GH TPS (LEH.MOH.)            | 4       | 250.00        | 28/11/2024 09:13    |                              | BOILER MISC. PROBLEM               |
| ANTA CCPP                    | 1       | 88.71         | 28/11/2024 07:59    | 28/11/2024                   | CONSERVATION OF MAIN FUEL/RSD      |
| ANTA CCPP                    | 3       | 88.71         | 28/11/2024 07:59    | 28/11/2024                   | CONSERVATION OF MAIN FUEL/RSD      |
| KOTA TPS                     | 7       | 195.00        | 28/11/2024 23:28    |                              | DRUM LEVEL HIGH/ low               |
| SURATGARH TPS                | 3       | 250.00        | 28/11/2024 16:00    |                              | STATOR EARTH FAULT                 |
| JALIPA KAPURDI TPP           | 8       | 135.00        | 28/11/2024 04:27    |                              | BOILER MISC. PROBLEM               |
| AURAIYA CCPP                 | 1       | 111.19        | 28/11/2024 07:57    | 28/11/2024                   | CONSERVATION OF MAIN FUEL/RSD      |
| AURAIYA CCPP                 | 2       | 111.19        | 28/11/2024 07:53    | 28/11/2024                   | CONSERVATION OF MAIN FUEL/RSD      |
| AURAIYA CCPP                 | 3       | 111.19        | 28/11/2024 07:55    | 28/11/2024                   | CONSERVATION OF MAIN FUEL/RSD      |
| AURAIYA CCPP                 | 4       | 111.19        | 28/11/2024 07:51    | 28/11/2024                   | CONSERVATION OF MAIN FUEL/RSD      |
| DADRI CCPP                   | 1       | 130.19        | 28/11/2024 07:59    | 28/11/2024                   | CONSERVATION OF MAIN FUEL/RSD      |
| DADRI CCPP                   | 3       | 130.19        | 28/11/2024 07:58    | 28/11/2024                   | NO/REDUCED IRRIGATION DEMAND       |
| DADRI CCPP                   | 4       | 130.19        | 28/11/2024 07:56    | 28/11/2024                   | CONSERVATION OF MAIN FUEL/RSD      |
| OBRA TPS                     | 12      | 200.00        | 28/11/2024 02:56    |                              | FURNACE DRAFT ABNORMAL             |
| OBRA TPS                     | 14      | 660.00        | 28/11/2024 18:12    | 29/11/2024                   | T.B.TEMP./COOLING PROBLEM          |
| GANDHAR CCPP                 | 1       | 144.30        | 28/11/2024 08:01    | 28/11/2024                   | CONSERVATION OF MAIN FUEL/RSD      |
| GANDHAR CCPP                 | 2       | 144.30        | 28/11/2024 08:03    | 28/11/2024                   | CONSERVATION OF MAIN FUEL/RSD      |
| GANDHAR CCPP                 | 3       | 144.30        | 28/11/2024 07:58    | 28/11/2024                   | CONSERVATION OF MAIN FUEL/RSD      |
| KAWAS CCPP                   | 1       | 106.00        | 28/11/2024 07:58    | 28/11/2024                   | NO/REDUCED IRRIGATION DEMAND       |
| KAWAS CCPP                   | 2       | 106.00        | 28/11/2024 07:58    | 28/11/2024                   | CONSERVATION OF MAIN FUEL/RSD      |
| KAWAS CCPP                   | 3       | 106.00        | 28/11/2024 07:58    | 28/11/2024                   | NO/REDUCED IRRIGATION DEMAND       |
| KAWAS CCPP                   | 4       | 106.00        | 28/11/2024 07:58    | 28/11/2024                   | CONSERVATION OF MAIN FUEL/RSD      |
| WANAKBORI TPS                | 8       | 800.00        | 28/11/2024 19:10    |                              | WATER WALL TUBE LEAKAGE            |
| BINA TPS                     | 2       | 250.00        | 28/11/2024 03:23    |                              | DRUM LEVEL LOW                     |
| CHANDRAPUR(MAHARASHTRA) STPS | 4       | 210.00        | 28/11/2024 10:19    |                              | ELECTRICAL MISCELLANEOUS PROBLEMS  |
| CHANDRAPUR(MAHARASHTRA) STPS | 5       | 500.00        | 28/11/2024 08:05    |                              | P.A. FANS PROBLEM                  |
| KORADI TPS                   | 6       | 210.00        | 28/11/2024 22:05    | 29/11/2024                   | ELECTRICAL MISCELLANEOUS PROBLEMS  |
| PAINAMPURAM TPP              | 2       | 660.00        | 28/11/2024 23:16    | 29/11/2024                   | BOILER MISC. PROBLEM               |
| NEYVELI TPS-II               | 3       | 210.00        | 28/11/2024 02:38    |                              | FUEL SUPPLY & OTHER MISC. PROBLEMS |
| NEYVELI TPS-II               | 5       | 210.00        | 28/11/2024 20:05    |                              | WATER WALL TUBE LEAKAGE            |
| TUTICORIN TPS                | 3       | 210.00        | 28/11/2024 11:20    |                              | WATER WALL TUBE LEAKAGE            |

| Station                         | Unit No | Capacity (MW) | Date of Maintanance | Expected/Sync Date of return | remarks                           |
|---------------------------------|---------|---------------|---------------------|------------------------------|-----------------------------------|
|                                 |         |               | DD/MM/YYYY HH:24MM  | DD/MM/YYYY HH:24MM           |                                   |
| 1                               | 2       | 3             | 4                   | 5                            | 6                                 |
| SINGARENI TPP                   | 1       | 600.00        | 28/11/2024 20:13    |                              | WATER WALL TUBE LEAKAGE           |
| TENUGHAT TPS                    | 2       | 210.00        | 28/11/2024 21:22    |                              | WATER WALL TUBE LEAKAGE           |
| FARAKKA STPS                    | 4       | 500.00        | 28/11/2024 14:56    |                              | BOILER MISC. PROBLEM              |
| MEJIA TPS                       | 7       | 500.00        | 28/11/2024 13:10    |                              | DC SUPPLY PROBLEM                 |
| BUDGE BUDGE TPS                 | 1       | 250.00        | 28/11/2024 23:18    | 12/12/2024                   | SCHEDULED ANNUAL MAINTENANCE      |
| KATHALGURI CCPP                 | 3       | 33.50         | 28/11/2024 00:00    |                              | Fuel Shortage                     |
| LAKWA REPLACEMENT POWER PROJECT | 1       | 9.96          | 28/11/2024 09:00    |                              | MISCELLANEOUS PLANNED MAINTENANCE |
| LAKWA REPLACEMENT POWER PROJECT | 2       | 9.96          | 28/11/2024 18:15    |                              | Fuel Shortage                     |
| AGARTALA GT                     | 1       | 21.00         | 28/11/2024 00:00    |                              | MISCELLANEOUS PLANNED MAINTENANCE |
| AGARTALA GT                     | 4       | 21.00         | 28/11/2024 00:00    |                              | MISCELLANEOUS                     |
| MONARCHAK CCPP                  | 1       | 65.40         | 28/11/2024 00:00    |                              | MISCELLANEOUS PLANNED MAINTENANCE |
| MONARCHAK CCPP                  | 2       | 35.60         | 28/11/2024 00:00    |                              | MISCELLANEOUS PLANNED MAINTENANCE |
| Total                           |         | 9736.08       |                     |                              |                                   |