

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 29-07-2025

Sub-Report - 15

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
PANIPAT TPS	8	250.00	29/07/2025 07:59	01/08/2025	TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE
ROPAR TPS	6	210.00	29/07/2025 11:05		GEN. TRANSFORMER TRIPPING/ DAMAGED
RAJPURA TPP	2	700.00	29/07/2025 23:58		H.P. AND L.P. bypass system
CHHABRA-II TPP	6	660.00	29/07/2025 19:54		SUPER HEATER TUBE LEAKAGE
KALISINDH TPS	1	600.00	29/07/2025 19:30		FURNACE EXPLOSION (PUFFING)
ANPARA TPS	4	500.00	29/07/2025 11:18		ECONOMISER TUBE LEAKAGE
PRAYAGRAJ TPP	1	660.00	29/07/2025 13:17		ELECTRICAL FAULT
KORBA-WEST TPS	4	210.00	29/07/2025 05:42		GENERATOR PROTECTION RELAY OPERATION PROBLEM
BANDAKHAR TPP	1	300.00	29/07/2025 13:07	30/07/2025	FUEL OIL PROBLEM
KUTCH LIG. TPS	3	75.00	29/07/2025 10:06		WATER WALL TUBE LEAKAGE
WANAKBORI TPS	3	210.00	29/07/2025 18:25		FURNACE FIRE OUT /FLAME FAILURE
WANAKBORI TPS	3		29/07/2025 20:45		TURBINE MISC. PROBLEM
VINDHYACHAL STPS	7	500.00	29/07/2025 05:29		WATER WALL TUBE LEAKAGE
BHUSAWAL TPS	6	660.00	29/07/2025 10:31		TURBINE MISC. PROBLEM
NORTH CHENNAI TPS	2	210.00	29/07/2025 21:15	30/07/2025	REHEATER TUBE LEAKAGE
KATHALGURI CCPP	2	33.50	29/07/2025 00:00		LOW SYSTEM DEMAND
LAKWA REPLACEMENT POWER PROJECT	2	9.96	29/07/2025 06:51		GRID DISTURBANCES MISC.
Total		5788.47			