

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

RECOMMISSIONING OF THERMAL/NUCLEAR UNITS AS ON: 29-09-2022

Sub-Report - 14

Station	Unit No	Capacity (MW)	Date of Maintanance	Sync Date	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
PANIPAT TPS	8	250.00	28/09/2022 07:43	29/09/2022 23:51	AIR PREHEATERS PROBLEM
ANTA CCPP	3	88.71	28/09/2022 21:01	29/09/2022 16:05	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	1	111.19	28/09/2022 20:38	29/09/2022 17:11	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	2	111.19	28/09/2022 20:55	29/09/2022 16:30	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	1	130.19	28/09/2022 20:46	29/09/2022 17:07	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	2	130.19	28/09/2022 21:00	29/09/2022 16:10	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	3	130.19	28/09/2022 20:59	29/09/2022 18:31	CONSERVATION OF MAIN FUEL/RSD
OBRA TPS	13	200.00	28/09/2022 19:26	29/09/2022 01:42	ELECTRICAL FAULT
OBRA TPS	13		29/09/2022 02:54	29/09/2022 10:04	DRUM LEVEL LOW
OBRA TPS	13		29/09/2022 15:43	29/09/2022 19:45	MAIN STEAM LINE PROBLEM
NAWAPARA TPP	2	300.00	14/09/2022 22:27	29/09/2022 11:39	COAL SHORTAGE
GANDHAR CCPP	1	144.30	28/09/2022 20:32	29/09/2022 17:28	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	2	144.30	28/09/2022 20:54	29/09/2022 16:30	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	3	144.30	28/09/2022 20:42	29/09/2022 16:58	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	1	106.00	28/09/2022 20:31	29/09/2022 17:15	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	2	106.00	28/09/2022 20:52	29/09/2022 17:33	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	4	106.00	28/09/2022 20:46	29/09/2022 16:39	CONSERVATION OF MAIN FUEL/RSD
SHREE SINGAJI TPP	1	600.00	28/09/2022 21:09	29/09/2022 01:17	ELECTRICAL FAULT
NIGRI TPP	1	660.00	29/09/2022 10:15	29/09/2022 15:25	GENERATOR PROTECTION
BHUSAWAL TPS	3	210.00	26/09/2022 16:15	29/09/2022 21:58	WATER WALL TUBE LEAKAGE
CHANDRAPUR(MAHARASHTRA) STPS	7	500.00	28/09/2022 13:40	29/09/2022 12:11	BOILER MISC. PROBLEM
NASIK TPS	3	210.00	18/09/2022 00:02	29/09/2022 07:20	WET/ POOR QUALITY COAL
URAN CCPP	8	108.00	01/09/2022 00:00	29/09/2022 21:23	Fuel Shortage
RAYALASEEMA TPS	5	210.00	27/09/2022 21:33	29/09/2022 09:15	WATER WALL TUBE LEAKAGE
JEGURUPADU CCPP PH I	1	52.80	29/09/2022 01:43	29/09/2022 17:42	G.V.ADJUSTMENT/LIMIT PROB/BUSING/MISC.
JEGURUPADU CCPP PH I	2	52.80	28/09/2022 21:38	29/09/2022 12:31	Fuel Shortage
JEGURUPADU CCPP PH I	4	77.00	28/09/2022 21:30	29/09/2022 15:59	Fuel Shortage
KUDANKULAM	1	1000.00	28/09/2022 19:30	29/09/2022 11:07	FIRE IN GEN. BUSHING/ BUSHING FAILURE
METTUR TPS	2	210.00	28/09/2022 05:52	29/09/2022 13:25	WATER WALL TUBE LEAKAGE
NORTH CHENNAI TPS	4	600.00	27/09/2022 02:24	29/09/2022 23:59	WATER WALL TUBE LEAKAGE
NEYVELI TPS(Z)	1	250.00	28/09/2022 03:49	29/09/2022 18:22	TURBINE MISC.
KAKATIYA TPS	1	500.00	29/09/2022 14:11	29/09/2022 19:24	MISCELLANEOUS ELECTRICAL WORKS

Station	Unit No	Capacity (MW)	Date of Maintanance	Sync Date	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
RAMAGUNDEM-B TPS	1	62.50	26/09/2022 21:30	29/09/2022 04:26	WATER WALL TUBE LEAKAGE
KAHALGAON TPS	2	210.00	14/08/2022 13:22	29/09/2022 23:53	CONSERVATION OF MAIN FUEL/RSD
TENUGHAT TPS	2	210.00	29/09/2022 00:45	29/09/2022 03:02	DRUM LEVEL HIGH/ low
SOUTHERN REPL. TPS	1	67.50	28/09/2022 23:26	29/09/2022 09:25	CONDENSER TUBE LEAKAGE/ CLEANING
KATHALGURI CCPP	9	30.00	29/09/2022 11:03	29/09/2022 14:30	MISCELLANEOUS
LAKWA REPLACEMENT POWER PROJECT	2	9.96	28/09/2022 22:42	29/09/2022 10:24	Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	3	9.96	27/09/2022 11:44	29/09/2022 09:33	Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	4	9.96	29/09/2022 03:24	29/09/2022 08:59	Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	4		29/09/2022 19:56	29/09/2022 23:51	Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	5	9.96	29/09/2022 04:06	29/09/2022 06:36	Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	6	9.96	28/09/2022 00:00	29/09/2022 23:42	Fuel Shortage
AGARTALA GT	5	25.50	29/09/2022 14:24	29/09/2022 15:28	MISCELLANEOUS
AGARTALA GT	5		29/09/2022 10:37	29/09/2022 14:05	MISCELLANEOUS
Total		8,098.49			