

**CENTRAL ELECTRICITY AUTHORITY  
G O & D WING  
OPERATION PERFORMANCE MONITORING DIVISION**

**RECOMMISSIONNING OF THERMAL/NUCLEAR UNITS AS ON: 29-09-2024**

Sub-Report - 14

Station	Unit No	Capacity (MW)	Date of Maintanance	Sync Date	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
SURATGARH TPS	4	250.00	29/09/2024 15:30	29/09/2024 19:56	FURNACE FIRE OUT /FLAME FAILURE
JAWAHARPUR STPP	1	660.00	29/09/2024 04:33	29/09/2024 09:59	TURBINE MISC.
PRAYAGRAJ TPP	2	660.00	25/09/2024 21:15	29/09/2024 11:22	MISCELLANEOUS PLANNED MAINTENANCE
BHILAI TPS	1	250.00	26/09/2024 11:03	29/09/2024 07:14	ECONOMISER TUBE LEAKAGE
PATHADI TPP	1	300.00	26/09/2024 20:04	29/09/2024 19:20	AIR PREHEATERS PROBLEM
UKAI TPS	4	200.00	29/09/2024 08:12	29/09/2024 16:03	EXCITATION SYSTEM FAILURE
WANAKBORI TPS	1	210.00	28/09/2024 10:13	29/09/2024 23:59	RESERVE SHUT DOWN
WANAKBORI TPS	7	210.00	24/09/2024 06:30	29/09/2024 07:00	WATER WALL TUBE LEAKAGE
MUNDRA UMTTP	1	800.00	29/08/2024 13:17	29/09/2024 20:23	COAL FEEDING SYSTEM FAILURE.
MAUDA TPS	3	660.00	23/09/2024 18:52	29/09/2024 04:14	SUPER HEATER TUBE LEAKAGE
URAN CCPP	5	108.00	28/09/2024 20:00	29/09/2024 18:00	RESERVE SHUT DOWN / STANDBY UNIT
RAYALASEEMA TPS	2	210.00	29/09/2024 01:18	29/09/2024 03:45	FURNACE FIRE OUT /FLAME FAILURE
VALLUR TPP	1	500.00	29/09/2024 00:42	29/09/2024 05:52	GENERATOR PROTECTION MISC/BACK UP PROT
METTUR TPS	3	210.00	29/09/2024 09:28	29/09/2024 23:22	TURBINE MISC. PROBLEMS
BOKARO TPS `A` EXP	1	500.00	26/09/2024 04:48	29/09/2024 22:11	WATER WALL TUBE LEAKAGE
SAGARDIGHI TPS	1	300.00	26/09/2024 05:24	29/09/2024 11:10	TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE
SOUTHERN REPL. TPS	2	67.50	28/09/2024 23:35	29/09/2024 08:32	VARIOUS STEAM LEAKAGES
KATHALGURI CCPP	4	33.50	29/09/2024 00:00	29/09/2024 23:59	Fuel Shortage
AGARTALA GT	1	21.00	29/09/2024 00:00	29/09/2024 23:59	Fuel Shortage
AGARTALA GT	2	21.00	29/09/2024 00:00	29/09/2024 23:59	Fuel Shortage
AGARTALA GT	5	25.50	29/09/2024 00:00	29/09/2024 23:59	Fuel Shortage
Total		6,196.50			